



BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Calder B. Clay III

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

Executive Director

& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MINOR SPILL: Thursday, August 1, 2024, 11:20 am – 1:00 pm

REPORT SUBMITTED: Monday, August 5, 2024

LOCATION OF MINOR SPILL: [3040 Greenbriar Road East](#) - MH ID: 58215
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After the blockage was removed, it was determined that the causes of this minor spill were debris and sand.

ESTIMATED VOLUME DISCHARGED: 8,800 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

RECEIVING WATERS: Unnamed ditch feeding Rocky Creek

SERVICE BASIN AFFECTED: Lower Rocky Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Thursday, August 1, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: MWA has hired a contractor that will clean and use CCTV to investigate approximately 2,500 linear feet of 24-inch sewer main to analyze any deterioration and sediment in the sewer line.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones