



**BOARD MEMBERS**

Gary Bechtel

*Chairman*

Frank Patterson

*Vice-Chairman*

Calder B. Clay III

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

*Executive Director*

*& President*

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

[MaconWater.org](http://MaconWater.org)

**MINOR SPILL REPORT TO EPD**

**EPD Watershed Protection Branch**  
**2 Martin Luther King, Jr. Drive**  
**Suite 1152**  
**Atlanta, GA 30334**

**DATE OF MINOR SPILL:** Wednesday, August 7, 2024, 10:35 am – 6:00 pm

**REPORT SUBMITTED:** Friday, August 9, 2024

**LOCATION OF MINOR SPILL:** [3050 Old Bowman Road](#) - MH ID: 65489  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF MINOR SPILL:** After the blockage was removed, it was determined that the cause of this minor spill was due to debris.

**ESTIMATED VOLUME DISCHARGED:** 8,860 gallons  
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**RECEIVING WATERS:** Ditch feeding Beaverdam Creek

**SERVICE BASIN AFFECTED:** Beaverdam Creek

**WRF SERVICE AREA NPDES PERMIT:** GA0024538

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

**SPILL STATUS:** The blockage has been removed; sewage is no longer escaping.

**SIGNS POSTED:** Wednesday, August 7, 2024

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** This line is scheduled to be cleaned and televised and will also be added to the Hotspot Inspection list for monitoring.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

**REPORT SUBMITTED BY:** Bryan Jones