



OVERFLOW REPORT

BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

Executive Director

& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

DATE OF OVERFLOW: Friday, January 24, 2025, 1:34 pm – 3:00 pm

REPORT SUBMITTED: Monday, January 27, 2025

LOCATION OF OVERFLOW: [766 Blanton Boulevard](#) – MH ID: 67088
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After clearing the blockage, we determined that the minor overflow was caused by debris in the sewer main.

ESTIMATED VOLUME DISCHARGED: 688 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Sabbath Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Friday, January 24, 2025

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This line is scheduled for cleaning and CCTV inspection. It will also be added to the Hotspot Inspection list for ongoing monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Bryan Jones