



MACON WATER AUTHORITY

CONTRACT FOR

Plum Street Lane Stormwater **Pipe Rehabilitation**

PROPRIETARY NOTICE

This document is prepared by the Macon Water Authority for the sole purpose of communicating to our vendors. The proprietary information contained herein is based on the requirements of the project. None of the information in this document is to be shared with any third parties without the expressed written consent of the Macon Water Authority.

INDEX

SECTION 00020	Invitation to Bid
SECTION 00100	Instructions to Bidders
SECTION 00210	Federal Employment Affidavits
SECTION 00300	Bid
SECTION 00410	Bid Bond
SECTION 00420	Statement of Bidder's Qualifications
SECTION 00421	Statement of Equipment
SECTION 00422	Corporate Certificate
SECTION 00423	Statement of Disadvantaged Firm Utilization
SECTION 00425	Contractor's License Certification
SECTION 00430	Contractor's Certification of Authority
SECTION 00480	Non-Collusion Affidavit of Prime Bidder
SECTION 00500	Contract Agreement
SECTION 00550	Pre-Award Oath
SECTION 00600	Performance Bond
SECTION 00601	Blank Page – Performance Bond Surety Location
SECTION 00610	Payment Bond
SECTION 00611	Blank Page – Payment Bond Surety Location
SECTION 00700	General Conditions
SECTION 00800	Supplementary Conditions
SECTION 00801	Pay Estimate Summary Sheet
SECTION 01010	Summary of Work
SECTION 01016	Occupancy
SECTION 01020	Allowances
SECTION 01025	Measurement & Payment
SECTION 01091	Codes and Standards
SECTION 01200	Project Meetings
SECTION 01310	Construction Schedules
SECTION 01320	Construction Video and Photographs
SECTION 01340	Shop Drawings, Product Data and Samples
SECTION 01510	Temporary Facilities
SECTION 01540	Job Site Security
SECTION 01569	Safety
SECTION 01610	Transportation and Handling
SECTION 01611	Storage and Protection
SECTION 01710	Cleaning
SECTION 01720	Record Documents
SECTION 01740	Warranties and Bonds

TECHNICAL SPECIFICATIONS

SECTION 02956	CCTV Sewer Inspection
SECTION 06000	Sewer Lining CIPP

END OF INDEX

INVITATION TO BID

THE MACON WATER AUTHORITY
MACON, GEORGIA

Sealed Bids for furnishing all materials, labor, tools, equipment and appurtenances necessary for the installation of Plum Street Lane Stormwater Pipe Rehabilitation (the “Project”) will be received by the Macon Water Authority (the “Owner”), at the Macon Water Authority, 537 Hemlock Street, Human Resources Training Room, Macon, Georgia 31201 until 10:00 A.M., local time, February 25, 2025, and then at said office publicly opened and read aloud. All bidders must attend a mandatory pre-bid meeting at the same location at 10:00 A.M. February 11, 2025. All bid questions must be submitted to the Owner by 10:00 A.M. on February 18, 2025. The Bidder should attend the pre-bid meeting in its entirety.

The Project consists of all necessary labor, material, and time to install CIPP liner in pipe sections as indicated on the drawings.

The Project will be awarded in one Contract. Fifty-one percent (51%) of the Work under the Contract Documents must be self-performed by the General Contractor. The Project will be awarded by base bid on a lump sum basis for the performance and completion of all Work required by the Contract Documents.

The Contract Documents include, but may not be limited to, the Instructions to Bidders, the Contract Agreement, the General Conditions, the Drawings, the Specifications (Divisions 01 through 46, inclusive, where applicable), and the forms of Bid Bond, Performance Bond, and Payment Bond. These and any other Contract Documents may be examined at the following location:

Engineering Department
Macon Water Authority
537 Hemlock Street
Macon, GA 31201

Copies of Contract Documents may be obtained at the office of the Engineer, (River 2 Tap, Inc., 580 West Crossville Rd, Ste 101, Roswell, GA 30075, (770) 569-7038) upon a non-refundable payment of **\$250.00** for each set. A street address must be provided to ensure prompt delivery. No partial sets of bidding documents shall be issued. **Bidders must purchase the Contract Documents in order to be eligible to submit a bid.** Bid documents on the MWA website are for informational purposes only.

Each Bid must be accompanied by a Bid Bond in the amount of 10% of the Bid, prepared on the form of Bid Bond that is part of the Contract Documents, duly executed by the Bidder as principal and having as surety thereon a surety company licensed to do business in the State of Georgia and listed in the latest issue of U.S. Treasury Circular 570.

Bidders must comply with the Disadvantaged Business Enterprise Participation Requirements

specified in the Instructions to Bidders.

The Bidder shall affix to the outside of its Bid envelope the Bidder's Georgia Utility Contractor License Number. A license number of a Utility Manager or a subcontractor is insufficient, and any Bid that fails to affix to the outside of its Bid envelope the Bidder's Georgia Utility Contractor License Number may be rejected.

The successful Bidder for this Project shall be required to furnish a Performance Bond and Payment Bond, satisfactory to the Owner, each in the amount of 100 % of the Contract Price.

Employment of Local Businesses and Contractors: It is the desire of the Owner that local businesses--including disadvantaged, minority, and women enterprise subcontractors-- be given the opportunity to participate on the various parts of the Work.

The Owner's encouragement of participation of disadvantaged, minority, and women enterprises and of locally owned businesses and contractors is not intended to restrict or limit competitive bidding or to increase the cost of the Work. The Owner supports a healthy, free market system that seeks to include responsible local businesses and provide ample opportunities for local business growth and development.

In an effort to assist minority-owned businesses, Georgia law permits an income tax adjustment on the state tax return of any company that subcontracts with a certified minority-owned firm to furnish goods, property or services to the State of Georgia pursuant to O.C.G.A. §48-7-38. Suppliers should consult with their tax advisors to find out how to take advantage of these tax credits.

The Owner reserves the right to reject any or all Bids. The Owner reserves the right to waive informalities and technicalities.

The Macon Water Authority
Ron Shipman
Executive Director & President

END OF SECTION

INSTRUCTIONS TO BIDDERS

1.01 CONTRACT DOCUMENTS

- A. The Bidder's attention is directed to the General Conditions and other Contract Documents, all of which should be reviewed and studied by the Bidders before submitting a Bid.
- B. The Contract Documents shall define and describe the complete Work to which they relate.

1.02 DEFINITIONS

The Bidder's attention is called to the definitions set forth in Article 41 of the General Conditions.

1.03 PREPARATION AND EXECUTION OF BID

- A. Each Bid must be prepared to represent that it is based solely upon the materials and equipment specified in the Contract Documents.
 - 1. *Trade Names.*— When reference is made in the Contract Documents to trade names, brand names, or to the names of manufacturers, such references are made solely to indicate that products of that description may be furnished and are not intended to restrict competitive bidding. Unless requests for approvals of other products have been received and approvals have been published by addendum in accordance with the procedure described below in this Section, the successful Bidder may furnish no products of any trade names, brand names, or manufacturers' names except those designated in the Contract Documents.
 - 2. *Use of other products.*—If a Bidder desires to use products of trade or brand names or of manufacturers' names which are different from those specified in the Contract Documents, application for the approval of the use of such products must be received by the Engineer at least ten (10) days prior to the date set for the opening of Bids. The application to the Engineer for approval of a proposed product must be accompanied by:
 - a. a schedule setting forth in which respects the materials or equipment submitted for consideration differ from the materials or equipment designated in the Contract Documents; and
 - b. a copy of the published recommendations of the manufacturer for the installation of the product together with a complete schedule of changes in the drawings and specifications, if any, which must be made in other work in order to permit the use and installation of the proposed product in accordance with the recommendations of the manufacturer of the product.

In addition, the Engineer will give consideration to reports from reputable independent testing laboratories, verified experience records showing the reputation

- of the proposed product with previous users, evidence of reputation of the manufacturer for prompt delivery, evidence of reputation of the manufacturer for efficiency in servicing its products, or any other written information that is helpful in the circumstances. To be approved, a proposed product must also meet or exceed all express requirements of the Contract Documents.
3. *Burden of proof.*— The degree of proof required for approval of a proposed product as acceptable for use in place of a named product or products is that amount of proof necessary to convince a reasonable person beyond all doubt.
 4. *Request for conference.*—Any Bidder who alleges that rejection of a submittal is the result of bias, prejudice, caprice, or error on the part of the Engineer may request a conference with a representative of the Owner: PROVIDED, that the request for said conference, submitted in writing, shall be received by the Owner at least five (5) days prior to the date set for the opening of Bids, time being of the essence.
 5. *Issuance of addenda.*— If the submittal is approved by the Engineer, an addendum will be issued to all prospective Bidders. Issuance of an addendum is a representation to all Bidders that the Engineer, in the exercise of its professional judgment and discretion, established that the product submitted for approval is acceptable and meets or exceeds all express requirements.
- B. Each Bid must be submitted on the Bid forms which are a part of the Contract Documents. **All blank spaces for Bid prices, both words and figures, must be filled in and completed in ink.** In case of discrepancy, the amount shown in words will govern. All required enclosed certifications or other documents must be fully completed and executed when submitted.
- C. In case of discrepancies between the figures shown in the unit prices and the totals, the unit prices shall apply and the totals shall be corrected to correspond with the unit prices. In case of discrepancies between written amounts and figures, written amounts shall take precedence over figures and the sum of all Bid extensions (of unit prices) plus lump sum items shall take precedence over the Bidders input of the Bid Total.
- D. Each Bid must be submitted in a sealed envelope, addressed to the Macon Water Authority (the “Owner”). Each sealed envelope containing a Bid must be plainly marked on the outside as, “Plum St. Ln. Stormwater Pipe Rehabilitation”.
- E. The Bidder shall provide on the outside of the sealed envelope the following information:
1. Bidder's Name;
 2. Bidder's Georgia Utility Contractor License Number (if applicable); and,
 3. The words, “SEALED BID”
- F. Any Bid submitted which does not contain the above information on the outside of the sealed envelope will not be opened and will be returned to the Bidder.

- G. If forwarded by mail, the sealed envelope containing the Bid must be enclosed in another envelope addressed as follows:
- THE MACON WATER AUTHORITY
Attn: Heather Veal
790 Second Street
Post Office Box 108
Macon, Georgia 31202-0108
- H. Any and all Bids not meeting the aforementioned criteria for Bid submittal may be declared non-responsive, and subsequently returned to the Bidder unopened.
- I. The Bidder, in signing a Bid on the whole or any portion of the Project, shall conform to the following requirements:
1. Bids which are not signed by individuals making the Bid shall have attached thereto a power of attorney evidencing authority to sign the Bid in the name of the person for whom it is signed.
 2. Bids which are signed for a partnership shall be signed by all of the partners or by an attorney-in-fact. If a Bid is signed by an attorney-in-fact, there should be attached to the Bid a power of attorney executed by the partners evidencing authority to sign the Bid.
 3. Bids which are signed for a corporation shall have the correct, legal corporate name thereof, as reflected in the records of the Georgia Secretary of State, and the signature of the president or other authorized officer of the corporation manually written below the corporate name following the wording "By _____." The corporate seal shall be affixed to the Bid.
 4. The Bidder shall complete, execute and submit the following documents, (if applicable to the Bidder) unwhic are a part of the Contract Documents:
 - a. The Bid;
 - b. The Bid Bond;
 - c. Statement of Bidder's Qualifications;
 - d. Statement of Equipment;
 - e. Corporate Certificate, if the Bidder is a corporation;
 - f. Statement of Disadvantaged Business Enterprise ("DBE") compliance;
 - g. Contractor's License Certification;
 - h. Photocopy of State of Georgia Utility Contractor's License;
 - i. Photocopy of Certificate of Authority from Georgia Secretary of State's Office to do work in Georgia (if out of state contractor);
 - j. Non-Collusion Affidavit of Prime Bidder;
 - k. Any and all forms, certifications or other documentation required by the Georgia Department of Natural Resources Environmental Protection Division.

1.04 METHOD OF BIDDING

The unit or lump sum price for each of the several items in the Bid of each Bidder shall include its pro rata share of overhead and profit so that the sum of the products, obtained by multiplying the quantity shown for each item by the unit price, represents the total Bid. Any Bid not conforming to this requirement may be rejected. Additionally, unbalanced Bids (including unbalanced unit prices) may be rejected. Conditional Bids shall not be accepted. *The special attention of all Bidders is called to this provision, for should conditions make it necessary to revise the quantities, no limit will be fixed for such increased or decreased quantities, nor extra compensation allowed.*

1.05 ADDENDA AND INTERPRETATIONS

- A. No interpretation of the meaning of the Drawings, Specifications or other pre-bid documents or Contract Documents shall be made to any Bidder orally.
- B. Any and all such interpretations and any supplemental instructions will be in the form of written Addenda to the Contract Documents which, if issued, will be mailed, shipped or faxed to all prospective Bidders (at the respective addresses furnished) at least seventy-two (72) hours (exclusive of weekends and holidays) prior to the date fixed for the opening of Bids.
- C. Failure of Bidders to receive or acknowledge any Addendum shall not relieve them of any obligation under the Bid or the Contract Documents. All Addenda shall become part of the Contract Documents and obligations there under binding.

1.06 BID MODIFICATIONS

Bidders may modify their Bid by facsimile communication at any time prior to the scheduled closing time for receipt of Bids, provided such facsimile communication is received by the Owner prior to the time Bids are required, and provided further that the Owner is satisfied that a written confirmation of the facsimile modification over the signature of the Bidder was mailed by the Bidder to the Owner prior to the time Bids are required. The facsimile communication should not reveal the Bid price but should provide the addition or subtraction or other modification so that the final prices or terms will not be known by the Owner until the sealed Bid is opened. If written confirmation from the Bidder is not received by the Owner within two business days from the time Bids are required, no consideration will be given to the facsimile modification and the facsimile modification shall be rejected.

1.07 BID SECURITY

- A. Each Bid must be accompanied by a Bid Bond, prepared on the form of Bid Bond included herein, duly executed by the Bidder as principal and having as surety thereon a surety company authorized to do business in the State of Georgia and listed in the latest issue of U.S. Treasury Circular 570, in the amount of **ten (10%)** percent of the

Bid. Attorneys-in-fact who sign Bonds must file with each Bond a currently dated and valid original of their power of attorney. Where validity and currentness of a power of attorney are established by certification executed by a corporate officer, the certification shall be made and executed by a corporate officer of record, as reflected in the records of the Georgia Secretary of State, or by valid corporate resolution or authorization identifying such corporate officer.

- B. Except as provided in O.C.G.A. §§ 36-91-52 and 36-91-53, if for any reason whatsoever the successful Bidder withdraws from the competition after opening of the Bids, or if Bidder refuses to execute and deliver the Contract and Bonds required in Article 2 of the General Conditions, the provisions of the Bid Bond may be enforced.
- C. Except as provided in O.C.G.A. §§ 36-91-52 and 36-91-53, a Bid may not be revoked or withdrawn until sixty (60) days after the time set for opening the Bids. Upon expiration of this time period, the Bid will cease to be valid, unless the Bidder provides written notice to the Owner prior to the scheduled expiration date that the Bid will be extended for a time period specified by the Owner.

1.08 RECEIPT AND OPENING OF BIDS

The Owner may consider a technicality and informality any Bid not prepared and submitted in strict accordance with the provisions hereof and may waive any technicality and informality or reject any and all Bids. Any Bid may be withdrawn prior to the above scheduled time for the opening of Bids or authorized postponement thereof. Any Bid received after the time and date specified shall not be opened.

1.09 CONDITIONS OF THE PROJECT

- A. Each Bidder must be informed fully of the conditions relating to the construction of the Project and the employment of labor thereon. Failure to do so will not relieve a successful Bidder of the obligation to furnish all material and labor necessary to carry out the provisions of the Contract Documents. Insofar as possible, the Bidder, in carrying out the Work, must employ such methods or means as will not cause any interruption of or interference with the work of any other contractor.
- B. The Bidder is advised to examine the location of the Project and to be informed fully as to its conditions; access requirements, the conformation of the ground; the character, quality and quantity of the products needed preliminary to and during the prosecution of the work; the general and local conditions and all other matters which can in any way affect the work to be done under the Contract Documents. Failure to examine the site will not relieve the successful Bidder of an obligation to furnish all products and labor necessary to carry out the provisions of the Contract Documents.
- C. The Bidder shall notify the Owner of the date and time Bidder proposes to examine the location of the Project. The Bidder shall confine examination to the specific areas designated for the proposed construction, including easements and public right-of-ways. If, due to some unforeseen reason, the proceedings for obtaining the proposed construction site (including easements), have not been completed, the Bidder may enter

the site only with the express consent of the property owner. The Bidder is solely responsible for any damages caused by examination of the site.

- D. No permits are anticipated for this project.
- E. All areas of the work are in public right-of-way roads.

1.10 EQUAL EMPLOYMENT OPPORTUNITY

- A. During the performance of the Contract, the Bidder agrees as follows:
 - 1. The Bidder shall not discriminate against any employee or applicant for employment, or in any employment action during employment, based upon any applicable, legally-recognized and protected basis, including, but not limited to, veteran status, uniformed service member status, race, color, religion, sex, sexual orientation, gender identity, age (40 and over), pregnancy (including childbirth, lactation and related medical conditions), national origin or ancestry, citizenship status, physical or mental disability, genetic information (including testing and characteristics), or any other consideration protected by federal, state, or local law.
 - 2. The Bidder shall, in all solicitation or advertisement for employees placed by or on behalf of Bidder, state that all qualified applicants will receive consideration for employment without regard to any applicable, legally-recognized and protected consideration, including, but not limited to veteran status, uniformed service member status, race, color, religion, sex, sexual orientation, gender identity, age (40 and over), pregnancy (including childbirth, lactation and related medical conditions), national origin or ancestry, citizenship status, physical or mental disability, genetic information (including testing and characteristics), or any other characteristic or basis protected by federal, state, or local law.
 - 3. The Bidder shall send to each labor union or representative of the workers, with which the Bidder has a collective bargaining agreement or other contract or understanding, a notice advising the labor union or worker's representative of the Bidder's commitments under the Equal Employment Opportunity Program of the Owner and shall post copies of the notice in conspicuous places available to employees and applicants for employment.
 - 4. The Bidder and its subcontractors, if any, shall file compliance reports at reasonable times and intervals with the Owner in the form and to the extent prescribed by the Owner or the Georgia Department of Natural Resources. Compliance reports filed at such times as directed shall contain information as to the employment practices, policies, programs and statistics of the Bidder and its subcontractors.
 - 5. The Bidder shall demonstrate by the documentation required in Paragraph C, below, that a "Good Faith Effort" has been made to achieve compliance with the Owner's goal that a minimum of ten percent (10%) of the Contract Price shall be subcontracted to a Disadvantaged Business Enterprise (DBE), which includes

business enterprises owned by women and by minorities. More specifically, as used herein, the term “DBE” means a firm or business which is at least fifty-one percent (51%) owned, operated, capitalized, and controlled by one or more United States citizens or lawfully admitted residents who are socially and economically disadvantaged, as defined below.

As used herein, social disadvantage means an individual who is a member of a *presumed group* or who is a *woman*. Economic disadvantage, as used herein, means, generally, a socially disadvantaged individual who does not have a personal net worth in excess of \$1.32 million dollars, excluding the primary residence and ownership in the subject firm.

Member(s) of a *presumed group* include Black Americans (any Black racial group originating in Africa); Hispanic Americans (origins in Mexico, Puerto Rico, Cuba, Central and South America, or other Spanish or Portuguese cultures); Native Americans (Native of Alaska or Hawaii or certified member of a federal or state recognized Tribe); Asian Pacific Americans (origins in the Pacific Islands, China, Taiwan, Korea, Japan, Thailand, Burma, Cambodia, Vietnam, Malaysia, Indonesia, Singapore, or Philippines); and Subcontinent Asian Americans (origins in India, Pakistan, Bangladesh, Bhutan, Maldives Islands, Nepal, or Sri Lanka).

As used herein, the term “subcontracted” means providing subcontracting services or furnishing products or materials to be utilized in the performance of the Work.

6. The Bidder shall include the provisions of paragraphs 1 through 6 of this Section 1.10.A in every subcontract or purchase order so that such provisions will be binding upon each subcontractor or vendor.
- B. In determining whether a Bidder has made “Good Faith Efforts”, the Owner will look not only at the different kinds of effort that a Bidder has made, but also the quantity and intensity of these efforts.
 - C. The following list of kinds of efforts is provided for consideration, but this is not an exhaustive list of efforts that may be considered by the Owner:
 1. Whether the Bidder attended any pre-solicitation or pre-bid meetings that were scheduled by the Agent to inform DBEs of contracting and subcontracting opportunities;
 2. Whether the Bidder advertised in general circulation, trade association, and minority-focus media concerning the sub-contracting opportunities;
 3. Whether the Bidder provided written notice to a reasonable number of specific DBEs that their interest in the Contract was being solicited, in sufficient time to allow the DBEs to participate effectively;
 4. Whether the Bidder followed up initial solicitations of interest by contacting DBEs to determine with certainty whether the DBEs were interested;

5. Whether the Bidder selected portions of the Work to be performed by DBEs in order to increase the likelihood of meeting the DBE goals (including, where appropriate, breaking down contracts into economically feasible units to facilitate DBE participation);
 6. Whether the Bidder provided interested DBEs with adequate information about the Drawings, Specifications and requirements of the Contract Documents;
 7. Whether the Bidder negotiated in good faith with interested DBEs, not rejecting DBEs as unqualified without sound reasons based on a thorough investigation of their capabilities;
 8. Whether the Bidder made efforts to assist interested DBEs in obtaining bonding, lines of credit, or insurance required by the Contract Documents or Contractor; and
 9. Whether the Bidder effectively used the services of available minority or women community organizations; minority or women contractor's groups; local, state and federal minority or women business assistance offices and other organizations that provide assistance in the recruitment and placement of DBEs.
- D. Each Bidder shall include with his or her Bid a Statement of Disadvantaged Firm Utilization. Such statement shall include, as a minimum, the names and addresses of all disadvantaged/minority/women enterprise firms providing subcontracting services, furnishing products or materials, etc., the nature of the work to be contracted; and the anticipated cost of the services by each named firm as a percentage of the total Contract Price set forth in the Bid. The percentage participation should be calculated on the basis of the proportion of total dollar value of the Bid, including bulk purchase materials supplied by DBEs.
- E. It is the desire of the Owner that DBEs be given the opportunity to bid on the various parts of the Work, and that to the extent feasible, DBE firms in the Middle Georgia area will be solicited and used in order to meet the DBE goal set forth above. However, this desire is not intended to restrict or limit competitive bidding or to increase the cost of the Work. The Owner supports a healthy, free market system that seeks to include responsible businesses and provide ample opportunities for business growth and development.

In an effort to assist minority-owned businesses, Georgia law permits an income tax adjustment on the state tax return of any company that subcontracts with a certified minority-owned firm to furnish goods, property or services to the State of Georgia pursuant to O.C.G.A. §48-7-38. Suppliers should consult with their tax advisors to find out how to take advantage of these tax credits.

1.11 NOTICE OF SPECIAL CONDITIONS

If any special federal, state, county or city laws, municipal ordinances, and the rules and regulations of any authorities having jurisdiction over construction of the Project,

enclosed, herein referred to, or applicable by law to the Project, conflict with requirements of the Contract Documents, then the federal, state, county or city laws, municipal ordinances, and the rules and regulations of any authorities having jurisdiction over construction of the Project shall prevail and supersede the conflicting requirements of the Contract Documents.

1.12 OBLIGATION OF BIDDER

- A. By submission of a Bid, each Bidder warrants that Bidder has inspected the site and has read and is thoroughly familiar with the Contract Documents (including all addenda). The failure or omission of any Bidder to examine any form, instrument or document shall in no way relieve any Bidder from any obligation in respect to the Bid.
- B. Special attention is directed to Article 4, "Insurance" contained at pages 00700-3 through 00700-6 in the General Conditions. The Owner requires (1) "Worker's Compensation and Employer's Liability Insurance," (2) "Commercial General and Umbrella Liability Insurance," (3) "Business Auto and Umbrella Liability Insurance," and (4) "Materials and Floater" Insurance. For each of the required policies, the Owner requires a certificate of insurance at least quarterly, a copy of the endorsement of the insurance company showing the Owner as an additional insured, and a copy of the insurance policy declaration and any necessary endorsements.
- C. Attention is further directed to Paragraph 6 of 00500, Contract Agreement and Article 9 of 00700, General Conditions regarding assignments. Prior written consent of the Owner is required for any assignment of any portion of this Contract, including any assignment due to "buyout" of Bidder or other acquisition of Bidder where the Bidder is a corporation or where Bidder is 50 percent or more owned by a corporation, firm, or person.

1.13 METHOD OF AWARD

- A. The Contract, if awarded, will be awarded to the lowest responsible and responsive Bidder whose Bid meets the requirements and criteria set forth in the Contract Documents. The Contract, if awarded, will be awarded by base bid on a lump sum basis for the performance and completion of all Work required by the Contract Documents.
- B. The Bidder to whom the award is made will be notified. The Owner reserves the right to reject any and all Bids and to waive any technicalities and informalities in Bids received whenever such rejection or waiver is in the Owner's interest.
- C. A responsive Bidder shall be one who submits a Bid in the proper form without qualification or intent other than as called for in the Contract Documents, and who binds itself on behalf of the Bid to the Owner with the proper Bid Bond completed and attached, and who properly completes all forms required to be completed and submitted at the time of the Bidding. The Bidder shall furnish all data, documents, forms, and certifications required by the Contract Documents. Failure to do so may result in the Bid being declared non-responsive.

- D. A responsible Bidder shall be one who can fulfill the following requirements:
1. The Bidder shall maintain a permanent place of business. This requirement applies to the Bidder where the Bidder is a division of a corporation, or where the Bidder is 50 percent or more owned by a person, corporation or firm.
 2. The Bidder shall demonstrate adequate construction experience and sufficient equipment resources to properly perform the work under and in conformance with the Contract Documents. This evaluation will be based upon a list of completed or active projects and a list of construction equipment available to the Bidder to perform the work. The Owner may make such investigations as deemed necessary to determine the ability of the Bidder to perform the Work, and the Bidder shall furnish to the Owner all such information and data for this purpose as the Owner may reasonably request. The Owner reserves the right to reject any Bid if the evidence submitted by, or investigation of, such Bidder fails to satisfy the Owner that such Bidder is properly qualified to carry out the obligations of the Contract Documents and to complete the Project contemplated therein.
 3. The Bidder shall demonstrate financial resources of sufficient strength to meet the obligations incident to the performance of the Work covered by the Contract Documents. The ability to obtain the required Performance and Payment Bonds will not alone demonstrate adequate financial capability.

1.14 EMPLOYMENT OF LOCAL LABOR

Preference in employment on the Project shall, insofar as practical, be given to qualified local labor.

END OF SECTION

FEDERAL WORK AUTHORIZATION PROGRAM AFFIDAVITS

**EACH BIDDER MUST PROVIDE THE OWNER WITH THE
PROPERLY COMPLETED AND PROPERLY SIGNED FEDERAL
WORK AUTHORIZATION PROGRAM AFFIDAVITS AS
REQUIRED BY O.C.G.A. § 13-10-91**

**THIS FORM MUST BE COMPLETED BY ALL CONTRACTORS, ALL
SUBCONTRACTORS AND ALL SUB-SUBCONTRACTORS**

THE FORMS ARE ATTACHED HERETO.

Contractor Affidavit under O.C.G.A. § 13-10-91(b)(1)

By executing this affidavit, the undersigned contractor verifies its compliance with O.C.G.A. § 13-10-91, stating affirmatively that the individual, firm or corporation which is engaged in the physical performance of services on behalf of the Macon Water Authority has registered with, is authorized to use and uses the federal work authorization program commonly known as E-Verify, or any subsequent replacement program, in accordance with the applicable provisions and deadlines established in O.C.G.A. § 13-10-91. Furthermore, the undersigned contractor will continue to use the federal work authorization program throughout the contract period and the undersigned contractor will contract for the physical performance of services in satisfaction of such contract only with subcontractors who present an affidavit to the contractor with the information required by O.C.G.A. § 13-10-91(b). Contractor hereby attests that its federal work authorization user identification number and date of authorization are as follows:

Federal Work Authorization User Identification Number

Date of Authorization

Name of Contractor

Name of Project

Name of Public Employer: the Macon Water Authority

I hereby declare under penalty of perjury that the foregoing is true and correct.

Executed on _____, ____, 20__ in _____ (city), _____ (state).

Signature of Authorized Officer or Agent

Printed Name and Title of Authorized Officer or Agent

SUBSCRIBED AND SWORN BEFORE ME
ON THIS THE _____ DAY OF _____, 20__.

NOTARY PUBLIC

My Commission Expires: _____, 20__.

Subcontractor Affidavit under O.C.G.A. § 13-10-91(b)(3)

By executing this affidavit, the undersigned subcontractor verifies its compliance with O.C.G.A. § 13-10-91, stating affirmatively that the individual, firm or corporation which is engaged in the physical performance of services under a contract with _____ [insert name of contractor] on behalf of the Macon Water Authority has registered with, is authorized to use and uses the federal work authorization program commonly known as E-Verify, or any subsequent replacement program, in accordance with the applicable provisions and deadlines established in O.C.G.A. § 13-10-91. Furthermore, the undersigned subcontractor will continue to use the federal work authorization program throughout the contract period and the undersigned subcontractor will contract for the physical performance of services in satisfaction of such contract only with sub-subcontractors who present an affidavit to the subcontractor with the information required by O.C.G.A. § 13-10-91(b). Additionally, the undersigned subcontractor will forward notice of the receipt of an affidavit from a sub-subcontractor to the contractor within five business days of receipt. If the undersigned subcontractor receives notice that a sub-subcontractor has received an affidavit from any other contracted sub-subcontractor, the undersigned subcontractor must forward, within five business days of receipt, a copy of the notice to the contractor. Subcontractor hereby attests that its federal work authorization user identification number and date of authorization are as follows:

Federal Work Authorization User Identification Number

Date of Authorization

Name of Subcontractor

Name of Project

Name of Public Employer: Macon Water Authority

I hereby declare under penalty of perjury that the foregoing is true and correct.

Executed on _____, ____, 20__ in _____ (city), _____ (state).

Signature of Authorized Officer or Agent

Printed Name and Title of Authorized Officer or Agent

SUBSCRIBED AND SWORN BEFORE ME
ON THIS THE _____ DAY OF _____, 20__.

NOTARY PUBLIC

My Commission Expires: _____, 20__.

Sub-subcontractor Affidavit under O.C.G.A. § 13-10-91(b)(4)

By executing this affidavit, the undersigned sub-subcontractor verifies its compliance with O.C.G.A. § 13-10-91, stating affirmatively that the individual, firm or corporation which is engaged in the physical performance of services under a contract for _____ [insert name of subcontractor or sub-subcontractor with whom such sub-subcontractor has privity of contract] and _____ [insert name of contractor] on behalf of the Macon Water Authority has registered with, is authorized to use and uses the federal work authorization program commonly known as E-Verify, or any subsequent replacement program, in accordance with the applicable provisions and deadlines established in O.C.G.A. § 13-10-91. Furthermore, the undersigned sub-subcontractor will continue to use the federal work authorization program throughout the contract period and the undersigned sub-subcontractor will contract for the physical performance of services in satisfaction of such contract only with sub-subcontractors who present an affidavit to the sub-subcontractor with the information required by O.C.G.A. § 13-10-91(b). The undersigned sub-subcontractor shall submit, at the time of such contract, this affidavit to _____ [insert name of subcontractor or sub-subcontractor with whom such sub-subcontractor has privity of contract]. Additionally, the undersigned sub-subcontractor will forward notice of the receipt of any affidavit from a sub-subcontractor to _____ [insert name of subcontractor or sub-subcontractor with whom such sub-subcontractor has privity of contract]. Sub-subcontractor hereby attests that its federal work authorization user identification number and date of authorization are as follows:

Federal Work Authorization User Identification Number

Date of Authorization

Name of Sub-subcontractor

Name of Project

Name of Public Employer

I hereby declare under penalty of perjury that the foregoing is true and correct.

Executed on _____, ____, 20__ in _____ (city), _____ (state).

Signature of Authorized Officer or Agent

Printed Name and Title of Authorized Officer or Agent

SUBSCRIBED AND SWORN BEFORE ME
ON THIS THE _____ DAY OF _____, 20__.

NOTARY PUBLIC

My Commission Expires: _____, 20__.

BID

TO: MACON WATER AUTHORITY

FROM: _____
(Bidder's Name)

FOR: _____

Submitted: _____, 20__

The undersigned Bidder, in compliance with your Invitation to Bid for the construction of this Project, having examined the Contract Documents and the site of the proposed Work, and being familiar with all of the conditions surrounding the construction of the proposed Project, including the availability of materials and labor, hereby proposes to construct the Project in accordance with the Contract Documents.

The Bidder proposes and agrees, if this Bid is accepted, to contract with the Macon Water Authority, in the form of Contract Agreement specified, and to furnish all necessary products, machinery, tools, apparatus, means of transportation and labor necessary to complete the construction of the Work in full and complete accordance with the reasonably intended requirements of the Contract Documents to the full and entire satisfaction of the Macon Water Authority with a definite understanding that no money will be allowed for extra work except as set forth in the Contract Documents, for the following prices:

Item No.	Quantity	Unit	Description	Unit Price	Total Price
1	CIPP REHABILITATION				
a.	1	LS	a. CIPP Pipe Lining of Pipes indicated on contract drawings b. All incidental and specified Work associated with above.		

Total Bid for Items 1 through _____, inclusive, in the amount of

_____ Dollars

(\$ _____) which sum hereinafter is called the "Base Bid".

The Bidder agrees hereby to commence Work under this Contract, with adequate personnel and equipment, on a date to be specified in a written order of the Engineer, and to fully complete all Work under this Contract within 28 consecutive calendar days from and including said date specified in the written order of the Engineer. Bidder further agrees to pay as liquidated damages, the sum of \$250.00 for each calendar day thereafter required to achieve substantial completion of all Work.

The Bidder declares an understanding that the quantities shown for unit price items are subject to either increase or decrease, and that should the quantities of any of the items of Work be increased, the Bidder proposes to do the additional Work at the unit prices stated herein; and should the quantities be decreased, the Bidder also understands that payment will be made on the basis of actual quantities at the unit price bid and will make no claim for additional costs or anticipated profits for any decrease in quantities; and that actual quantities will be determined upon completion of Work, at which time adjustment will be made to the Contract Price by direct increase or decrease.

In case of discrepancies between the figures shown in the unit prices and the totals, the unit prices shall apply and the totals shall be corrected to agree with the unit prices. In case of discrepancies between written amounts and figures, written amounts shall take precedence over figures and the sum of all Bid extensions (of unit prices) plus lump sum items shall take precedence over the Bidder's represented BID TOTAL.

The Bidder furthermore agrees that, in the case of a failure to execute the Contract Agreement and Bonds within ten days after receipt of conformed Contract Documents for execution, the attached Bid Bond accompanying this Bid and the monies payable thereon shall be paid into the funds of the Macon Water Authority as liquidated damages for such failure.

Attached hereto is a Bid Bond for the sum of _____

_____ Dollars (\$ _____) according to the conditions of "Instructions to Bidders" and provisions thereof.

Bidder acknowledges receipt of the Following Addenda:

Addendum No. 1, dated: _____

Addendum No. 2, dated: _____

Addendum No. 3, dated: _____

Addendum No. 4, dated: _____

Remainder of Page Left Blank
[Signatures, attestations, and seal on following page]

BIDDER: _____

By: _____

Name: _____
(Print or Type)

Title: _____

Address: _____

Phone: _____

Attest: _____

Name: _____
(Print or Type)

Title: _____

(SEAL)

Note: Attest for a corporation must be by the secretary of record for the corporation, as reflected in the records of the Georgia Secretary of State; for a partnership by another partner; for an individual by a notary.

Note: If the Bidder is a corporation, the Bid shall be signed by an officer of the corporation; if a partnership, it shall be signed by a partner. If signed by others, authority for signature shall be attached.

The full names and addresses of persons or parties interested in the foregoing Bid, as principals, are as follows:

<u>Name</u>	<u>Address</u>
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

END OF SECTION

BID BOND

STATE OF GEORGIA

COUNTY OF MACON-BIBB

KNOW ALL MEN BY THESE PRESENTS, that we, _____, as Principal, and _____, as Surety, are held and firmly bound unto the Owner, the Macon Water Authority, in the sum of _____ Dollars (\$ _____) lawful money of the United States of America, for the payment of which sum well and truly to be made, we bind ourselves, our heirs, personal representatives, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, the Principal has submitted to the Owner a Bid for the _____.

NOW THEREFORE, the conditions of this obligation are such that if the Bid be accepted, the Principal shall, within ten days after receipt of conformed Contract Documents, execute a Contract in accordance with the Bid upon the terms, conditions and prices set forth therein, and in the form and manner required by the Contract Documents and execute sufficient and satisfactory separate Performance and Payment Bonds payable to the Owner, each in an amount of 100 percent of the total Contract Price, in form satisfactory to the Owner, then this obligation shall be void; otherwise, it shall be and remain in full force and effect in law; and the Surety shall, upon failure of the Principal to comply with any or all of the foregoing requirements within the time specified above, immediately pay to the aforesaid Owner, upon demand, the amount hereof in good and lawful money of the United States of America, not as a penalty, but as liquidated damages.

This bond is given pursuant to and in accordance with the provisions of the Georgia Procurement Manual and Georgia Local Government Public Works Construction Law, O.C.G.A. § 36-91-1 et. seq.. All the provisions of the law referring to this character of bond as set forth in said Manual or Code Sections or as may be hereinafter enacted and these are hereby made a part hereof to the same extent as if set out herein in full.

*Remainder of Page Left Blank
[Signatures, attestations, and seals on following page]*

IN WITNESS WHEREOF, the said Principal has hereunder affixed its signature and seal, and said Surety has hereunto caused to be affixed its corporate signature and seal, by its duly authorized officers, on this _____ day of _____, 20__.

CONTRACTOR - PRINCIPAL: _____

By: _____

Name: _____

(Print or Type)

Address: _____

Phone: _____

Attest: _____

Name: _____

(Print or Type)

Title: _____

(SEAL)

Note: Attest for a corporation must be by the secretary of record for the corporation, as reflected in the records of the Georgia Secretary of State; for a partnership by another partner; for an individual by a notary.

SURETY: _____

By: _____

Name: _____

(Print or Type)

Title: _____

Phone: _____

Attest: _____

Name: _____

(Print or Type)

Title: _____

(SEAL)

Note: Surety companies executing bonds must appear on the Treasury Department's most current list (Circular 570 as amended) and be authorized to transact business in the state where the Project is located.

END OF SECTION

SECTION 00420

STATEMENT OF BIDDER'S QUALIFICATIONS

All questions must be answered and the data given must be clear and comprehensive. This statement must be notarized. If necessary, questions may be answered on separate attached sheets. The Bidder may submit any additional information desired. Attach all additional sheets to this statement.

1. Name of Bidder: _____
2. Permanent main office address: _____
3. When organized: _____
4. If a Corporation, where incorporated: _____
5. How many years have you been engaged in the contracting business under your present firm or trade name? _____
6. Contracts on hand: (Schedule these, showing amount of each contract and the appropriate anticipated dates of completion): _____
7. General description of type of work performed by your company: _____

8. Have you ever failed to complete any work awarded to you? If so, where and why?

9. Have you ever defaulted on a contract? If so, where and why?

10. Attach a list of the most important projects recently completed by your company which are similar in scope to this Project. For each project, list its: official name and owner, a contact person's name, company and position, address and phone number; completion date; and contract amount.
11. Names, background and experience of the principal members of your organization, including officers: _____

Statement of Bidder's Qualifications

12. The undersigned hereby authorizes and requests any person, firm, or corporation to furnish any information requested by the Owner in verification of the recitals comprising this Statement of Bidder's Qualifications.

Dated this _____ day of _____, 20__.

BIDDER: _____

By: _____

Title: _____

State of _____

County of _____

_____ being duly sworn deposes and says that he or she is _____ of _____ and that the answers to the foregoing questions and all statements therein contained are true and correct. Subscribed and sworn to before me this _____ day of _____, 20__.

Notary Public: _____

(SEAL)

My Commission Expires: _____

(Date)

END OF SECTION

SECTION 00421

STATEMENT OF EQUIPMENT

Show machinery and other equipment available to the Bidder for prosecuting the Work required by the Contract Documents. (To be filled in by Bidder and submitted with Bid.)

Available Machinery and Other Equipment	Location	Ownership	Date Proposed To Be Placed On Work
--	----------	-----------	--

The above is a true statement of the equipment available to the undersigned Bidder for prosecuting the Work required by the Contract Documents. Where it is shown that the equipment is not owned by the Bidder, arrangements have been made with the owners to furnish the equipment.

Signed: _____

Name: _____

Title: _____

END OF SECTION

SECTION 00422

CORPORATE CERTIFICATE

I, _____, certify that I am the Secretary of the Corporation named as Bidder in the foregoing Bid; that _____, who signed said Bid on behalf of the Bidder was then _____ of said Corporation; that said Bid was duly signed for and on behalf of said Corporation by authority of its Board of Directors, and is within the scope of its corporate powers; that said Corporation is organized under the laws of the State of _____.

This _____ day of _____, 20____.

(Corporate Secretary) _____

(SEAL)

END OF SECTION

STATEMENT OF DISADVANTAGED FIRM UTILIZATION

The Bidder shall list all disadvantaged firms, as are defined in the Instructions to Bidders, providing subcontracting services, furnishing products or materials, etc., to be utilized in the performance of the work. This list shall be submitted in the following format:

Subcontractor (Name & Address)	Nature of Work to be Contracted	Group (Local, DBE)	Anticipated Cost of Services (\$ Value, %)
			\$
			%
			\$
			%
			\$
			%
			\$
			%
			\$
			%
			\$
			%
			\$
			%
			\$
			%

NOTE: Any proposed changes from the above list shall be submitted in writing to the Macon Water Authority prior to initiation of the action, with the reason for the proposed deviation.

END OF SECTION

SECTION 00425

CONTRACTOR'S LICENSE CERTIFICATION

Contractor's Name: _____

Georgia Contractor's License Number: _____

Expiration Date of License: _____

I certify that the above information is true and correct and that the classification noted is applicable to the Bid for this Project.

Signed: _____

Printed: _____

Date: _____

END OF SECTION

CONTRACTOR'S CERTIFICATION OF AUTHORITY
(IF OUT OF STATE CONTRACTOR)

Contractor's Name: _____

Georgia Certificate of Authority Number: _____

Expiration Date of Certificate: _____

I certify that the above information is true and correct and that the classification noted is applicable to the Bid for this Project.

Signed: _____

Printed: _____

Date: _____

END OF SECTION

SECTION 00480

NON-COLLUSION AFFIDAVIT OF PRIME BIDDER

STATE OF GEORGIA COUNTY OF _____
_____, being first duly sworn, deposes and says that:

He or she is _____
(Owner, Partner, Officer, Representative or Agent)
of _____, the Bidder that has submitted the attached Bid;

He or she is fully informed respecting the preparation and contents of the attached Bid and of all pertinent circumstances respecting such Bid;

He or she understands that collusive bidding is a violation of State and Federal law and can result in fines, prison sentences, and civil damages awards;

Such Bid is genuine and is not a collusive or sham Bid;

Neither the said Bidder nor any of its officers, partners, owners, agents, representatives, employees or parties in interest, including this Affiant, has in any way colluded, conspired, connived or agreed, directly or indirectly with any other Bidder, firm or person to submit a collusive or sham Bid in connection with the Contract for which the attached Bid has been submitted or to refrain from bidding in connection with such Contract, or has in any manner, directly or indirectly, sought by agreement or collusion or communication or conference with any other Bidder, firm or person to fix the price or prices in the attached Bid or of any other Bidder, or to fix any overhead, profit or cost element of the Bid price or the Bid price of any other Bidder, or to secure through any collusion, conspiracy, connivance or unlawful agreement any advantage against the Owner, the Macon Water Authority, or any person interested in the proposed Contract; and

The price or prices quoted in the attached Bid are fair and proper and are not tainted by any collusion, conspiracy, connivance or unlawful agreement on the part of the Bidder or any of its agents, representatives, owners, employees, or parties in interest, including this Affiant. Affiant agrees to abide by all conditions of this Bid, and certifies that he or she is authorized to sign this Bid for the Bidder.

(Signed) _____

(Title) _____

Subscribed and Sworn to before me this _____ day of _____, 20__.

(Notary Public)
(SEAL)

My Commission Expires: _____

Note: If the Bidder is a partnership, all of the partners and any officer, agent or other person who

may have represented or acted for the partnership shall also make the foregoing oath. If the Bidder is a corporation, all officers, agents, or other persons who may have acted for or represented the corporation shall also make the oath.

END OF SECTION

CONTRACT AGREEMENT

AGREEMENT BETWEEN CONTRACTOR AND OWNER

THIS AGREEMENT is made and entered into on the ___ day of _____ in the year Two Thousand and _____ (20___) by and between _____, hereinafter referred to as the “Contractor”, and THE MACON WATER AUTHORITY, hereinafter (the “Owner”) (collectively, “the Parties”).

WITNESSETH, that the Contractor and the Owner, for the consideration hereinafter named, agree as follows:

1. SCOPE OF WORK. - That the Contractor will furnish all products, tools, construction equipment, materials, skill and labor of every description necessary to carry out and to complete in a good, firm, substantial workmanlike manner perform the _____ project and will complete the Work in strict conformity with the Drawings and the Specifications (Divisions 01 through 46, inclusive, together with the foregoing Bid made by the Contractor, the Invitation to Bid, Instructions to Bidders, General and Supplementary Conditions, Special Conditions, Performance and Payment Bonds and all Addenda hereto incorporated (if applicable) which form essential parts of this Contract Agreement, as if fully contained herein, the same collectively referred to as the “Contract Documents.”

2. TIME OF COMPLETION.-The Contractor shall commence the Work to be performed under this Contract Agreement on a date to be specified in a written Notice to Proceed and shall achieve substantial completion of all Work required by the Contract Documents within _____ (_____) consecutive calendar days (the “Contract Time”). Time is of the essence and is an essential element of this Contract, and the Contractor shall pay to the Owner, not as a penalty, but as liquidated damages, the sum of _____ Dollars (\$ _____ .00) for each calendar day for which there is an unexcused delay in achieving substantial completion of the Work within the time limit set forth herein. These liquidated damages are not established as a penalty but are calculated and agreed upon in advance by the Owner and the Contractor due to the uncertainty and impossibility of making a determination as to the actual and consequential damages incurred by the Owner and the general public of Macon-Bibb County, Georgia as a result of the failure on the part of the Contractor to complete the Work on time. Such liquidated damages referred to herein are intended to be and are cumulative and shall be in addition to every other remedy now or hereafter enforceable at law, in equity, by statute, or under the Contract Documents.

3. THE CONTRACT PRICE.-The Owner shall pay to the Contractor for the faithful performance of the Contract Agreement, subject to additions and deductions as provided for in the Contract Documents, in current funds a sum of _____ Dollars (\$ _____ .00) (the “Contract Price”) which sum shall also pay for loss or damage arising out of the nature of the Work aforesaid, or from the action of the elements, or from unforeseen obstructions or difficulties encountered in the prosecution of the Work, and for all expenses incurred by, or in consequence of the Work, its suspension or discontinuance and for well and faithfully completing the Work and the whole thereof, as herein provided, and for replacing

defective Work or products for a period of one year after completion.

4. PROGRESS PAYMENTS The Owner shall make progress payments on account of the Contract Price as follows: On or about the 20th day of each month, ninety-five percent (95%) of the value, based on the contract prices, of labor and materials incorporated in the Work and of materials suitably stored at the site thereof up to the twenty-fifth day of the month preceding, as estimated by the Engineer, less the aggregate of previous payments. Application for Payment must be made on the standard Owner's form to be provided by the Owner to the Contractor. No form of collateral in lieu of cash will be acceptable as retainage. At the discretion of the Owner, the retainage of each Subcontractor may be released separately as each Subcontractor completes its work. An application for release of a Subcontractor's retainage shall bear the certificates of the Subcontractor, the Contractor, and the Engineer that the Subcontractor's work has been fully performed and that the sum for which payment is requested is due by the Contractor to the Subcontractor. Checks releasing a Subcontractor's retainage shall be made payable to the Contractor, the Contractor's surety, and the Subcontractor, and shall be mailed to the Contractor's surety. This Article does not create any contractual relationship between the Owner and the Subcontractor or any duty of the Owner to any Subcontractor. Payments pursuant to this Article shall in no way diminish, change, alter or affect the rights of the Owner under the Contract Documents.

5. FINAL PAYMENT.-(a)-Final payment including retainage, shall be due 30 days after the date of notice from the Owner of the final acceptance of the Work, provided that all other requirements of the Contract Documents shall have been met in full. Final payment shall be made by a check payable jointly to the Contractor and surety and shall be mailed to the surety.

(b)-Upon receipt of written notice from the Contractor pursuant to Article 30 of the General Conditions that the Work is ready for final inspection, the Engineer shall promptly make such inspection, and when he/she finds the Work complies with the Contract Documents, and when the Contract shall have been fully performed the Engineer shall promptly issue a final certificate of recommendation to the Owner, over the Engineer's signature, stating that the Work required by the Contract Documents has been completed under the terms and conditions thereof, and that the entire balance of the Contract Price found to be due to the Contractor and noted in said final certificate, is due and payable.

(c)-Before issuance of a final certificate of recommendation, the Contractor shall submit evidence satisfactory to the Engineer that all payrolls, material bills, and all other indebtedness in connection with the Work has been paid in full.

(d)-If full completion of the Work is materially delayed through no fault of the Contractor, and the Engineer so certifies same, the Owner shall, upon certificate of the Engineer, and without terminating the Contract, make payment of the balance due for that portion of the Work fully completed. Such payment shall be made under the terms and conditions of the General Conditions governing final payment, except that it shall not constitute a waiver of claims.

6. NO ASSIGNMENT.- This Contract and the proceeds of this Contract may not be assigned nor may the performance thereunder be assigned, except with the prior written consent of the Owner.

7. BONDS. – The Contractor shall furnish both a performance bond and a payment bond and shall pay the premium thereon. The performance bond shall guarantee the full performance of the Contract.

Remainder of Page Left Blank

[Signatures, attestations, and seals on following page]

IN WITNESS WHEREOF, the parties hereto have executed this Contract Agreement under their respective seals on the day and date first above written in six counterparts, each of which shall, without proof or accounting for the other counterparts, be deemed an original Contract.

Signed, sealed, and delivered in the presence of:

THE MACON WATER AUTHORITY

1. _____

By: _____
Gary Bechtel, Chairman

2. _____

Attest: _____
Ron Shipman, Executive Director & President

(Official Seal)

Signed, sealed, and delivered in the presence of:

CONTRACTOR: _____

1. _____

By: (Signed) _____

2. _____

(Printed) _____

Attest: (Signed) _____

(Printed) _____

(Secretary)

(Corporate Seal)

APPROVED AS TO FORM

(Printed Name)
Attorney for the Macon Water Authority

END OF SECTION

PRE-AWARD OATH

STATE OF GEORGIA
COUNTY OF _____

In accordance with O.C.G.A. 36-91-21(e), we, the undersigned of _____

being first duly sworn, depose and say that:

We have not directly or indirectly violated O.C.G.A. 36-91-21(d), and more specifically, we have not

- prevented or attempted to prevent competition in such bidding or proposals by any means whatever,
- prevented or endeavored to prevent anyone from making a bid or proposal thereof by any means whatever, nor
- caused or induced another to withdraw a bid or proposal for the work.

We, the undersigned, to the best of our knowledge, affirm that no other officers, agents or other persons acted for or represented the Contractor in the bidding for and procurement of this Contract.

Signature	Printed Name	Title	Date
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

(Notary Public) My Commission Expires: _____

(SEAL)

END OF SECTION

PERFORMANCE BOND

Bond No. _____

KNOW ALL MEN BY THESE PRESENTS:

That

(Legal title and address of the Contractor)

as Principal (hereinafter referred to as "Contractor"), and _____

(Legal title and address of Surety)

as Surety (hereinafter referred to as "Surety"), do hereby acknowledge ourselves indebted and firmly bound and held unto the Macon Water Authority (the "Owner") in the amount of _____ Dollars (\$ _____ .00) to which payment Contractor and Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, the above bound Principal has entered into a Contract with Owner bearing date of _____ for construction of _____ Project in accordance with Contract Documents prepared by Owner all of which said Contract Documents are incorporated herein by reference and made a part hereof, and are hereinafter collectively referred to as the "Contract."

NOW THEREFORE, THE CONDITION OF THIS OBLIGATION is such that, if the Contractor shall promptly and faithfully perform and comply with the terms and conditions of said Contract; and shall indemnify and save harmless the Owner against and from all costs, expenses, damages, injury or loss to which said Owner may be subjected by reason of any wrongdoing, including patent infringement, misconduct, want of care or skill, default or failure of performance on the part of said Principal, his agents, subcontractors of employees, in the execution or performance of said Contract, and shall fully reimburse and repay the said Owner any and all outlay, costs, and expense which it may incur in making good any such default and shall guarantee all products and workmanship against defects, as provided in the Contract Documents which comprise and constitute the Contract, for a period of one year and shall replace all defective work and products for such period of one year then this obligation shall be null and void; otherwise it shall remain in full force and effect.

1. The said Surety to this bond, for value received, hereby stipulates and agrees that no change or changes, extension of time or extensions of time, alteration or alterations or addition or additions to the terms of the Contract or to the Work to be performed thereunder, or the specifications or drawings accompanying same shall in any wise affect its obligations on this bond, and it does hereby waive notice of any such change or changes, extension of time or extensions of time, alteration or alterations or addition or additions to the terms of the

Contract or to the Work or to the specifications or drawings.

2. It is expressly agreed that this bond shall be amended automatically and immediately, without formal and separate amendments hereto, upon amendment to the Contract not increasing the Contract Price more than 20 percent in excess of the original Contract Price, so as to bind the Principal and Surety to the full and faithful performance of the Contract as so amended. The term "amendment" shall include any alteration, addition, extension, or modification of any character whatsoever.
3. If pursuant to the Contract Documents the Contractor shall be declared in default by the Owner under the aforesaid Contract, the Owner shall take possession of the Project and finish the Work by whatever method the Owner may deem expedient, in accordance with Article 7 of the General Conditions.
4. Supplementary to and in addition to the foregoing, whenever the Owner shall notify the Surety that the Owner has notice that the Contractor has failed to pay any subcontractor, materialman, or laborer for labor or materials certified by the Contractor as having been paid for by the Contractor, the Surety shall, within thirty (30) days of receipt of such notice, cause to be paid any unpaid amount for such labor or materials.
5. It is expressly agreed by the Principal and the Surety that the Owner, if it desires to do so, is at liberty to make inquiries at any time of subcontractors, laborers, materialmen, or other parties concerning the status of payments for labor, materials, or services furnished in the prosecution of the work.
6. The Surety agrees that other than as is provided in this bond it may not demand of the Owner that the Owner shall (a) perform any thing or act, (b) give any notice, (c) furnish any clerical assistance, (d) render any service, (e) furnish any papers or documents, or (f) take any action of any nature or description which is not required of the Owner to be done under the Contract Documents.
7. No right of action shall accrue on this bond to or for the use of any person or corporation other than the Owner named herein or the legal successors of the Owner.

This bond is given pursuant to and in accordance with the provisions of the Georgia Procurement Manual and of Title 36, Chapter 91 of the Official Code of Georgia Annotated, as may be amended or modified from time to time, and all the provisions of the law referring to this character of bond as set forth in said sections or as may be hereafter enacted or amended and these are hereby made a part hereof to the same extent as if set out in full herein.

Remainder of Page Left Blank

[Signatures, attestations, and seals on following Page]

Signed and sealed this _____ day of _____, 20__.

Signed, sealed and delivered
in the presence of:

(Insert Name of Contractor)

1. _____

By: (Signed) _____

(Printed) _____

2. _____

Attest :(Signed) _____

(Printed) _____

(CORPORATE SEAL)

Signed, sealed and delivered
in the presence of:

(Insert Name of Surety)

1. _____

By: (Signed) _____

(Printed) _____

2. _____

Attest :(Signed) _____

(Printed) _____

(CORPORATE SEAL)

APPROVED AS TO FORM:

(Printed Name)

Attorney for the Macon Water Authority

END OF SECTION

PLACE SURETY FOR PERFORMANCE BOND HERE

PAYMENT BOND

Bond No. _____

KNOW ALL MEN BY THESE PRESENTS:

That

(Legal title and address of the Contractor)

as Principal (hereinafter referred to as “Contractor”), and _____

(Legal title and address of Surety)

as Surety (hereinafter referred to as “Surety”), do hereby acknowledge ourselves indebted and firmly bound and held unto the Macon Water Authority (the “Owner”), in the amount of _____ Dollars (\$ _____ .00) to which payment Contractor and Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, the above bounden Principal has entered into a Contract with Owner bearing date of _____ for construction of _____ Project in accordance with the Contract Documents prepared by Owner, all of which said Contract Documents are incorporated herein by reference and made a part hereof, and are hereinafter collectively referred to as the “Contract.”

NOW THEREFORE, THE CONDITION OF THIS OBLIGATION is such that if the Contractor shall promptly make payment to all claimants as hereinafter defined for all labor and material supplied in the prosecution of the work provided for in said Contract Documents, then this obligation shall be void; otherwise it shall remain in full force and effect, subject, however, to the following conditions:

1. The said Surety to this bond, for value received, hereby stipulates and agrees that no change or changes, extension of time or extensions of time, alteration or alterations or addition or additions to the terms of the Contract or to the Work to be performed thereunder, or the specifications or drawings accompanying same shall in any wise affect its obligations on this bond, and it does hereby waive notice of any such change or changes, extension of time or extensions of time, alteration or alterations or addition or additions to the terms of the Contract or to the work or to the specifications or drawings.
2. It is expressly agreed that this bond shall be amended automatically and immediately, without formal and separate amendments hereto, upon amendment to the Contract Documents not increasing the Contract Price more than 20 percent in excess of the original Contract Price, so as to bind the Contractor and Surety to the full and faithful performance of the Contract as so amended. The term “amendment” shall include any alteration, addition, extension, or modification of any character whatsoever.

3. A Claimant is defined as any subcontractor and any person supplying labor, materials, machinery, or equipment in the prosecution of the Work provided for in said Contract.
4. Every person or entity entitled to the protection hereunder and that has not been paid in full for labor or materials furnished in the prosecution of the Work referred to in said bond before the expiration of a period of ninety days after the day on which the last of the labor was done or performed by them, or materials or equipment or machinery was furnished or supplied by them for which such claim is made, or when they have completed its subcontract for which claim is made, shall have the right to sue on such payment bond for the amount, or the balance thereof, unpaid at the time of the commencement of such action and to prosecute such action to final execution and judgment for the sum or sums due them; provided, however, that any person or entity having direct contractual relationship with a subcontractor, but no contractual relationship, express or implied, with the Contractor, shall have the right of action upon this bond upon giving written notice to said Contractor within ninety days from the day on which such person or entity did or performed the last of the labor, or furnished the last of the materials or machinery or equipment for which such claim is made, stating with substantial accuracy the amount claimed and the name of the party to whom the materials were furnished or supplied or for whom the labor was performed or done; provided further that nothing contained herein shall limit the right of action to said 90-day period. Notice may be served by depositing a notice, registered mail, postage prepaid, duly addressed to the Contractor at any place the Contractor maintains an office or conducts business, including any post office or branch post office or any letter box under the control of the United States Postal Service, or notice may be served in any manner in which the sheriffs of Georgia are authorized by law to serve summons or process.
5. Every suit instituted under this section shall be brought in the name of the claimant without the Owner being made a party thereto. The official who has the custody of said bond is authorized and directed to furnish, to any person or entity making application therefor who submits an affidavit that it has supplied labor or material for such work and payment therefor has not been made, or that it is being sued on any such bond, a copy of such bond and the Contract for which it was given, certified by the official who has custody of said bond; this copy shall be primary evidence of this bond and Contract and shall be admitted as evidence without further proof. Applicants shall pay for such certified copies and such certified statements such as fees as the official fixes to cover the cost of preparation thereof, but in no case shall the fee exceed the fees which the clerks of the superior courts are permitted to charge for similar copies.
6. No action can be instituted on this bond after one year from the date of the final acceptance of the Owner.

This bond is given pursuant to and in accordance with the provisions of the Georgia Procurement Manual and of Title 36, Chapter 91 of the Official Code of Georgia Annotated, as may be amended or modified from time to time, and all the provisions of the law referring to this character of bond as set forth in said sections or as may be hereafter enacted or amended and these are hereby made a part hereof to the same extent as if set out in full herein.

[Signatures, attestations, and seals on following Page]

Signed and sealed this _____ day of _____, 20__

Signed, sealed and delivered
in the presence of:

(Insert Name of Contractor)

By: (Signed) _____

(Printed) _____

1. _____

Attest :(Signed) _____

(Printed) _____

2. _____

(CORPORATE SEAL)

Signed, sealed and delivered
in the presence of:

(Insert Name of Surety)

By: (Signed) _____

(Printed) _____

1. _____

Attest :(Signed) _____

(Printed) _____

2. _____

(CORPORATE SEAL)

APPROVED AS TO FORM:

(Printed Name)

Attorney for the Macon Water Authority

END OF SECTION

PLACE SURETY FOR PAYMENT BOND HERE

SECTION 00700

GENERAL CONDITIONS

Article 1. - Notice of Award of Contract.00700-2
Article 2. - Execution of Contract Documents.....00700-2
Article 3. - Contract Security.....00700-2
Article 4. - Insurance.00700-3
Article 5. - Hazards and Indemnification.00700-5
Article 6. - Notice to Proceed.00700-6
Article 7. - Termination of Work for Default.00700-6
Article 8. - Termination for Convenience of Owner.00700-7
Article 9. - Assignments.00700-8
Article 10. - Subcontractors, Materialmen, Suppliers and Employees.00700-8
Article 11. - Engineer.00700-11
Article 12. - Separate Contracts.....00700-12
Article 13. - Laws and Regulations.00700-13
Article 14. - Taxes.00700-14
Article 15. - Notice and Service Thereof.00700-14
Article 16. - Patents and Royalties.00700-15
Article 17. - Land and Rights-of-Way.00700-15
Article 18. - Products.....00700-15
Article 19. - Supervision of Work.00700-16
Article 20. - Interruption of Facility Operations.00700-16
Article 21. - Protection of Work, Property and Persons.00700-17
Article 22. - Protection of the Environment.....00700-18
Article 23. - Protection, Location and Relocation of Utilities.....00700-18
Article 24. - Schedules, Reports and Records.....00700-19
Article 25. - Drawings and Specifications.00700-21
Article 26. - Surveys and Permits.....00700-23
Article 27. - Testing, Inspection and Rejection of Work.....00700-23
Article 28. - Contract Time and Liquidated Damages.....00700-25
Article 29. - Changes in the Work.....00700-27
Article 30. - Payments and Completion.00700-33
Article 31. - Certificates of Payment.....00700-37
Article 32. - Payments Withheld.00700-38
Article 33. - Notice of Commencement.00700-38
Article 34. - Correction of Work after Final Payment.....00700-39
Article 35. - Cash Allowances.....00700-40
Article 36. - Contractor's Warranty as to Performance.....00700-40
Article 37. - Claims.....00700-40
Article 38. - Use of Premises.....00700-42
Article 39. - Specification Arrangement.00700-42
Article 40. - Valuable Material, Geological Specimens00700-42

Article 41. - Definitions.....00700-42

Article 1. - Notice of Award of Contract. Within sixty (60) days after receipt of Bids, the Owner will notify the successful Bidder of the award of the Contract. Should the Owner require additional time to award a Contract, the time may be extended by the mutual agreement between the Owner and the successful Bidder. If an award of Contract has not been made within 60 days from the Bid date or within the extension mutually agreed upon, the Bidder may withdraw the Bid without further liability on the part of either party.

Article 2. - Execution of Contract Documents. (a) *Time Limits.*—Within fifteen (15) days of notification of Award of Contract, the Owner will furnish the Contractor with conformed copies of Contract Documents for execution by the Contractor and the surety. The Contractor and its surety must execute the bond forms contained in the conformed Contract Documents without any changes. Within ten (10) days after receipt, the Contractor shall return all the Contract Documents properly executed by the Contractor and the surety. Attached to each set of Contract Documents shall be original powers-of-attorney for the person executing the Bonds for the surety and certificates, endorsements, and declarations of insurance for the required insurance coverages, all as required by Article 3 and Article 4. Within thirty (30) days after receipt of the conformed Contract Documents properly completed and executed by the Contractor and the surety together with the power-of-attorney, and the proper certificates, endorsements and declarations of insurance, the Owner will complete the execution of the Contract Documents. Distribution of the completed Documents will be made upon execution by the Owner.

(b) *Failure of Contractor or Surety to Execute Documents.*—Should the Contractor or the surety fail to properly execute the Documents within the specified time the Owner will have the right to proceed on the Bid Bond accompanying the Bid.

(c) *Failure of Owner to Execute Documents.*—If the Owner fails to execute the Documents within the time limit specified, the Contractor will have the right to withdraw the Bid without penalty. In such event the Owner will have no liability to the Contractor under these Documents or otherwise.

(d) *Extensions of Time.*—Should either party require an extension of any of the time limits stated above, this shall be done only by mutual agreement between both parties.

(e) *Changes to Documents.*-- Insertion, addition, alteration, modification, revision, or deletion of any text, verbiage, provision, statement, term, condition, or other component of the Contract Documents, whether textual, numerical, or pictorial, is prohibited and no such unilateral change to the Contract Documents shall be binding. In the event the Owner discovers any attempt by the Contractor to modify the Contract Documents by insertion, addition, alteration, revision, or deletion of any text, verbiage, provision, statement, term, condition, or other portion of the Contract Documents without the written assent and approval of the Owner, the Owner shall have grounds to withdraw the contract award, terminate all proceedings related to contractual relationship with the Contractor for the subject Project, and to award the contract to the next bidder which met the requirements of the invitation to bid.

(f) *Incorporation of Prior Agreements.* — All agreements between the parties are incorporated into this Agreement. In the event of any conflict or inconsistency between this Agreement and any provisions, terms or conditions of any other prior agreement, the provisions, terms and conditions of this Agreement shall supersede, control and prevail over the conflicting or inconsistent provisions of the prior agreement.

Article 3. - Contract Security.—The Contractor shall furnish separate Performance and Payment Bonds each in a sum equal to the amount of the Contract Price on the Owner’s forms. Such Bonds shall be executed by the Contractor and a bonding company licensed to transact such business in Georgia and named on the current list of “Companies Holding Certificates of Authority as Acceptable Sureties on Federal Bonds” as published in the Treasury Department Circular Number 570. The expense of these Bonds shall be borne by the Contractor.

If at any time a surety on any such Bond is declared bankrupt, becomes insolvent, loses its right to do business in Georgia or is removed from the list of Surety Companies accepted on Federal Bonds, the Contractor shall, within ten (10) days after notice from the Owner to do so, substitute acceptable Bonds in such form and sum and signed by such other surety as may be satisfactory to the Owner. The premium on such substitute Bonds shall be paid by the Contractor. No further progress payments shall be deemed due, nor shall any be made, until the new surety furnishes acceptable Bonds to the Owner. The person executing the substitute Bonds on behalf of the surety shall submit with the Bonds valid powers-of-attorney certified to by an official of said surety company.

Article 4. - Insurance—Proof of insurance coverage and furnishing of insurance policies acceptable to the Owner shall be as set forth in this Article.

(a) *Policies, Certificates, Limits and Disposition of Documents.*—The Contractor shall obtain at his expense insurance with limits as shown hereinbelow, unless the Contractor desires to broaden the limits and obtain more protection. The Contractor shall provide the Owner with all insurance documentation and evidence of insurance as required herein, and updated certificates of all insurance required herein must be provided to the Owner at least quarterly until Final Payment.

(1) **WORKER'S COMPENSATION AND EMPLOYER’S LIABILITY INSURANCE.**—The Contractor shall procure and maintain Worker's Compensation and Employers Liability Insurance for all of his employees to be engaged in Work on the project under this contract, and in case any such Work is sublet, the Contractor shall require the Subcontractor similarly to provide Worker's Compensation and Employer’s Liability Insurance for all of the latter's employees to be engaged in such work unless such employees are covered by the protection afforded by the Contractor's insurance. Worker's Compensation insurance policies shall include GEORGIA under Section 3A and shall include Other States coverage and Voluntary Compensation.

Worker’s Compensation Limits:	Statutory
Employers Liability Limits:	
Each Accident	\$1,000,000

Disease - Policy Limit	\$1,000,000
Disease - Each Employee	\$1,000,000

Contractor waives all rights against Owner and its agents, officers, directors, and employees for recovery of damages to the extent these damages are covered by the worker's compensation and employer's liability or commercial umbrella liability insurance obtained by Contractor pursuant to Article 4 of this agreement. The Waiver of Our right To Recover From Others Endorsement, ISO Form SC 00 03 13 shall be attached to the policy showing the Owner listed in the Schedule.

Disposition: Certificate(s) of insurance showing the required coverage and copy of declaration page must be returned to the Owner with properly executed Contract Documents. If requested by the Owner, Contractor shall also provide a certified copy of the policy(ies) required by Article 4(a)(1).

(2) COMMERCIAL GENERAL AND UMBRELLA LIABILITY INSURANCE.—The Contractor shall procure and shall maintain commercial general liability (CGL) and if necessary, commercial umbrella insurance with a limit of not less than \$2,000,000 each occurrence, as shall protect him and any Subcontractor performing Work covered by this Contract from claims for damages for bodily injury, including accidental death, as well as from claims for property damages, which may arise from operations under the Contract Agreement, whether such operations are by himself or by any Subcontractor or by anyone directly or indirectly employed by either of them.

CGL insurance shall be written on ISO occurrence form CG 00 01 10 93 (or substitute form providing equivalent coverage) and shall cover liability arising from premises, operations, independent contractors, products-completed operations, personal injury and advertising injury, and liability assumed under an insured contract (including the tort liability of another assumed in a business contract). If such CGL insurance contains a general aggregate limit, it shall apply separately to this project, (Per Project Aggregate Endorsement). Each policy shall be indorsed with ISO Form CG 25 03 11 85 or equivalent form with wording satisfactory to Owner.

The Owner shall be included as an additional insured under the CGL, using ISO additional insured endorsement CG 20 33 or a substitute providing equivalent coverage, and under the commercial umbrella, if any. This insurance shall apply as primary insurance with respect to any other insurance or self-insurance programs afforded to the Owner.

There shall be no endorsement or modification of the CGL limiting the scope of coverage for liability arising from explosion, collapse, or underground property damage.

Contractor waives all rights against the Owner and its agents, officers, directors, and employees for recovery of damages to the extent these damages are covered by commercial general liability or commercial umbrella liability insurance maintained pursuant to Article 4 of this agreement.

Disposition: Certificate(s) of insurance showing the required coverage and copy of declaration page must be returned to the Owner with properly executed Contract Documents. If

requested by the Owner, Contractor shall also provide a certified copy of the policy(ies) required by Article 4(a)(2).

(3) BUSINESS AUTO AND UMBRELLA LIABILITY INSURANCE.—The Contractor shall procure and shall maintain business automobile liability, and if necessary, commercial umbrella liability insurance with a limit of not less than \$2,000,000 each occurrence.

Such insurance shall cover liability arising out of any auto (including owned, hired, and non-owned autos).

Business auto coverage shall be written on ISO form CA 00 01, CA 00 05, CA 00 12, CA 00 20 or a substitute form providing equivalent liability coverage. If necessary, the policy shall be endorsed to provide contractual liability coverage equivalent to that provided in the 1990 and later editions of ISO form CA 00 01. This insurance shall apply as primary insurance with respect to any other insurance or self-insurance programs afforded to the Owner.

Contractor waives all rights against the Owner and its agents, officers, directors, and employees for recovery of damages to the extent these damages are covered by the business auto liability or commercial umbrella liability insurance obtained by Contractor pursuant to Article 4 of this agreement or under any applicable auto coverage.

Disposition: Certificate(s) of insurance showing the required coverage and copy of declaration page must be returned to the Owner with properly executed Contract Documents. If requested by the Owner, Contractor shall also provide a certified copy of the policy(ies) required by Article 4(a)(2).

Cross-Liability Coverage.—If Contractor’s liability policies do not provide the standard ISO separation of insureds provision, or a substantially similar clause, they shall be endorsed to provide cross-liability coverage.

(3) By proper endorsement, the policy must name

MACON WATER AUTHORITY
790 Second Street
P. O. Box 108
Macon, GA 31202

as an additional insured and shall provide for not less than thirty (30) days prior written notice before cancellation or any material change in the policy, except for non-payment of premium which shall require ten (10) days prior written notice of cancellation, to the Owner.

(4) Commercial Umbrella/Excess Policy:

Contractor shall procure a commercial umbrella or excess policy with a limit of no less than \$5,000,000. Coverage must follow form over underlying policies including GL, Auto and Employer’s Liability insurance.

(5) MATERIALS AND EQUIPMENT FLOATER. - The Contractor shall procure, and shall maintain during the performance of the Contract Agreement, Materials and Equipment Floater (May be labeled as *Equipment Floater* or Installation Floater or Builders Risk) Insurance to protect the interests of the Owner, the Contractor and Subcontractors against loss by vandalism, malicious mischief, and all hazards included in a standard All Risk Endorsement. The amount of insurance shall at all times equal or exceed the amount of the materials in the Contract + \$30k for Owner furnished materials. The policies shall be in the names of the Owner and the Contractor.

Disposition: Original policy must be returned to the Owner with properly executed Contract Documents. Owner may accept with returned, executed Contract Documents in lieu of an original policy, an insurance binder evidencing the policy coverage, but Contractor shall not be relieved of the obligation to furnish the actual policy.

Endorsement on Materials and Equipment Floater Policy.—There shall be attached to and made a part of the insurance policy for MATERIALS AND EQUIPMENT FLOATER an endorsement of the insurance company in accordance with the specimen shown in preceding Paragraph (a)(3).

Article 5. - Hazards and Indemnification. (a) *Hazards.* —The Contractor shall be responsible from the time of his execution of the Contract Documents or from the time of the beginning of the first work, whichever shall be earlier, for all injury or damage of any kind resulting from the Work to persons or property regardless of who may be the owner of the property. It is the intention of this paragraph to shift the full and complete risk of all such loss to the Contractor for the period of construction and until notice from the Owner of the final acceptance of the Work is made in accordance with Article 30, regardless of whether or not any particular hazard shall be insured against.

(b) *Indemnification.*—In addition to the liability imposed upon the Contractor on account of bodily injury (including death) or property damage, which liability is not impaired or otherwise affected hereby, the Contractor assumes the obligation to save the Owner harmless and to indemnify and defend the Owner, the Engineer and their agents and employees from and against all claims, damages, losses and expenses including claims consultant's and attorney's fees arising out of or through bodily injury, sickness, disease or death of any person or persons or damage to property (regardless of who may be the owner of the property) including the loss of use resulting therefrom arising out of or suffered through any act or omission of the Contractor or any Subcontractor, or anyone either

- (1) directly or indirectly employed by the Contractor, or
- (2) under the supervision of the Contractor or any subcontractor in the prosecution of the Work required by the Contract Documents.

In any and all claims against the Owner or the Engineer, or any of their agents or employees, by any employee of the Contractor, any Subcontractor, anyone directly or indirectly employed by any of them, or anyone for whose acts any of them may be liable, this indemnification obligation shall not be limited in any way by any limitation on the amount or type of damages, compensation or benefits

payable by or for the Contractor or any Subcontractor under workers' compensation acts, disability benefit acts or other employee benefits acts.

(c) *Sole Negligence Exception.* —The Contractor shall not be liable or responsible for loss or damage, and the indemnity obligation set forth above will not apply if the incident from which the loss or damage arose was the result of the sole negligence or sole cause of the Owner, the Engineer, or their agents, servants and employees.

Article 6. - Notice to Proceed. The Notice to Proceed will be issued, following the pre-construction conference, within thirty (30) days of the execution of the Contract Agreement by the Owner. The time may be extended by mutual agreement between the Owner and the Contractor. If the Notice to Proceed has not been issued within the thirty (30) day period or within the period mutually agreed upon, the Contractor may terminate the Contract Agreement without further liability on the part of either party.

Within ten (10) days of receiving the Notice to Proceed, the Contractor must initiate on-site construction activity. If on-site construction activity is not initiated within this time period, the Owner may begin proceedings for Termination of Work for Default.

Article 7. - Termination of Work for Default. —(a) *Definition.*—The Work may be terminated for default if any one of the following events or circumstances occurs:

- (1) The Contractor is adjudged bankrupt or becomes insolvent;
- (2) The Contractor makes a general assignment for the benefit of creditors;
- (3) A trustee or receiver is appointed for the Contractor or for any of Contractor's property;
- (4) The Contractor files a petition to take advantage of any debtor's act, or to reorganize under the bankruptcy or applicable laws;
- (5) The Contractor fails to supply sufficient skilled workmen, materials or equipment;
- (6) The Contractor fails to make satisfactory progress toward timely completion of the Work;
- (7) The Contractor fails to make prompt payments to Subcontractors or material suppliers for labor, materials or equipment;
- (8) The Contractor disregards laws, ordinances, rules, regulations, or orders of any public body having jurisdiction of the Work;
- (9) The Contractor fails to comply with directives of the Engineer; or,

(10) The Contractor otherwise violates any provision of the Contract Documents.

(b) *Grounds for Issuance of Notice of Declaration of Default.* —It shall be a sufficient ground for the issuance of a notice of declaration of default that the Contractor has been unfaithful or delinquent in the performance of the Contract or any part of it in any respect. The Engineer does not have authority to declare the Contractor in default.

(c) *Termination of Services and Possession of the Project.* —The Owner may, without prejudice to any other right or remedy and after giving the Contractor and surety written notice ten (10) days in advance, terminate the services of the Contractor and take possession of the Project, the Work and of all products thereon owned by the Contractor, and finish the Work by whatever method the Owner may deem expedient. In such case the Contractor shall not be entitled to receive any further payment until the Work is finished. If the unpaid balance of the Contract Price exceeds the direct and indirect costs of completing the Project and all Work, including compensation for additional professional services, such excess shall be paid to the Contractor. If such costs exceed such unpaid balance, the Contractor or surety shall pay the difference to the Owner. Such costs incurred by the Owner will be determined by the Engineer and incorporated in a Change Order.

(d) *Effect of Termination.* —Where the Contractor's services have been so terminated by the Owner, said termination will not affect any right of the Owner against the Contractor then existing or which may thereafter accrue. Any retention or payment of monies by the Owner due the Contractor will not release the Contractor from compliance with the Contract Documents.

Article 8. - Termination for Convenience of Owner. (a) *General.* —If, for any reason other than those provided for under Article 7, the Owner elects to discontinue, in whole or in part, the Work under this Contract, the Owner may, ten (10) days after delivery of a written notice to the Contractor and the Engineer, terminate, in whole or in part, the Contractor's performance of the Work under this Contract. The notice of termination shall specify the extent to which performance of the Work under the Contract is terminated.

(b) *Entitlement to Payment.* —In the event of such termination by the Owner, the Contractor shall be entitled to payment for the Work properly performed up to the time of the termination and reimbursement for such actual costs as are reasonably incurred by the Contractor due to the termination and not otherwise compensated. The Contractor shall also be entitled to profit on the amounts payable to the Contractor, but such profit shall be limited to six (6%) percent of such amounts. The Contractor shall not be entitled to any payment, including any anticipated profit, on Work not performed, and the Contractor shall not be entitled to any compensation or recovery of damages for any other costs, losses, or damages of any nature.

Article 9. - Assignments. The Contractor shall not assign the whole or any part of this Contract or any monies due or to become due hereunder without prior written consent of the Owner.

Should the Owner consent, in writing, to Contractor's assigning of all or any part of any monies due, or to become due, under this Contract, the instrument of assignment shall contain a

clause substantially to the effect that it is agreed that the right of any assignee in and to any monies due or to become due to the Contractor shall be subject to any set-offs then due to the Owner and to prior liens of all persons, firms, and corporations for services rendered or materials supplied for the performance of the Work called for under this Contract.

Article 10. - Subcontractors, Materialmen, Suppliers and Employees. —(a) *Submission of List.* —As soon as possible after notice of award of the Contract and in any event not later than the time fixed in the Contract for delivery of the executed Contract Documents to the Owner, the Contractor shall submit in writing to the Engineer a list of the names of Subcontractors that the Contractor will engage for the Work. The list of Subcontractors is not submitted for approval, but is for the purpose of establishing:

- (1) What trades and portions of the Work are to be performed under subcontract; and,
- (2) The names of the entities selected by the Contractor to perform work by subcontract, the aforesaid selection being a matter lying solely within the discretion of the Contractor.

The Contractor shall utilize the services of specialty Subcontractors on those parts of the Work which, under normal construction practices, are best performed by specialty Subcontractors and as may be required by the Engineer in the Engineer's sole discretion, at no additional cost to the Owner. If the Contractor desires to self-perform specialty Work, the Contractor shall submit a notice to the Owner accompanied by evidence that the Contractor's own organization has successfully performed the type of work, and the performance of the Work by specialty Subcontractors will result in materially increased costs or inordinate delays.

(b) *No Approval of Subcontractors.*—Neither the Owner nor the Engineer undertakes to pass upon or approve any Subcontractor.

(c) *Warranty of Contractor.*—The Contractor warrants that the Subcontractors selected by the Contractor are reputable, skilled, reliable, competent, qualified in the trade or field in which such Subcontractors are to perform Work on the Project, and that all Subcontractors are thoroughly familiar with applicable codes.

(d) *Certification on account of.*—The Engineer shall, upon written request, furnish to any Subcontractor, wherever practicable, evidence of the amounts certified as payable or paid on the Subcontractor's account. Furnishing any such evidence shall not establish any relationship between the Engineer and any Subcontractor.

(e) *Contractor Responsible for Acts and Omissions of Subcontractors, Materialmen, Suppliers and Employees.*—The Contractor agrees that it is as fully responsible for the acts and omissions of its Subcontractors, materialmen, suppliers, and employees (and of entities either directly or indirectly employed by any of them) as the Contractor is for the acts and omissions of entities directly employed or engaged by the Contractor. The failure of a Subcontractor, materialman, supplier, or employee to timely and properly perform any Work shall not be asserted

by the Contractor as an excuse for any omission from, or noncompliance with, the requirements of the Contract Documents; nor shall the Contractor be entitled to an extension of the Contract Time because of any failure of a Subcontractor, materialman, supplier, or employee to timely perform the Work unless such failure was a direct result of some critical delay to the Subcontractor, materialman, supplier or employee of the kind and character described under Article 28 of the General Conditions for which the Contractor shall have requested and received an extension of time under the terms of Article 28 of the General Conditions. The subcontracting of work does not relieve the Contractor of the full responsibility for the execution of the Work and for compliance with all requirements of the Contract Documents. The Contractor may not assert negligence, inefficiency, insolvency, bankruptcy, or incompetence of any Subcontractor, materialman, supplier, or employee as excuse for any noncompliance with methods and material designated in the Contract Documents. As to Subcontractors, materialmen, suppliers and employees of the Contractor, the doctrine that a principal is liable for acts and omissions of his agent shall be binding on the Contractor, and the Contractor may not reverse the aforesaid doctrine by serving as a conduit or agent for its Subcontractors, materialmen, suppliers and employees. Any provision in any Contract between the Contractor and any Subcontractor pursuant to which the Contractor is obliged to present to the Owner any claim of any Subcontractor shall be invalid, null and void.

(f) *No Contract Between Owner and Any Subcontractor, Materialman, Supplier, or Employee.*—Nothing contained in the Contract Documents shall create any contractual relationship between the Owner and any Subcontractor or between the Owner and any materialman, supplier or employee of the Contractor or its Subcontractors.

(g) *Relationship of Contractor and Subcontractors.*—The Contractor agrees to bind every Subcontractor to, and every Subcontractor agrees to be bound by, the terms of the Contract Documents, including the following provisions of this Article:

The Subcontractor agrees

- (1) To be bound to the Contractor by the terms of the Contract Documents and to assume toward the Contractor all the obligations and responsibilities that the Contractor by the Contract Documents assumes toward the Owner.
- (2) To submit to the Contractor applications for payment in such reasonable time as to enable the Contractor to apply for payment under Article 30 of the General Conditions.
- (3) To make claims for extras, for extensions of time or for damages to the Contractor in the manner provided in the General Conditions for like claims by the Contractor upon the Owner.

The Contractor agrees

- (1) To be bound to the Subcontractor by all the obligations that the Owner assumes to the Contractor under the Contract Documents.

- (2) To pay the Subcontractor upon the payment of certificates issued under the schedule of values described in Article 24 of the General Conditions the amount allowed to the Contractor on account of the Subcontractor's work to the extent of the Subcontractor's interest therein; amounts retained by the Contractor from payments due to Subcontractors (expressed as a percentage) shall not exceed that being retained by the Owner.
- (3) To pay the Subcontractor as required by the Contract Documents.
- (4) To pay the Subcontractor on demand for its work or materials as far as executed and fixed in place, less the retained percentage, even though the Engineer fails to approve payment to the Contractor for any cause not the fault of the Subcontractor.
- (5) To pay the Subcontractor a just share of any fire insurance money received by the Contractor.
- (6) To make no demand for liquidated damages or penalty for delay in any sum in excess of such amount as may be specifically identified in the subcontract.
- (7) That no claim for services rendered or materials furnished by the Contractor to the Subcontractor shall be valid unless written notice thereof is given by the Contractor to the Subcontractor during the first ten days of the calendar month following that in which the claim originated.
- (8) To give the Subcontractor an opportunity to be present and to submit evidence in any dispute involving rights of the Subcontractor.

(b) *Owner Not Obligated to any Subcontractor.*—There is no obligation on the part of the Owner to pay, or to see to the payment of, any sums to any (1) Subcontractor, (2) materialman, (3) supplier, (4) laborer, (5) employee, or (6) claimant as defined in the Payment Bond.

(c) *Incorporation of Terms in Subcontracts.*—The Contractor agrees that failure on its part to incorporate in all subcontracts an express provision in accordance with this Article shall be deemed to be and is a breach of an essential covenant, and that, in the event of such breach, that Contractor shall, within five (5) days after demand of the Owner, furnish proof in writing that the deficiency has been remedied and that (1) the Contractor may not maintain that it is beyond the Contractor's right or ability to require performance of terms of the Contract Documents by a Subcontractor and (2) no Subcontractor may maintain that it has not assumed toward the Contractor all the obligations and responsibilities that the Contractor has assumed toward the Owner.

Article 11 - Engineer.—(a) *Supervision.*—The Engineer shall have general supervision and direction of the Work except in respect to safety and except as qualified by Articles 27 and 36 of the General Conditions. He/she shall make visits to the Project site and make determination as to whether the Work is proceeding in accordance with the Contract Documents. Except for projects on which the Macon Water Authority itself serves in the capacity of engineer by use of its employees,

which shall be indicated in the Contract Documents, the Engineer is an independent contractor and acts as the agent of the Owner only when in special instances he/she is authorized in writing by the Owner so to act, and in such instances he/she shall, upon request, show the Contractor written authority. The Engineer has authority to stop the Work whenever such stoppage may be necessary to ensure the proper execution of the Contract.

(b) *Interpreter and Impartial Judge.*—As the Engineer is the interpreter of the conditions of the Contract and the judge of its performance, the Engineer shall side neither with the Owner nor with the Contractor but shall use the Engineer’s powers to enforce the faithful performance of the Contract by both the Owner and the Contractor.

(c) *Succession.*—In case of the termination of the employment of the Engineer, the Owner shall appoint a capable and reputable Engineer against whom the Contractor shall make no objection and whose status under the Contract shall be that of the former Engineer.

(d) *Promptness.*—The Engineer shall make decisions with reasonable promptness after presentation of evidence on (i) any claim of the Owner or Contractor, (ii) a demand of the Owner or Contractor for a decision on any matter relating to the execution, or progress, of the Work, or (iii) a demand of the Contractor or Owner for interpretation of or additional instructions (“Request for Information” or “RFI”) with respect to the Contract Documents.

(e) *Engineer’s Authority.*—The Engineer shall be vested with the authority to judge, determine and direct the following:

- (1) Whether products furnished are of the quality, type and kind called for by the Contract Documents and are otherwise acceptable for the Work as provided in the Contract Documents, and if not, to reject those not so qualifying or otherwise unacceptable;
- (2) Whether products incorporated in the Work comply with the standards and requirements of the Contract Documents as to installation and operation and, if not, to require their removal and replacement, at the expense of the Contractor, with products which do meet the qualifications and operating ability, requirements, performance and standards as provided in said Contract Documents;
- (3) The accuracy of quantities, amount of Work performed and all other submittals by the Contractor submitted in partial or periodic payment estimates, and whether all or any part of such quantities and other submittals are acceptable and comply with the Contract Documents, and to disallow any submittals not approved by the Engineer until the deficiencies causing such disallowance have been eliminated and rectified;
- (4) The validity and merit of any and all claims for additional compensation or extension of the Contract Time;
- (5) All matters relating to artistic effect;

- (6) The validity and reasonableness of any notice of facility interruption given under Article 20 of the General Conditions; and,
- (7) All other matters relating to the proper execution of the Work in conformity with the Contract Documents, including workmanship.

The determination and decision, and any resulting approval, non-approval, condemnation, rejection, requirements of removal or replacement in all the foregoing matters of or by the Engineer shall be final and conclusive and binding upon the Contractor, all Subcontractors and all suppliers of products materials and equipment.

(f) *Claims for alleged procrastination.*—No claim for delay to the Contractor or for additional expense to the Contractor shall commence to accrue on account of failure of the Engineer to render decisions, make interpretations, or furnish additional instructions until ten (10) days after receipt of written claim for additional compensation, damages, or extension of time served upon the Engineer and the Owner and not then unless such claim be reasonable and otherwise permitted under the Contract Documents.

Article 12. - Separate Contracts.—(a) *Cooperation of Contractor.*—The Owner reserves the right to let other contracts in connection with, or related to, this Project. The Contractor shall afford other contractors reasonable opportunity for the introduction and storage of their products and the execution of their work, and the Contractor and other contractors shall properly connect and coordinate their respective work with each other. If the proper execution or results of any part of the Contractor’s Work depends upon the work of any other contractor, the Contractor shall inspect and promptly report to the Engineer any defects in such other contractor’s work that render it unsuitable for such proper execution and results.

(b) *Performance of Work by Owner.*—The Owner may perform additional work related to the Project with Owner’s own forces. The Contractor shall afford the Owner reasonable opportunity for the introduction and storage of products and the execution of such work and shall properly connect and coordinate Contractor’s work with work performed by Owner’s own forces.

(c) *Claims for Extra Expense.*—If the performance of additional work by other contractors or the Owner is not noted in the Contract Documents prior to the execution of the Contract, written notice thereof will be given to the Contractor prior to starting any such additional work. If the Contractor believes that the performance of such additional work by the Owner or others causes the Contractor any additional expense or entitles the Contractor to an extension of the Contract Time, the Contractor may make a claim therefor as provided in Article 29 of the General Conditions.

Article 13. - Laws and Regulations. (a) *General.*—The Contractor acknowledges and agrees that all applicable federal, state, county and city laws, municipal ordinances, and the codes, rules, and regulations of all authorities having jurisdiction over construction of the Project shall apply to the Contract as though written out in full herein. The Contractor shall keep fully informed of all laws, ordinances and regulations of the federal, state, county, city and municipal governments or

authorities in any manner affecting those engaged or employed in the Work or the material used in the Work or in any way affecting the conduct of the Work and of all orders and decrees of bodies or tribunals having any jurisdiction or authority over same. If any discrepancy or inconsistency should be discovered in these Contract Documents herein referred to, in relation to any such law, ordinance, regulation, order or decree, the Contractor shall herewith report the same, in writing, to the Owner and the Engineer.

(b) *Expense for Violation of Laws, Ordinances, etc.*—If the Contractor performs any work knowing or reasonably knowing it to be contrary to such laws, ordinances, rules or regulations without such notice to the Owner, the Contractor shall bear all costs arising therefrom.

(c) *Indemnification.*—The Contractor shall at all times observe and comply with all such existing and future laws, ordinances, and regulations, and shall protect and indemnify the Owner, the Engineer and their agents against the violation of any such law, ordinance regulation, order or decree, whether by the Contractor or by the Contractor’s employees or Subcontractors.

(d) *Drug Free Workplace Act.*—The Contractor certifies that the provisions of O.C.G.A. §§ 50-24-1 through 50-24-6 (as may be amended or re-numbered) relating to the “Drug Free Workplace Act” will be complied with in full. The Contractor further certifies that: (i) A Drug Free Workplace will be provided for employees during the performance of the Contract, and (ii) that if a Subcontractor is engaged by the Contractor to work in a Drug Free Workplace, the Contractor shall secure from the Subcontractor the following written certification:

“As part of the subcontracting agreement with _____
(Contractor’s name) _____, _____ (Subcontractor’s name)
certifies to the Contractor that a drug-free workplace will be provided for the Subcontractor’s employees during the performance of this Contract pursuant to the ‘Drug Free Workplace Act’”. Contractor also certifies to the Owner and the Engineer that the Contractor and its employees will not engage in the unlawful manufacture, sale, distribution, dispensation, possession, or use of any controlled substance or marijuana during the performance of the Contract.

(e) *Alcoholic Beverages on the Jobsite.*—The Contractor will strictly enforce a policy prohibiting the possession and consumption of alcoholic beverages on the jobsite before, during or after working hours for duration of the Work.

Article 14. - Taxes. (a) *General.*—The Contractor shall pay all sales, consumer, use and other similar taxes required by the law of the place where the Work is performed. The Owner will be responsible for any sales or use tax due on products furnished by the Owner to the Contractor to be incorporated into the Work.

(b) *Tabulation.*—The Contractor shall provide a written tabulation, plus other documentation as may be required, of all taxes, including sales tax, paid by the Contractor to assist the Owner in obtaining sales or use tax refunds for eligible machinery and equipment used for the primary purpose of reducing or eliminating air or water pollution as provided for in Chapter 48-8-3 (36) and (37) of the Official Code of Georgia (as may be amended). Such written tabulation shall be

included with each partial payment request. Additionally, the tabulation shall be documented with copies of invoices indicating the amount of tax paid, with all blanks completed on the invoice, and with a description of the function of the item included in the tabulation. All taxes will be paid by the Contractor. All refunds will accrue to the Owner.

Article 15. - Notice and Service Thereof. (a) *General.*—All notices, demands, requests, instructions, approvals, and claims shall be in writing.

(b) *Notice to Contractor.*—Any notice to or demand upon the Contractor will be sufficiently given if delivered at the office of the Contractor specified in the Bid (or at such other office as the Contractor may from time to time designate to the Owner in writing), or if delivered by the United States Mail in a sealed, postage-prepaid envelope, or delivered by facsimile transmission, followed by written confirmation, in each case addressed to such office.

(c) *Notice to Owner.*—All papers required to be delivered to the Owner shall, unless otherwise specified in writing to the Contractor, be delivered to:

Macon Water Authority
790 Second Street
Macon, GA 31201
FAX (478) 750-2007

Any notice to or demand upon the Owner shall be sufficiently given if delivered to the Office of the Executive Director or if delivered by the United States Mail in a sealed, postage-prepaid envelope, or delivered by facsimile addressed to said Executive Director or to such other representative of the Owner or to such other address as the Owner may subsequently specify in writing to the Contractor for such purposes. Any such notice or demand shall be deemed to have been given to the Owner or made only as of the time of actual delivery to Owner.

(d) *Delivery to Engineer or Resident Inspector.*—Notice in writing or orally to the Engineer or to the resident inspector is not notice to the Owner unless a copy of the aforesaid notice in writing shall have been properly served upon the Owner as provided in this Article.

Article 16. - Patents and Royalties. (a) *General.*—If the Contractor uses any patented, trademarked or copyrighted design, process, device, material or other item, , the Contractor shall provide for such use by suitable agreement between the Owner and the holder of such patented, trademarked or copyrighted design, device or material. The Contract Prices shall include royalties or costs arising from the use of such design, device, or materials, in any way involved in the Work.

(b) *Indemnification.*—The Contractor and the Contractor's surety shall indemnify and save harmless the Owner, the Engineer and their agents from claims for infringement by reason of the use of such patented, trademarked or copyrighted design, process, device or materials in connection with Work agreed to be performed under this Contract, and shall indemnify the Owner, the Engineer and their agents for any cost, expense, damage and reasonable attorneys' fees which the

Owner, the Engineer or their agents may be obliged to pay by reason of such infringement, at any time during the prosecution of the Work or after completion of the Work.

Article 17. - Land and Rights-of-Way. (a) *Project Site.*—The Owner will provide, as indicated in the Contract Documents and prior to the Notice to Proceed, the lands upon which the Work is to be performed, rights-of-way for access thereto, and such other lands which are designated for the use of the Contractor. The Contractor shall confine all Work and all associated activities to the easements and other areas designated for the Contractor’s use. The Contractor shall comply with any limits on construction methods and practices which may be required by easement agreements.

(b) *Delays in Providing Access.*—If, due to some unforeseen reason, the necessary easements are not obtained, the Contractor shall receive an equitable extension of Contract Time or an equitable increase in the Contract Price, or both, to cover the Contractor’s additional costs as a result thereof, provided the Owner is notified in writing of the claim. The Contractor’s claim therefor shall be made as provided for in Article 29 of the General Conditions.

(c) *Additional Easements.*—Should additional temporary easements for ingress or egress be required by the Contractor for access to the Work, these easements shall be obtained by the Contractor, at no additional cost to the Owner.

Article 18. - Products. (a) *Storage.*—Products shall be stored in accordance with the manufacturer’s recommendations to insure the preservation of their quality and fitness for the Work. Stored products to be incorporated in the Work shall be located so as to facilitate prompt inspection by the Owner or the Engineer.

(b) *Installation.*—Manufactured products shall be applied, installed, connected, erected, used, cleaned, and conditioned as directed by the manufacturer.

(c) *Conformance with Shop Drawings.*—Products shall be furnished in accordance with shop drawings or samples submitted by the Contractor and approved by the Engineer.

(d) *Quality and Ownership.*—Unless otherwise specified, all products incorporated into the Work shall be new, and both workmanship and materials shall be of good quality. The Contractor shall, if required, furnish satisfactory evidence as to the kind and quality of products. The burden of proof is on the Contractor. Products to be incorporated into the Work shall not be purchased by the Contractor or Subcontractor subject to a chattel mortgage or under a conditional sale contract or other agreement by which an interest is retained by the seller.

Article 19. - Supervision of Work. (a) *Supervision by Contractor.*—The Contractor shall give efficient supervision to the Work, using its best skill and attention. The Contractor shall be solely responsible for the means, methods, techniques, sequences, and procedures of construction.

(b) *Superintendent of Contractor.*—The Contractor shall employ and maintain on the Work a qualified superintendent and any necessary assistants, all satisfactory to the Owner and Engineer, who shall have been designated in writing by the Contractor as the Contractor’s representative at the

site. The superintendent shall not be changed except with the consent of the Owner and Engineer unless the superintendent proves to be unsatisfactory to the Contractor and ceases to be in the Contractor's employ. The superintendent shall represent the Contractor and shall be present on the site at all times as required to perform adequate supervision and coordination of the Work. The superintendent's sole responsibility shall be to superintend the construction of the Project; he shall not be a "working foreman." The superintendent shall have full authority to act on behalf of the Contractor and to execute orders or directions of the Engineer without delay. The superintendent shall have full authority to promptly supply products, tools, plant equipment and labor as may be required. The superintendent's authority shall be such that all communication given to the supervisor shall be as binding as if given to the Contractor.

(c) *Contractor's Personnel.*—The Contractor shall employ only competent and skilled personnel. The Contractor shall at all times enforce strict discipline and good order among its employees and shall not employ on the Work any unfit person or anyone not skilled in the work assigned to him. The Contractor shall, upon demand from the Engineer, immediately remove any superintendent, foreman, or worker whom the Engineer or Owner may consider incompetent or undesirable.

Article 20. - Interruption of Facility Operations. (a) *General.*—The Contractor shall provide the Owner with written notice at least five (5) days prior to any interruption in facility operations required by any construction activity. The notice shall include the date and time of the scheduled interruption; the length of time the interruption will be in effect; the procedures to be followed in effecting the interruption; a complete identification of all those processes, equipment and operations to be affected; and all other information the Owner may require. The Contractor shall provide any and all equipment, piping, auxiliary power or other means necessary to sustain facility operations or function for interruptions which have not been identified by the Contract Documents, or when interruptions must exceed the time allowed by the Contract Documents.

(b) *Damages and Fines.*—Any damages resulting from surcharging, overflow or back-up caused by the Contractor's operations shall be the Contractor's responsibility. Any fines levied against the Owner resulting from a surcharge, overflow or backup caused by the Contractor shall be paid by the Contractor.

Article 21. - Protection of Work, Property and Persons. (a) *Duty to Protect Persons and Property.*—The Contractor shall be responsible for initiating, maintaining and supervising all safety precautions and programs in connection with the Work. The Contractor shall take all necessary precautions for the safety of, and shall provide necessary protection to prevent damage, injury or loss to all employees on the Work and other persons who may be affected thereby, all the Work and all products to be incorporated therein, whether in storage on or off the site, and other property at the site and adjacent thereto, including trees, shrubs, lawns, walks, pavements, roadways, structures and utilities not designated for removal, relocation or replacement in the course of construction. The Contractor shall pay for any such damage, injury, or loss except such as may be directly the result of errors in the Contract Documents or such as shall be caused directly by agents or employees of the Owner.

(b) *Safety Precautions.*—The Contractor shall comply with the Occupational Safety and Health Act, the Contract Work Hours and Safety Standards Act, and all rules and regulations relating thereto. Contractor warrants and represents that it is thoroughly familiar with the safety requirements with regard to scaffolding set forth in O.C.G.A. § 25-15-110, the requirements concerning blasting or excavating near underground gas pipes and utility facilities contained in O.C.G.A. § 25-9-1, *et seq.*, and the High Voltage Safety Act, O.C.G.A. § 46-3-30, *et seq.*, and that the Work shall be prosecuted in complete accord with all limitations and requirements set forth in these, and other applicable, laws. The contractor’s operation of the jobsite shall be consistent with the provisions of the “Manual of Accident Prevention in Construction” issued by the Associated General Contractors of America, Inc., and shall maintain an accurate record of all cases of death, occupational disease, and injury requiring medical attention or causing loss of time from work arising out of and in the course of employment on the Work. The Contractor alone shall be responsible for the safety, efficiency, and adequacy of its plant, appliances, and methods and for any damage which may result from their improper construction, maintenance, or operation. The Contractor shall erect and properly maintain at all times as required by the conditions and progress of the work proper safeguards for the protection of workers and the public and shall post danger warnings against any hazards created by the construction operations. The Contractor shall designate a responsible member of its organization on the Work whose duty shall be the prevention of accidents. In the absence of notice to the contrary filed with the Engineer in writing with a copy to the Owner, this person shall be the superintendent of the Contractor.

(c) *Emergencies.*—In an emergency affecting the safety of life or the Work or adjoining property, the Contractor, without special instruction or authorization from the Engineer or Owner, is hereby permitted to act, at its discretion, to prevent such threatened loss or injury. Any remuneration claimed by the Contractor on account of emergency work shall be determined in accordance with allowances permitted on force account under section (c), Case(c) of Article 29 of the General Conditions.

(d) *Injury or Loss to Persons or Property.*—The Contractor shall remedy all damage, injury or loss to any property, improvements or facilities caused, directly or indirectly, in whole or in part, by the Contractor or any of the Contractor’s Subcontractors or anyone directly or indirectly employed by and of them or anyone for whose acts any of them may be liable. The property, improvements or facilities shall be replaced or restored to a condition as good as when the Contractor entered upon the Work. In case of failure on the part of the Contractor to restore such property, or pay for such damages or injury, the Owner may, after 48 hours written notice, proceed to repair, rebuild, or otherwise restore such property, improvements or facilities as may be deemed necessary. The cost thereof will be deducted from any monies due or which may become due to the Contractor under this Contract.

(e) *Blasting.*—In the absence of an express provision in the Contract Documents permitting blasting, there shall be no blasting. If blasting is permitted under the Contract Documents and under the law which is applicable to the Project site, such blasting shall be done in such manner as to prevent all damage and injury.

(f) *Rain Water, Surface Water, and Backup.*—The Contractor shall protect all Work,

including but not limited to excavations and trenches, from rain water, surface water, and back-up of drains and sewers. The Contractor shall furnish all labor, pumps, shoring, enclosures, and equipment necessary to protect and keep the Work free of water. Completed Work and stored products shall be suitably protected during inclement weather to allow Work to proceed in a timely fashion. Work planned, or in progress, should be performed to minimize impact of adverse weather conditions.

Article 22. - Protection of the Environment. (a) *General.*—The Contractor shall be responsible for taking all measures required to minimize all types of pollution associated with the undertaking of the proposed Work, and shall abide by the requirements of all governmental agencies having jurisdiction over the Work or Contractor's Project operations.

(b) *Restoration.*—Any area used or involved in the Project that is disturbed by the Contractor, shall be restored to original or better condition, even though such area is outside the limits of that specified for grading, grassing or landscaping.

Article 23. - Protection, Location and Relocation of Utilities. (a) *Notification and Protection.*—The Contractor shall notify owners of adjacent utilities when prosecution of the Work may affect them. The Contractor shall protect from damage all existing improvements or utilities at, or in proximity to, the site of the Work, and shall repair or restore any damage to such facilities resulting from the performance of the Work. If the Contractor fails or refuses to repair any such damage promptly, the Owner may have the Work performed and charge the cost thereof to the Contractor.

(b) *Relocation.*—Prior to the construction or installation of any proposed facility or pipeline, the Contractor shall expose all existing utilities true to their vertical and horizontal location, within the vicinity of the Work. In order to avoid conflicts between existing and proposed facilities or utilities, the Contractor shall either relocate the existing or proposed utility on a temporary or permanent basis, or shall take whatever means necessary to protect the existing facilities or utilities during the installation of proposed utilities, as approved by the Engineer. No separate or additional payment will be made for the relocation of existing utilities or for any work associated with the protection of existing facilities or utilities.

Article 24. - Schedules, Reports and Records.—(a) *Progress Reports.*—Within such reasonable time as the Owner shall designate in writing, the Contractor shall submit to the Owner such schedule of quantities and costs, construction progress schedules, payrolls, bills, vouchers, correct copies of all subcontracts, statements, reports, correct copies of all agreements, correspondence, and written transactions with the surety that have any relevance to the Work, estimates, records, and other data as the Owner may request concerning Work performed or to be performed under this Contract. When requested by the Owner, the Contractor shall give the Owner access to accounts relating to the foregoing. The above reports shall include but are not limited to (i) written notice of dates by which specified Work will have been completed, (ii) written notice of dates by which condemned Work shall have been remedied, (iii) written notice that condemned Work has been remedied, (iv) written notice as to the date or dates by which Work that has not been performed with equal steps and at the same rate required by the construction progress schedule shall have been brought into conformity with the schedule, (v) written notice of the date by which any undisputed

claim of a Subcontractor, materialman, or laborer shall have been paid, (vi) written advice regarding the nature and amount of any disputed claim of a Subcontractor, materialman, or laborer, and (vii) information regarding work performed under Sections (c), Case (b) and Case (c) of Article 29 of the General Conditions.

(b) *Construction Progress Schedule.*—Within ten (10) days of the Notice to Proceed, the Contractor shall submit to the Engineer a Preliminary Progress Schedule (“PPS”) and a Near Term Schedule (“NTS”) in the form and with the content required by the Specifications. Within forty-five (45) days of the Notice to Proceed, the Contractor shall submit to the Engineer the Overall Project Schedule (“OPS”) as required in the Specifications.

(c) *Schedule of Values.*—The Contractor shall, within ten (10) days of the Notice to Proceed, submit to the Engineer a Schedule of Values of the various parts of the Work, including quantities, aggregating the total Contract Price, divided in such manner as to facilitate payments to Subcontractors in accordance with Article 10, with a complete breakdown of the Contract Price so arranged and so itemized in accordance with the Specifications as to meet the approval of the Engineer, and, if requested, supported by such evidence as to its correctness as the Engineer may direct. This schedule, designated herein as the Schedule of Values, when approved by the Engineer shall be used as a basis for certificates of payment.

(d) *Shop Drawings.*—The Contractor shall prepare, execute, and submit shop drawings as required by the Specifications. No shop drawings shall be submitted which do not comply with the Contract Documents.

(e) *Schedule of Submittals.*—Within ten (10) days of the Notice to Proceed, the Contractor shall prepare and submit for the approval of the Engineer a Schedule of Submittals showing the estimated date of submittal of all shop drawings and the desired approval date for each shop drawing anticipated. The Contractor shall submit in accordance with the schedule and the Engineer shall furnish approval in accordance with the schedule. The schedule must be consistent with the construction progress schedules.

(f) *Submitting Updated Schedules.*—An updated OPS and NTS together with an updated Schedule of Submittals shall be presented with each periodical payment request. Failure to timely submit such schedules will delay processing of the pay request until receipt of the updated schedules.

(g) *Float in the Schedule.*—If the OPS reflects a completion date prior to the completion date established in the Contract Agreement, or as extended by Change Order, this shall afford no basis for a claim of delay should the Contractor not complete the Work prior to the projected date set forth in the OPS. All “float” between the completion date in the OPS and the completion date established in the Contract Agreement shall belong to and be exclusively available to the Owner. Should a Change Order be executed with a revised completion date, the progress schedule shall be revised to reflect the new completion date.

(h) *Record Drawings.*—The Contractor shall maintain on the Project site throughout the

Contract Time an up-to-date set of records and drawings as required by the Specifications.

(i) *Project Coordination Meetings.*—The Contractor shall participate in Project Coordination Meetings to be held on the site monthly, or more often if conditions warrant, to establish the current state of completion and revise the schedule as necessary. The Project Coordination Meeting will be conducted by the Owner and the Engineer.

(j) *Maintenance of Project Scheduling System.*—The Contractor shall take the following steps to ensure that the Project stays on schedule:

- (1) The Contractor shall implement the detailed NTS of activities to the fullest extent possible between Project Coordination Meetings.
- (2) The Contractor shall provide a copy of the Contractor's Daily Report to the Resident Inspector by 10:00 a.m. of the day following the Report date. This Daily Report will contain, as a minimum, the weather conditions; number of workers by craft, including supervision and management personnel on site; active and inactive equipment on site; Work accomplished by Critical Path Method activity item; problems; and visitors to the jobsite.
- (3) If a current activity or series of activities on the OPS is behind schedule and if the late status is not due to an excusable delay for which an extension of the Contract Time would be forthcoming, the Contractor shall attempt to reschedule the activity to be consistent with the OPS so as not to delay completion of the Contract. The Contractor agrees that:
 - a. The Contractor shall attempt to expedite the activity to completion so as to have it agree with the OPS. Such measures as the Contractor may choose shall be made explicit during the Project Coordination Meeting;
 - b. If, within two weeks of identification of such behind-schedule activity, the Contractor is not successful in restoring the activity to an on-schedule status, the Contractor shall:
 1. Carry out the activity with the scheduled crew on an overtime basis until the activity is complete or back on schedule;
 2. Increase the crew size or add shifts so the activity can be completed as scheduled; or,
 3. Commit to overtime or increased crew sizes for subsequent activities, or some combination of the above as deemed suitable by the Engineer.

These actions shall be taken at no increase in the Contract Price.

- (4) Maintain a current copy of all construction schedules on prominent display in the Contractor's field office at the Project site; and,
- (5) Cooperate with the Owner or Owner's representative in all aspects of the Project

Scheduling System. Failure to implement the Project Scheduling System or to provide specified schedules, diagrams, and reports, or to implement actions to re-establish progress consistent with the OPS may be causes for withholding of payment.

Article 25. - Drawings and Specifications.

(a) *Identification.*— The Contract Documents shall be as defined in Article 41(e) of the General Conditions. They are intended to define, describe, and provide for all Work necessary to complete the Project in an acceptable manner, ready for use, occupancy, or operation by the Owner. Insertion, addition, alteration, modification, revision, or deletion of any text, verbiage, provision, statement, term, condition, or other component of the Contract Documents, whether textual, numerical, or pictorial, is prohibited and no such unilateral change to the Contract Documents shall be binding.

(b) *Number of Copies.*—The Engineer will furnish the Contractor two copies of the Contract Documents, one copy of which the Contractor shall have available at all times on the Project site. Any additional copies will be furnished at additional cost.

(c) *Correlation and Intent.*—The Contract Documents are complementary, and what is called for by one shall be as binding as if called for by all. The intention of the documents is to include all labor and materials, equipment, and transportation necessary for the proper execution of the Work. It is not intended, however, that materials or work not covered by or properly inferable from any heading, branch, class, or trade of the Specifications shall be supplied unless distinctly noted on the drawings. Materials or Work described in words which so applied have a well-known technical or trade meaning shall be held to refer to such recognized standards. In the event the Engineer shall have used such phrases anywhere in the Specifications as: “work indicated on the drawings and herein specified”, “work shown and specified”, “in accordance with the drawings and Specifications”, “indicated on the drawings and Specifications”, “in accordance with Specifications and applicable drawings”, “these Specifications and the accompanying drawings”, “as indicated on the drawings and as specified herein”, or similar expressions, they shall not be deemed to be and are not a defeasance of the provisions under this Article of the General Conditions, and they are not to be construed as requiring Work to be called for both in the Specifications and in the drawings in order to be a requirement under the Contract. Any of the aforesaid conjunctive expressions and phrases or any cross-references between drawings and Specifications, between Specifications and Specifications, or between drawings and drawings to the contrary notwithstanding, the Contract Documents are complementary, and what is called for by one shall be as binding as if called for by all.

(d) *Refinement of Documents.*—The Contractor shall do no Work without complete, definite, and clear Drawings and Specifications. In the event the Contract Documents are not complete, definite, and clear, the Contractor shall make demand upon the Engineer, in writing, for a Request for Instructions (RFI) in accordance with Section (d) (iii) of Article 11 of the General Conditions. A copy of such demand shall be served upon the Owner. With reasonable promptness the Engineer shall furnish complete, definite, and clear instructions in writing, or by means of drawings, or in writing and by means of drawings. Such additional instructions if given orally shall be confirmed in writing or by drawings or both within a reasonable time. All such additional instructions shall be

consistent with the Contract Documents, true developments thereof, and reasonably inferable therefrom. The Work shall be executed in conformity with the aforesaid instructions. The Engineer shall furnish the Owner a copy of all additional instructions issued to the Contractor. No clarification of the Drawings and Specifications hereunder by the Engineer will entitle the Contractor to any additional monies unless a Change Order has been processed as provided by Article 29 of the General Conditions.

(e) *Conflicts.*—The following principles shall govern the settlement of disputes which may arise over conflicts in the Contract Documents:

- (i) as between figures given on drawings and the scaled measurements, the figures shall govern;
- (ii) as between large-scale drawings and small-scale drawings, the larger scale shall govern;
- (iii) As between Drawings and Specifications, the requirements of the Specifications shall govern;
- (iv) as between the form of the Contract Agreement, General Conditions or agency funding documents, the requirements of the agency funding documents shall govern; and,
- (v) in cases where products or quantities are omitted from the Specifications, the description and quantities on the Drawings shall govern.

Conflicts noted shall be reported to the Engineer. The principles set forth herein shall not alter the provisions of subsection (c) herein. Schedules, lists, indexes, tables, inventories, written instructions, written descriptions, summaries, statements, classifications, specifications, written selections, or written designations although appearing on the drawings are deemed to be and are “Specifications” within the meaning of this Article.

(f) *Materially Differing Site Conditions.*—Any materially differing site condition as between what is shown on the Drawings and Specifications and actually found on site shall be immediately reported to the Engineer and Owner, in writing, prior to the continuance of Work at the site. Failure of the Contractor to notify the Engineer, in writing, of the differing site condition prior to performance of Work at the site shall constitute a waiver of any claim for additional monies. Any Change Order necessitated by the differing site condition shall be processed as provided under Article 29 of the General Conditions. Any Work done by the Contractor following a discovery of such differing site condition or ambiguity or need for clarification in the Contract Drawings and Specifications, prior to a written report to the Engineer, shall not entitle the Contractor to additional monies and shall be done at the Contractor's risk.

Article 26. - Surveys and Permits.—(a) *Surveys.*—The Owner will furnish a land survey to establish a base line for locating the principal component parts of the Work, as shown in the Contract Documents. A bench mark will be otherwise specified in the Contract Documents; the Contractor shall develop and make all detailed surveys needed for construction, such as alignment, slope stakes, batter boards, stakes for pile location and other working points, lines, elevations and

cut sheets.

(b) *Permits.*—Permits and licenses of a temporary nature necessary for the prosecution of the Work shall be obtained and paid for by the Contractor. Permits, licenses and easements for permanent structures or permanent changes in existing facilities shall be obtained and paid for by the Owner unless otherwise specified.

Article 27. - Testing, Inspection and Rejection of Work.—(a) *Testing of Materials.*—Unless otherwise specifically provided for in the Specifications, the inspection and testing of materials and products to be incorporated in the Work at the site shall be made by bureaus, laboratories, or agencies approved by the Owner; the cost of such inspection and testing shall be paid by the Contractor. The Contractor shall furnish evidence, satisfactory to the Owner and Engineer, that the materials and products have passed the required tests prior to their incorporation into the Work. The Contractor shall promptly segregate and remove rejected materials and products from the site of the Work.

(b) *Access to Work.*—The Owner and Engineer and their representatives shall at all times have access to the Work wherever it is in preparation or progress, and the Contractor shall provide proper facilities for such access and for inspection.

(c) *Notice to Engineer from Contractor Prior to Covering Work.*—If the Specifications, the Engineer's instructions (either in the Specifications or issued later in writing), laws, ordinances or any public authority require any Work to be specially tested or approved, the Contractor shall give the Engineer timely notice in writing of its readiness for inspection, and if the inspection is by any authority other than the Engineer, of the date fixed for such inspection. Inspections by the Engineer shall be made promptly and where practicable at the source of supply. If any Work should be covered without approval or consent of the Engineer, it must, if required by the Engineer, be uncovered for examination at the Contractor's expense.

(d) *Re-examination or Re-testing of Work Covered pursuant to Consent of Engineer.*—Re-examination or re-testing of questioned work covered pursuant to consent of the Engineer may be ordered by the Engineer, and if so ordered the Work must be uncovered by the Contractor. If such Work is found in accordance with the Contract Documents the Owner shall pay the cost of re-examination and replacement or of re-testing. If such Work is found not in accordance with the Contract Documents the Contractor shall pay such cost unless he shall show that the defect in the Work was caused by another contractor of the Owner, and in that event the Owner shall pay such cost. Re-examination or re-testing under the terms of this section applies only to Work which has been covered with consent of the Engineer. Work covered without consent of the Engineer must be uncovered for examination as provided under Article 27(c) of the General Conditions.

(e) *Inspection Does Not Relieve Contractor.*—Under the Contract Documents, the Contractor has assumed the responsibility of furnishing all services, labor, and materials for the entire Work in accordance with such documents. No provisions of this Article or any inspection of the Work by the Owner, representatives of the Owner, resident inspector, clerk-of-the-works, architects employed by the Engineer, representatives of the Engineer, or the Engineer shall in any way

diminish, relieve, or alter said responsibility and undertaking of the Contractor; nor shall the omission of any of the foregoing to discover or to bring to the attention of the Contractor the existence of any Work or materials injured or done not in accordance with said Contract Documents in any way diminish, relieve, or alter such obligation of the Contractor nor shall the aforesaid omission diminish or alter the rights or remedies of the Owner as set forth in the Contract Documents. Subject to the provisions of Section (g) herein, the resident inspector has no power to make decisions, to accept or reject Work, or to consent to the covering of Work. The resident inspector owes no duty to the Contractor.

(f) *False Start.*—In the event notice of readiness pursuant to Article 30(g) of the General Conditions shall have been issued prematurely by the Contractor, the Contractor’s action shall be deemed to be a “false start”, and the Contractor shall be liable for the damage resulting from the aforesaid false start, including but not limited to the salary, professional fees, and travel and living expenses of the person or parties inconvenienced by the aforesaid false start.

(g) *Authority and Duties of the Resident Inspector.*—The Resident Inspector will be authorized to inspect all Work done and all products furnished, including preparation, fabrication and manufacture of the products to be used, but the Resident Inspector is not authorized to alter or waive any requirements of the Contract Documents. The Resident Inspector may temporarily reject products or suspend the Work until any question at issue can be referred to and decided by the Engineer. The responsibility of the Contractor is not lessened by the presence of the Resident Inspector.

(h) *Rejection of Work; Orders of Condemnation.*—The Contractor shall remove from the premises within the time designated in orders of condemnation all Work condemned by the Engineer as failing to conform to the Contract Documents, whether incorporated in the Work or not, and the Contractor shall promptly replace and re-execute the Work in accordance with the Contract Documents and without expense to the Owner and shall bear the expense of making good all work of other contractors destroyed by such removal or replacement. The Contractor shall supply any omitted Work and perform all unexecuted Work within the time fixed by the Engineer in orders of condemnation.

(i) *Remedy of the Owner for Breach of Order of Condemnation.*—If the Contractor does not make good a deficiency within the time fixed in an Order of Condemnation, the Owner may:

- (1) Remove the condemned Work and store it at the expense of the Contractor. If the Contractor does not pay the expenses of such removal and storing within ten (10) days after receipt of written demand of the Owner, the Owner may upon three (3) days’ notice in writing to the Contractor sell such materials at private sale or at auction and shall account for the net proceeds thereof after deducting all proper costs incurred by the Owner; or
- (2) Supply omitted Work, perform unexecuted Work, or replace and re-execute Work not done in accordance with the methods and materials designated in the Contract Documents and deduct the cost thereof from any payment then or thereafter due

the Contractor; or,

- (3) Accept the condemned Work and deduct the reasonable value of such Work from the Contract Price.

The remedies stated in this Article are in addition to the remedies otherwise available to the Owner, do not exclude such other remedies, and are without prejudice to any other remedies. Time limits stated in orders of condemnation are of the essence of the Contract. Unless otherwise agreed to by the Owner in writing, the making good of condemned Work shall physically commence at the site in not more than seven (7) days after receipt of the Order of Condemnation except that in case of emergency correction shall physically commence immediately and except that the Contractor shall in any event physically commence the correction at the site early enough to complete within the time allowed in the Order of Condemnation. The Owner shall give prompt consideration to reasonable requests for delay in commencement of the making good of orders of condemnation. The making good of condemned Work shall be completed within the time allowed in the Order of Condemnation unless the Contractor shall have requested from the Engineer an increase in the amount of time allowed and the Engineer shall have given notice to the Contractor in writing, with copy to the Owner, stating the additional time, if any, allowed. An extension of the time allowed to correct condemned Work shall not extend the Contract Time.

(j) *Notice of Correction from Contractor.*—The Contractor shall give prompt notice in writing to the Engineer, with copy to the Owner, upon completion of the correction of any Work, the supplying of any omission of any Work or materials or the performance of any unexecuted Work condemned by the Engineer. In the absence of such notice, it shall be and is presumed under this Contract that there has been no correction, supplying remedy, or performance of unexecuted Work.

Article 28. - Contract Time and Liquidated Damages. (a) *Rate of Progress.*—The Contractor shall proceed with the Work at a rate of progress which will insure substantial completion of the Project within the Contract Time. It is expressly understood and agreed by and between the Contractor and the Owner that the Contract Time for the Work is a reasonable time, taking into consideration the average climatic and economic conditions, and other factors prevailing in the locality of the Work. It is understood that the Contractor's proposed construction schedule is based on a normal 40-hour work week, less recognized holidays. If the Contractor desires to work in excess of a normal 40-hour work week, the Contractor shall submit a written request to the Owner and Engineer a minimum of two (2) days prior to the desired work date. The Contractor shall be responsible for any additional expenses incurred by the Owner as a result of any extended work hours, including resident inspection overtime. The cost associated with resident inspector overtime will be deducted from the Contractor's monthly progress payment request.

(b) *Grounds for Delays and Extensions of Time.*—If the Contractor be delayed at any time in the progress of the Work by any act or neglect of the Owner or the Engineer, or of any employee of either, or by any separate contractor of the Owner, or by changes ordered in the Work, or by strikes, lockouts, pickets, abnormal and unforeseeable weather, unforeseeable subsurface conditions, fire, unusual delay in transportation, unavoidable casualties, or any causes beyond the Contractor's control, or by any cause which the Engineer shall decide to justify the delay, then the Contract Time

may be extended for such reasonable time as the Engineer may decide.

(c) *Filing of Claims.*—No extension of the Contract Time shall be made for delay occurring more than ten (10) days before claim therefor is made in writing to the Engineer with a copy to the Owner. In the case of a continuing cause of delay, only one claim is necessary, but no claim for a continuing delay shall be valid unless the Contractor, within ten (10) days of the commencement of the delay, shall have given notice in writing to the Engineer, with copy to the Owner.

(d) *Weather Delays.*—The Contractor is held to be familiar with weather conditions in the Macon-Bibb County area. When a claim for extension of the Contract Time is based on abnormal and unforeseeable weather conditions the request must be accompanied by U.S. Weather Bureau data for the past ten (10) years for the Macon/Macon-Bibb County, Georgia area that substantiates the claim of abnormal and unforeseeable weather conditions. Each day of inclement weather is not, by itself, reason for an extension of the Contract Time. Extensions of the Contract Time will be based solely on the number of rain days in a monthly period that are in excess of the ten (10) year average as established for the Macon/Macon-Bibb County area. A rain day, for purposes of calculating the ten (10) year average, is defined as a day in which 0.10 inch of rain or more was measured by the Weather Bureau.

(e) *Delay in Furnishing Drawings.*—If no Schedule of Submittals or agreement stating the dates upon which drawings or approval of shop drawings shall be furnished is made, then no claim for delay shall be allowed on account of failure of the Engineer to furnish drawings or approval of shop drawings until fourteen (14) days after demand therefor and not then unless such claim be reasonable.

(f) *No Damages for Delay.*—In the event of any delay as set forth in Section (b) herein, the Contractor may be entitled to an extension of the Contract Time only, and shall not be entitled to any additional payment on account of such delay. Without limiting the foregoing, except as otherwise specifically provided under Article 29, the Contractor shall not be entitled to payment or compensation of any kind from the Owner for direct, indirect or impact damages, including but not limited to costs of acceleration or extended home office overhead arising because of hindrance or delay from any cause whatsoever, whether such hindrances or delays be reasonable or unreasonable, foreseeable or unforeseeable, or avoidable or unavoidable.

(g) *Liquidated Damages.*—If the Contractor shall fail to perform the Work required within the Contract Time, or extended Contract Time if authorized by Change Order, then the Contractor shall pay Owner the full amount of liquidated damages specified in the Contract Documents for each calendar day that the Contractor shall be in default after the time stipulated in the Contract Documents shall have expired, and the Owner shall deduct such liquidated damages from the Contractor's monthly progress payment request.

Article 29. - Changes in the Work.—(a) *Owner's Right to Make Changes.*—The Owner without invalidating the Contract may authorize or order extra work or may authorize or order changes by altering, adding to, or deducting from the Work, the Contract Price or the Contract Time, or both, being adjusted accordingly. The Contractor hereby expressly agrees that the Contractor shall have

no right to a claim for damages or extended overhead of any nature because of changes made by the Owner. Such Work is hereinafter designated “change” or “changes”.

(b) *Field Orders.*—The Engineer may at any time, by issuing a field order, make changes in the details of the Work. These changes by field order will not affect Contract Time or Contract Price. The Contractor shall proceed with the performance of any such changes in the Work so ordered by the Engineer, unless the Contractor believes that such field order entitles Contractor to a change in Contract Price or Contract Time, or both, in which event Contractor shall give the Engineer immediate, written notice thereof and if required by the Owner, an immediate estimate of the direct cost of Work as outlined in Case (b) below, after the receipt of the ordered change, and the Contractor shall not execute such changes pending the receipt of an executed Change Order or further written instruction from the Owner.

(c) *Cost to Owner for Changes.*—The cost to the Owner of any change shall be determined in one or more of the following ways:

CASE (a) By estimate and acceptance in a lump sum.

CASE (b) By unit prices identified in the Contract or subsequently agreed upon. Unit prices are net including overhead and profit. Neither establishment of unit prices in the Contract or later agreement to unit prices shall entitle the Contractor to execute any change under Case (b) prior to issuance of an authorization or order of the Owner in writing.

CASE (c) By force account, which is defined as expenditures allowed under Article 29(i) plus a percentage or percentages as stated under Article 29(i).

(d) *Changes Forbidden without Consent of Owner.*—Neither the Engineer or the Contractor shall make any change whatsoever in the Work without authorization or order of the Owner in writing except in emergency as described hereinbelow. The making of any change without authorization or order of the Owner in writing is a breach of contract except in emergency as referred to under Article 21 of the General Conditions. In the absence of authorization or order of the Owner given in advance in writing (except in emergency as referred to under Article 21 of the General Conditions) the Contractor shall have no claim for payment, repayment, reimbursement, remittance, remuneration, compensation, profit, cost, overhead, expense, loss, expenditure, allowance, charge, demand, hire, wages, salary, tax, cash, assessment, price, money, bill, statement, dues, recovery, restitution, benefit, recoupment, exaction, injury, damages or time based upon or resulting from any change.

(e) *Notice of demand of Contractor for extraordinary remuneration or for damages.*—For a change in the Work, the Contractor shall be entitled to no claim other than or in excess of allowances permitted under Article 29(i) unless prior to commencement of execution of the change (a) the Contractor shall have notified the Owner in writing of the nature of the claim and (b) the Owner shall have agreed in writing to the claim. Commencement of execution of a change authorized by the Owner in the absence of the aforesaid written notice from the Contractor and

written agreement to the claim by the Owner shall be deemed to be and is conclusive proof that the Contractor acknowledges that it makes no claim other than or in excess of allowances permitted under Article 29(i).

(f) *Subsurface Conditions.*—Material below the surface of the ground is assumed to be earth and other material that can be removed by a backhoe or similar equipment. Should conditions encountered below the surface of the ground be at variance to conditions indicated by Drawings, Specifications, or geotechnical reports, and subject to Article 23 of the General Conditions, the Contract Price may be adjusted as provided in this Article for changes in the Work upon claim by either party made in writing within a reasonable time after the first observance of the conditions; PROVIDED, however, that the Contractor shall in any event give written notice to the Owner before proceeding to execute any change resulting from subsurface conditions; and PROVIDED FURTHER; that the Owner shall not be liable to the Contractor for any claim occasioned by the aforesaid subsurface conditions except in accordance with and pursuant to authorization of the Owner issued in writing prior to commencement of execution of the aforesaid change to which authorization the Contractor shall have taken no exception. If exception to the authorization be taken by the Contractor, the Owner may issue an order pursuant to Article 29(i). Commencement of execution of work pursuant to Article 29(i) shall not exclude the recovery of damages by the Contractor under other Articles of the General Conditions, but the cost to the Owner for the changes executed pursuant to the aforesaid order shall not exceed the “net allowable expenditures” permitted to the Contractor under Article 29(i) plus the “allowance for overhead and profit” permitted under Article 29(i).

(g) *Rock.*—If rock, as hereinafter defined, is encountered, no claim for additional compensation for changes shall lie against the Owner in the absence of previous authorization by the Owner in writing, and the cost to the Owner for any changes shall be determined as provided in this Article. **CAUTION: No rock for which extra compensation is expected to be received shall be removed except pursuant to and in conformity with a written authorization or order of the Owner.** Shale, rotten stone, or stratified rock that can be loosened with a pick or removed by a backhoe or similar equipment shall not be classified as rock. Rock is defined as follows: any material which cannot be excavated with conventional equipment, and must be removed by drilling, chemical cracking, or blasting, and occupies an original volume of at least one-half cubic yard.

(h) *Existing Conditions.*—The Contractor in undertaking the Work under this Contract is assumed to have visited the premises and to have taken into consideration all conditions which might affect the Work. No consideration will be given any claim based on lack of knowledge of existing conditions except where existing conditions are such as cannot be readily ascertained. Any claims relating to conditions which were not readily ascertainable shall be adjusted as provided in this Article for changes in the Work.

(i) *Cost to Owner, Allowances for Contractor, and Allowable Expenditures.*—In Cases (a) and (c), above, the “allowance for overhead and profit” combined, included in the total cost to the Owner, shall be based upon the following schedule:

- (1) For the Contractor an allowance for Work which it performs with its own forces,

not to exceed 16% of its “net additional allowable expenditures”, if any, for changes.

- (2) For a Subcontractor an allowance for Work which it performs with its own forces, not to exceed 16% of its “net additional allowable expenditures”, if any, for changes. A Subcontractor shall receive no allowance for overhead and profit on Work not performed by its own forces. Under these Contract Documents, the forces of a Sub-subcontractor of a Subcontractor are deemed to be and are the forces of the Subcontractor.
- (3) For the Contractor an allowance for Work performed by its Subcontractor, not to exceed 10% of the amount, if any, due the Subcontractor for changes.

The above percentages shall be applied to the “net additional allowable expenditures”, if any, as limited and defined herein. If the net difference between “allowable expenditures” and savings results in a decrease in expenditures, the amount of credit allowed the Owner shall be the net decrease without any credit for profit and overhead. “Net additional allowable expenditures” as used herein shall mean the difference between all “allowable expenditures” and savings. The term “allowable expenditures” is limited to and defined as items of:

- (1) Labor which is defined as the specific labor wages including a thirty percent (30%) markup on the cost of direct payroll wages. The Contractor shall furnish, if required by the Owner, certified payrolls to verify wages.
- (2) Material delivered and used on the designated Work, including sales tax, if paid for by the Contractor and as verified by original invoices or otherwise verifiable to the Engineer's acceptance.
- (3) Rental, or Ownership cost of equipment, including necessary transportation of equipment, having a purchase value in excess of \$300.00. Rental or Ownership cost will be allowed for only those hours during which the equipment is required on the Project site. Cost allowances will not exceed the rates defined as follows: the hourly rate, for equipment not used exclusively in the change to the scope of Work, will be the monthly rate, as printed in the current Rental Blue Book for Construction Equipment published by Dataquest, divided by 176; the rate, for equipment used exclusively for those tasks identified in the change to the scope of Work, will be the daily, weekly or monthly rate, used singularly or in combination, which will provide the lowest total cost. The rates will be modified by the Rate Adjustment Table factors to reflect a depreciation allowance indexed to the year a machine was originally manufactured and sold. The rates will be adjusted to account for regional differences in annual use hours, cost of labor, freight, taxes, etc. The amount by which basic rates will be increased or decreased is shown on the adjustment maps included in the “Blue Book”. The equipment use period will begin only at the time equipment is unloaded at the site of the changed Work; will include each day that the equipment is required at the site of the changed Work; and will terminate at the end of the day on which the use of such

equipment becomes unnecessary, plus reasonable transportation time. The maximum time to be paid per day will not exceed eight hours unless the equipment is in operation for a longer time. The time which will be paid for per day for equipment not used exclusively in the change to the scope of Work, will be the hours which the equipment was actually in operation on the changed Work.

- (4) In cases where there is an extension of the Contract Time, *pro rata* expenditures for time of foremen employed in the direct superintendence of productive labor in execution of changes.

All expenditures not included in the term “allowable expenditures” as limited and defined in this Article shall be considered as overhead, including, but not limited to, bond premiums, supervision, travel (meals, transportation, and lodging), superintendence [except *pro rata* time of foremen as referred to herein], timekeepers, clerks, watchmen, hand tools, small tools, incidental job burdens, engineering, drafting, and office expense. Any other provisions in the Contract Documents to the contrary notwithstanding, only demonstrable, direct, out-of-pocket expenditures for the changes plus percentages as set forth hereinabove shall be allowable for changes. No wages of a foreman shall be allowable for a change carried on concurrently with contract Work unless the claim includes a demand for extension of time caused by the authorizing or ordering of the change.

(j) *Execution of Changes Pursuant to Order.*—In the event neither Case (a) nor Case (b) can be mutually agreed upon as the method of determining the cost to the Owner for a change, the Contractor, provided it receives a written order from the Owner, shall proceed on force account under Case (c), and he shall keep and present in such form as the Engineer may direct a correct account of the expenditures together with vouchers. Allowable expenditures shall in no event exceed current costs for like services and materials, the burden of proof being on the Contractor.

(k) *Stipulated Maximum Sum.*—Under Case (b) and Case (c), the Owner shall prescribe the limits of any authorization or order for a change by means of an authorization or order in writing stipulating the maximum sum of money committed toward execution of the said change, and the Contractor shall have no authority to perform any change which will cost the Owner in excess of the stipulated maximum sum. It shall be solely the Contractor’s responsibility **to apply in writing to the Owner, NOT [repeat NOT] to the Engineer,** for an enlargement of the scope of the authorization or order by an increase in the said stipulated maximum sum if during the course of the performance of a change on force account under Case (c) the additional cost of the change to the Owner as established in accordance with allowable expenditures and allowances for profit and overhead permitted under Article 29(i) is approaching, or may exceed, the said stipulated maximum sum. It shall likewise be the responsibility of the Contractor to apply for an enlargement of the scope of the authorization or order if the total value of units at any agreed unit price under Case (b) is approaching the said stipulated maximum sum. For changes in the Work no claim for payment, repayment, reimbursement, remittance, remuneration, compensation, profit, cost, overhead, expense, loss, expenditure, allowance, charge, demand, hire, wages, salary, tax, cash, assessment, price, money, bill, statement, dues, recovery, restitution, benefit, recoupment, exaction, injury or damages shall lie against the Owner for any amount in excess of such amount as shall have been mutually agreed to under Case (a) or in excess of such amount as shall have been established as the

stipulated maximum sum under Case (b) or Case (c). The cost to the Owner for any change in the Work, except a change based upon agreed unit prices under Case (b), shall be established in accordance with the schedule of allowances and percentages stipulated under Article 29(i).

(l) *Breakdown of Expenditures.*—To accompany all Change Orders, the Contractor shall furnish a breakdown of expenditures for labor and materials by units and quantities in the form prescribed by the Owner, and the breakdown shall be accompanied by the following declaration: “I do solemnly swear, under criminal penalty, that the costs shown hereinabove do not exceed current costs for like services or materials and do not exceed the actual costs to the Contractor therefor, and that the quantities shown do not exceed actual requirements.” For all force account changes, the Contractor shall promptly, and in no event later than thirty (30) days after receipt of written demand therefor, pursuant to Article 29(i) submit to the Engineer a complete, accurate, and final breakdown and account together with vouchers, showing all expenditures and percentages allowable under Case (c). For all unit price changes, the Contractor shall promptly, and in no event later than thirty (30) days after receipt of written demand therefor, pursuant to Article 29(i) submit to the Engineer an accurate account of the quantity of Work performed under Case (b). In any case, the Engineer shall certify to the amount [including under Case (a) and Case (c) the allowance prescribed in the Contract for overhead and profit] due the Contractor. The Contractor shall obtain and furnish as back-up to the Contractor’s breakdown a separate breakdown for each Subcontractor’s charges prepared by each Subcontractor on the letterhead of the Subcontractor and properly signed by the Subcontractor.

(m) *Payment on Account.*—If the Contractor desires to obtain payment on account before any change in the Work has been completed, a Change Order certified by the Engineer and signed by the Contractor and the Owner must have been executed for so much of the change as has been completed at the time of the filing of the request for payment on account.

(n) *Form and Execution of Change Orders.*—Change Orders shall be recommended by the Engineer and signed by the Contractor and the Owner in accordance with the form of change order prescribed by the Owner. No request for payment of the Contractor for account of a change shall be due, nor shall any such request appear on a progress payment request or demand for final payment until (1) the Change Order shall have been certified by the Engineer and (2) a Change Order shall have been executed by the Contractor and the Owner.

(o) *Claims Distinguished from Changes.*— Claims for damages arising out of alleged negligence of the Engineer or Owner as provided for under Article 37 of the General Conditions are distinguished from claims for allowances for changes as provided for under Article 29. Claims for damages must be filed entirely separately pursuant to Article 37 of the General Conditions and claims for allowances for changes must be filed entirely separately pursuant to Article 29 unless the Contractor and Owner agree in writing otherwise.

(p) *Conditions Different from Those Indicated in Contract Documents.*—The parties contemplate delays necessary to complete tests, to redesign, and to perform change order Work in the event conditions encountered at the site are different from those indicated in the Contract Documents, or to perform change order Work to correct errors and omissions in the Drawings and

Specifications. Execution of any change must be authorized. In such event there shall be an adjustment in the Contract Price as provided in the Contract for changes in the Work, but no claim for damages shall lie against the Owner for the aforesaid delays. Such delays are not a breach of contract because the parties contemplate such delays as a natural and probable consequence of construction operations. The parties agree that such delays constitute no wrong or injury, create no right to a claim for damages, and are not a ground for claiming extraordinary remuneration.

(q) *Unit Prices.*— The term “net” as used in reference to “unit prices” means in respect to Change Orders performed in accordance with Case (b) of Article 29 of the General Conditions that the unit prices offered by the Contractor and accepted by the Owner shall be inclusive of all sums for payment, repayment, reimbursement, remittance, remuneration, compensation, profit, cost, overhead, expense, loss, expenditure, allowance, charge, demand, hire, wages, salary, tax, cash, assessment, price, money, bill, statement, dues, recovery, restitution, benefit, recoupment, exaction, or injury. Upon request of the Owner in writing and within such reasonable space of time as the Owner shall designate in writing, the Contractor shall submit for consideration of the Owner proposals in writing for unit prices to be applied in the event Work is authorized by the Owner to be performed under Case (b) of Article 29. Under penalty of false swearing, a principal of the contracting firm shall certify that the unit prices submitted do not exceed current costs for like services or materials.

(r) *Combining Small Change Orders.*—The Owner may, with the Contractor’s concurrence, elect to postpone the issuance of a Change Order until such time that a single Change Order of substantial importance can be issued incorporating several changes. In such cases, the Owner will indicate this intent for each change in the Contract in a written notice to the Contractor, following agreement by the Owner and Contractor on the scope, price and time, if any, of the change.

(s) *Changes in the Contract Time.*—The Contract Time may be changed only by a Change Order. Changes in the Work described in section (a) of this Article and any other claim made by the Contractor for a change in the Contract Time will be evaluated by the Engineer and if the conditions warrant, an appropriate adjustment of the Contract Time will be made. The Engineer, when making these evaluations will take into consideration the amount and scope of Work which has been changed and will evaluate if the change in Work has affected the Critical Path as currently accepted on the Progress Schedule such that it would delay the completion of the Project. If after these evaluations have been made, and in the sole opinion of the Engineer the Contractor is due an extension of the Contract Time, then it will be granted by a Change Order. Extensions of the Contract Time granted as a result of weather will not result in a change in Contract Price.

(t) *Effect of Executed Change Order.*—The execution of a Change Order by the Contractor shall constitute conclusive evidence of the Contractor’s agreement to the ordered changes in the Work, the Contract as thus amended, the Contract Price and the Contract Time. The Contractor, by executing the Change Order, waives and forever releases any claim against the Owner for additional time or compensation for matters relating to or arising out of or resulting from the Work included within or affected by the executed Change Order. The foregoing waiver and release expressly includes, without limitation, claims for additional compensation or time based on the theory that the Contractor has suffered so-called “impact” damage attributable to the effect of change order Work

on other change orders Work or on unchanged Work.

Article 30. - Payments and Completion.—(a) *Contract Price.*— The Contract Price is either a lump sum or the sum of the unit prices stated in the Contract Agreement, for each item multiplied by the actual quantities installed of each item, and is the total amount payable by the Owner to the Contractor for the performance of the Work set forth in the Contract Documents. It is understood that the Contractor shall provide and pay for all products, labor, (including labor performed after regular working hours, on Sundays, or on legal holidays), equipment, tools, water, light, power, sewer, transportation, supervision, temporary construction of any nature, and all other services and facilities of any nature whatsoever necessary to execute, complete, place into operation, and deliver the Work.

(b) *Application for Payment and Receipts.*—The Contractor shall submit to the Engineer in accordance with a form to be supplied by the Owner an application for each monthly progress payment, and, if requested by the Owner or Engineer, receipts or other vouchers, showing his payments for materials and labor, including payments to Subcontractors as required by Article 10 of the General Conditions.

(c) *Progress Payments.*—If progress payments are made on valuation of Work done, such complete application shall be submitted to the Engineer at least twenty (20) days before payment falls due. In applying for payments, the Contractor shall submit a statement based upon the Schedule of Values on a progress payment form to be supplied by the Owner, and, if requested by the Engineer or Owner, itemized in such form and supported by such evidence as the Engineer or Owner may direct showing the Contractor's right to the payment claimed.

(d) *Materials stored.*—Application for payment may include, at the Contractor's option, the cost of products not yet incorporated into the Work which have been delivered to the site or to other storage locations authorized and approved by the Engineer. The Owner reserves the right to accept or reject pay requests for stored materials, and to limit payments to those stored materials which, in the Engineer's judgment, are necessary for continuing satisfactory Project progress.

Payment for stored products will be subject to the following conditions being met or satisfied:

- (1) The products shall be received in a condition satisfactory for incorporation in the Work, including manufacturer's storage and installation instructions;
- (2) The products shall be stored in accordance with the manufacturer's recommendations and in such manner that any and all manufacturer's warranties will be maintained and that they will not be damaged due to weather, construction operation, or any other cause;
- (3) An invoice from the manufacturer shall be furnished for each item on which payment is requested. The request may include reimbursement for cost of delivery, limited to common carrier rates, to the site, but will not include the Contractor handling, on or off site, or for storage expense;

- (4) The Contractor shall, on request of the Engineer, furnish written proof from the supplier of payment (less retention equal in percentage to that being retained by the Owner) for the products no later than 30 days after receipt of payment for same from the Owner. The Owner will have the right to deduct from the next payment estimate an amount equal to the payment for products if reasonable and adequate proof is not submitted; and,
- (5) Shop drawings, product data and samples, showing “No Exceptions Taken”, have been received from the Contractor for that specific equipment or material.

(e) *Operating Test Period.*—Upon receipt of written notice from the Contractor that the Work is ready to be placed into service for the operating test period, the Engineer will, within a reasonable time, inspect the Work. Prior to initiating the operating test, Work required by the Contract Documents must be in place and operable as determined by the Engineer, which includes, but is not limited to the following:

- (1) Pressure testing all lines as required in the Specifications;
- (2) Making adjustments of manhole rims;
- (3) Performing functional tests and providing manufacturers’ required certification as specified;
- (4) Removing temporary plugs, bulkheads, bypasses, etc., and diverting flow into the facility when directed by the Engineer; and,
- (5) All painting, grassing and restoration of the Work area, provided the Work area is not part of another segment not yet in the 30-day operating test period.

When the Engineer finds the Work of the Contractor ready for initiation of the operating test period, the Engineer will recommend to the Owner that the operating test period begin.

Certain segments of the Work, whether new or existing to be modified, may need to be placed in service prior to completion of the entire Project. Prior to placing these segments in operation, the requirements above, which pertain to the operating test period, must be complete for each segment.

The operating test period begins upon written notification from the Owner and runs for a period of 30 days. During this period, the Contractor shall complete all remaining items of Work, make adjustments found to be necessary, and ensure that all equipment and systems are functioning properly, and continue to function properly. The beginning of the operating test period initiates the Owner’s responsibility for providing chemicals, power, and operating personnel. The Contractor retains responsibility for maintaining equipment until acceptance by the Owner. The segments to be placed into service prior to completion of the entire Project will be determined solely by the Engineer or the Owner.

(f) *Conditions Precedent to Application for Final Payment.*—ALL WORK REQUIRED BY THE CONTRACT DOCUMENTS MUST BE COMPLETED BEFORE THE FINAL INSPECTION IS PERFORMED. This includes, but is not limited to, the following:

- (1) Performing infiltration and pressure tests as described in the detailed Specifications;
- (2) Removing temporary plugs, bulkheads, bypasses, etc.;
- (3) Flushing all lines with potable water furnished by Contractor;
- (4) Pressure testing all lines as required in the Specifications;
- (5) Demonstrating the operation of all valves;
- (6) Providing specified instruction for the Owner's personnel;
- (7) Disinfecting all water mains as required in the Specifications; and,
- (8) Grassing and restoration of the Work area.

(g) *Notification of Readiness for Final Inspection.*—When all conditions precedent for the application have been completed, the Contractor shall submit completed Record Drawings to the Engineer and give notice to the Engineer in accordance with Article 5 of the Contract Agreement with a copy to the Owner in the following words:

The work on the Contract for the **Plum Street Lane Stormwater Pipe Rehabilitation** having been fully completed except as stipulated herein below, it is requested that a final inspection be made promptly by the Engineer in accordance with Article 5 of the Contract Agreement. The following Work is incomplete through no fault of the Contractor:

No final inspection shall be made until such time as the Engineer has received a letter in the exact form indicated above and a copy thereof has been received by the Owner. In the event the Contractor shall have issued the "Notice of Readiness for Final Inspection" prematurely [hereinafter referred to as "false start"] he shall be liable for the damage resulting from the aforesaid false start including but not limited to the salaries, professional fees, and travel and living expenses of the persons or parties inconvenienced by the aforesaid false start. The Contractor acknowledges and agrees that he has an indivisible, non-delegable, and non-transferable contractual obligation to the Owner to make its own inspections of the Work at all stages of construction; and the Contractor shall supervise and superintend performance of the Contract in such manner as to enable it to confirm and corroborate at all times that all Work has been executed strictly, literally, rigidly, and inflexibly in accordance with the methods and materials designated in the Contract Documents so that (a) its certifications on periodical estimates shall be true and correct and (b) its notice of readiness for final inspection shall be true and correct. Accordingly, the Contractor agrees that it

may not defend or excuse any deviation from the Contract Documents on the ground (a) that the deviation was not brought to its attention by another person or party or other persons or parties or (b) that a Subcontractor is, or Subcontractors are, at fault.

(h) *Final Acceptance*.—If the Engineer finds the Work of the Contractor complete and acceptable in accordance with the provisions of the Contract Documents and that the Record Drawings accurately depict the complete Work, the Engineer will recommend to the Owner that the Project be accepted and that final payment be made. In the event that the final inspection reveals deficiencies in meeting the Contract requirements, the Contractor shall complete all remaining items of Work, and make adjustments found to be necessary. Upon receipt of written notice from the Contractor that the Work is complete and ready for re-inspection, the Engineer will make another final inspection. The Contractor will be notified, in writing, by the Owner of the final acceptance of the Work. The date of final acceptance shall be the beginning of the warranty period.

(i) *Liens*.—Neither the final payment or any part of the retained percentage shall become due until the Contractor has furnished the Owner proper and satisfactory evidence (under oath if required) that all claims for labor employed and materials used in the construction of the Work under this Contract have been paid, satisfied or waived, and that no claims can be filed against the Owner for such labor or materials. If required, the Contractor shall deliver to the Owner a complete release of all liens or claims arising out of this Contract, and an affidavit that so far as it has knowledge or information the releases include all labor and materials for which a lien or claim could be filed; provided, however, that the Contractor may, if any Subcontractor or claimant refuses to furnish a release, furnish a bond satisfactory to the Owner to indemnify the Owner against any lien or claim. If any lien or claim remains unsatisfied after all payments are made, the Contractor shall refund to the Owner all moneys that the Owner may be compelled to pay in discharging such lien or claim, including all costs and a reasonable attorneys' fees.

(j) *Compliance with O.C.G.A. §§ 13-10-80 and 13-10-81*.—For purposes of O.C.G.A. § 13-10-80(b) the term “substantial completion of the Work” shall mean that “the Work has been satisfactorily completed and is accepted in accordance with the Contract Documents.” If upon completion of the second “final” inspection provided for in subsection (g) of this Article there are still remaining (i) any disputed indebtedness or (ii) if there are liens upon the property, or (iii) there are any items of Work uncompleted which in the opinion of the Engineer are “incomplete items” within the meaning of O.C.G.A. §§ 13-10-80(b)(2)(B) and/or 13-10-81(c), an amount equal to two hundred percent (200%) of each such item of indebtedness, lien or uncompleted Work as determined by the Engineer shall be withheld until such item or items are paid, settled or completed and the remaining retainage shall be paid to the Contractor.

Article 31. - Certificates of Payment.—(a) *Issuance*.—If the Contractor has made application for payment as provided under Article 30, the Engineer shall not later than the date when each payment falls due issue to the Owner a certificate for such amounts as he decides to be properly due or state in writing his reasons for withholding a certificate.

(b) *Warranty of Title*.—The Contractor warrants that title to all Work and products covered by a Certificate of Payment, whether incorporated into the Project or not, will pass to the Owner

upon the receipt of such payment by the Contractor, free and clear of all liens, claims, security interests or encumbrances except retention equal in percentage to that being retained by the Owner.

(c) *Effect.*—No Certificate issued, or payment made to the Contractor, or partial or entire use of occupancy of the Project by the Owner shall be an acceptance of any Work or materials not in accordance with the Contract Documents. The making of the final payment shall constitute a waiver of all claims by the Owner other than those arising from unsettled liens, from faulty work appearing after final payment, or from the requirements of the Contract Documents, including but not limited to the provisions of Article 5, Hazards and Indemnification, of these General Conditions. Acceptance of the final payment shall operate as and shall be a release by the Contractor to the Owner from all claims of any kind or character arising out of or related to the Contract except for such specific amount or amounts as may have been withheld to cover the fair value of any incomplete Work which has been certified by the Engineer under the provision of Paragraph (d) of Article 5 of the Contract Agreement as incomplete through no fault on the part of the Contractor.

(d) *Date and Rate of Payment.*—Progress payments will be made by the Owner to the Contractor in accordance with Article 4 of the Contract Agreement. Final payment will be made in accordance with Article 5 of the Contract Agreement. The date and rate of payment are subject to Article 32 of the General Conditions. Sums retained pursuant to this Article are and remain the property of the Owner until such time as the Contractor shall have become entitled to receive payment of such retainage by complying with the full terms of the Contract Documents.

(e) *Delays in Making Payments.*—The date on which any progress payment is due shall be extended for such period of time as may be necessary in the determination of the Engineer for the Contractor to remedy any incorrect or incomplete application for payment.

(f) *Interest.*—Should the Owner fail to pay the sum named in any certificate of the Engineer when due, the Contractor shall receive, in addition to the sum approved in the certificate, simple interest thereon at the legal rate; PROVIDED, however, that the Contractor shall have given the Owner written notice of the date on which payment was properly due, and no interest shall be payable if the Owner makes payment when due or within three days after receipt of the aforesaid notice from the contractor. Such notice shall be in writing, and shall set forth:

- (1)— A short and concise statement that interest is due pursuant to this Article;
- (2)— The principal amount of the progress or final payment which is allegedly due to the Contractor; and,
- (3)— The first day and date upon which the Contractor alleges that interest will begin to accrue, pursuant to this Article.

(g) *Integration with the Prompt Pay Act.*—The provisions of the Contract Documents with respect to time limits for payments, grounds for withholding payment, conditions authorizing payments, and interest on late payments shall supersede all provisions of the Georgia Prompt Pay Act, as originally enacted or as amended, and any dispute arising between the parties hereto as to whether or not the provisions of this Contract or the Georgia Prompt Pay Act control will be resolved in favor of the terms of these Contract Documents.

Article 32. - Payments Withheld.—The Engineer may withhold or, on account of subsequently discovered evidence, nullify the whole or a part of any certificate to such extent as may be necessary to protect the Owner from loss on account of:

- (a)—Defective work not remedied;
- (b)—Claims filed or reasonable evidence indicating probable filing of claims;
- (c)—Failure of the Contractor to make payments properly to Subcontractors or for materials or labor;
- (d)—A reasonable doubt that the Project can be completed for the unpaid balance of the Contract Price.
- (e)—Damage to another Contractor or to some third party;
- (f)—Failure to maintain a rate of progress in accordance with the currently approved construction progress schedule;
- (g)—Failure to supply enough skilled workers or proper materials; or,
- (h)—Failure to complete all Work within the Contract Time.

When the above grounds are removed, the Engineer shall issue to the Owner a certificate for such withheld amounts as he determines to be properly due, and the Owner shall pay such amounts within ten (10) days. At the option of the Owner adherence to the construction progress schedule shall be a condition precedent to the right of the Contractor to demand payment of a progress payment. No omission on the part of the Owner to exercise the aforesaid option shall be construed to be a waiver of breach of the construction progress schedule or acquiescence therein, and the Owner may exercise its option from time to time as often as may, in its judgment, be expedient.

Article 33. - Notice of Commencement.—See Notice to Proceed, as used throughout these General Conditions.

Article 34. - Correction of Work after Final Payment.—Neither (1) the final certificate, (2) or any decision of the Engineer, (3) nor payment, (4) nor any provision in the Contract shall relieve the Contractor of responsibility for faulty materials, faulty workmanship, or omission of Work required by the Contract Documents, and the Contractor shall remedy any defects or supply any omissions resulting therefrom and pay for any damage to other Work resulting therefrom. The Owner shall give notice of observed defects or omissions with reasonable promptness. The Contractor shall within the time designated in orders of condemnation and without expense to the Owner, correct, remedy, replace, re-execute, supply omitted Work, or remove from the premises all Work condemned by the Engineer. The Contractor shall give prompt notice in writing to the Engineer, with copy to the Owner, upon completion of the supplying of any omitted Work or the correction of

any Work condemned by the Engineer. In the absence of said notice, it shall be and is presumed under this Contract that there has been no correction of the condemned Work or supplying of omitted Work. If the Contractor does not remove, make good the deficiency, correct, or remedy faulty Work, or supply any omitted Work within the time designated in orders of condemnation without expense to the Owner, the Owner, after ten (10) days' notice in writing to the Contractor, may remove the Work, correct the Work, remedy the Work or supply omitted Work at the expense of the Contractor. In case of emergency involving health, safety of property, or safety of life the Owner may proceed at once. Correction of defective Work executed under the Contract Documents or supplying of omitted Work, whether or not covered by warranty of a Subcontractor or materialmen, remains the primary, direct responsibility of the Contractor. The foregoing obligation of the Contractor shall remain in effect until the same shall have been extinguished by operation of the statute of limitations.

As additional security for the fulfillment of such obligation, but in no way limiting the same, the Contractor warrants and guarantees (1) that all work executed under the Contract Documents shall be free from defects of materials or workmanship for a period of one year from the notice of final acceptance of the Work by the Owner, and (2) that for not less than one year from such final acceptance, or for such greater time as may have been designated in the Contract Documents, products of manufacturers shall be free from defects of materials and workmanship. Whenever written guaranties or warranties are called for, the Contractor shall furnish the aforesaid for such period of time as may be required. The aforesaid instruments shall be in such form as to permit direct enforcement by the Owner against any Subcontractor, materialmen, or manufacturer whose guaranty or warranty is called for, and the Contractor agrees that:

- (a) The Contractor is jointly and severally liable with such Subcontractors, materialmen, or manufacturers;
- (b) The said Subcontractors, materialmen, or manufacturers are agents of the Contractor for purposes of performance under this Article, and the Contractor, as principal, ratifies the warranties or guaranties of his aforesaid agents by the filing of the aforesaid instruments with the Owner. The Contractor as principal is liable for the acts or omissions of his agents;
- (c) Service of notice on the Contractor that there has been breach of any warranty or guaranty will be sufficient to invoke the terms of the instrument; provided, however, that the Owner shall have furnished the Contractor with a copy of notice served on the Subcontractor, materialmen, or manufacturer; and,
- (d) The Contractor will bind his Subcontractor, materialmen, and manufacturers to the terms of this Article.

The calling for or the furnishing of written warranties shall in no way limit the contractual obligation of the Contractor as set forth hereinabove. The remedies stated in this Article are in addition to the remedies otherwise available to the Owner, do not exclude such other remedies, and are without prejudice to any other remedies.

Article 35. - Cash Allowances.—The Contractor shall include in the Contract Price all cash allowances named in the Contract Documents and shall cause the Work thus covered to be done by such contractors or firms and for such sums as the Engineer may direct, the Contract Price being adjusted in conformity therewith. The Contractor declares that the Contract Price includes such sums for overhead and profit on account of cash allowances as he deems proper. No demand for overhead and profit other than those included in the Contract Price shall be allowed. The Contractor shall not be required to employ for any such Work persons against whom he has a reasonable objection.

Article 36. – Contractor’s Warranty as to Performance.—The Contractor warrants that it is familiar with the codes applicable to the Work and that it has the skill, knowledge, competence, organization, and plan to execute the Work promptly and efficiently in compliance with the requirements of the Contract Documents. The Contractor having the obligation to keep a competent superintendent engaged on the Work during its progress, to employ only skilled mechanics, and to enforce strict discipline and good order among its employees, the Contractor, itself, is responsible for seeing that the Work is installed in accordance with the Contract Documents. Failure or omission on the part of the Owner, representatives of the Owner, agents of the Owner, resident engineer inspector, clerk-of-the-works, engineers employed by the Engineer, representatives of the Engineer, or the Engineer either to discover or to bring to the attention of the Contractor any deviation from, omission from, or noncompliance with the Contract Documents shall not be asserted by the Contractor as a defense for failure on the Contractor’s part to install the Work in accordance with the Contract Documents or for any other neglect to fulfill requirements of the Contract; nor shall the presence of any one, or all, or any of the foregoing at the site or the fact that any one, or all, or any of the foregoing may have examined the Work or any part of it be asserted as a defense by the Contractor against a claim for failure on its part to install the Work in accordance with the Contract Documents or for any neglect to fulfill requirements of the Contract. No requirement of this Contract may be altered or waived except in pursuance of a written order of the Owner and in strict accordance with the provisions in the Contract for changes in the Work.

Article 37. - Claims.—(a) *Extra Cost.*—If the Contractor maintains that any instructions by drawings or otherwise involve extra cost to the Owner under this Contract, the Contractor shall give the Owner and the Engineer written notice thereof within a reasonable time after the receipt of such instructions, and in any event before proceeding to execute any change except in emergency endangering life or property. The allowances to the Contractor shall then be as provided under Article 29 of the General Conditions. No claim for extra cost shall be valid unless so made.

(b) *Protest.*—All references to arbitration are deleted from the Contract Documents. Decisions of the Engineer shall be rendered in all cases as provided for under the General Conditions of the Contract, but no decision of the Engineer shall deprive the Owner or the Contractor of any form of redress which may be available under the laws of the State of Georgia to contracting parties. Any decision of the Engineer shall be final and binding on the Contractor in the absence of written notice of protest from the Contractor received by the Owner by registered mail within twelve (12) days of the date of the decision of the Engineer. The Owner shall have twelve (12) days from the date of receipt of a protest within which to investigate and make a reply. There

is no provision under the Contract for execution of work “under protest”. A protest must contain (1) the date of the decision of the Engineer to which exception is taken, (2) a statement of the issue or issues, (3) a citation of the provision or provisions of the Contract Documents which govern the issue or issues, (4) a summary of the logical principle or principles on which the protest is based, and (5) a summary of the legal grounds for taking exception. Filing a written notice of protest shall not be grounds for an extension of the Contract Time.

(c) *Shall be Based on the Legal Assertions of the Contractor.*—The Contractor shall assert claims solely on the basis of (a) principles of logic and (b) principles of law to which the Contractor, itself, has prescribed. The Contractor shall not protest a decision or request a conference on the ground merely that a Subcontractor, materialmen, or supplier has protested to the Contractor. Accordingly, the Contractor shall neither file a claim or make a request for a conference with the Owner regarding a claim except as it shall be for the purpose of asserting in the exercise of the Contractor’s best judgment such views, requests, and legal propositions as he deems the Contractor is entitled to maintain independently of any right of any Subcontractor, materialmen, or supplier against the Contractor.

(d) *Conference with the Owner.*—

(1) *Effect of.*—The Owner has no legal obligation to confer orally with the Contractor about the terms of the Contract or its performance and may insist that all transactions and all intercourse shall be in writing. Agreement of the Owner to confer with a Contractor shall not be construed as an offer of the Owner to reconsider or alter the Owner’s policies, practices, procedures, or prior position, and no such agreement shall constitute a waiver of any right or defense of the Owner. Such a conference is without prejudice to any rights or defense of the Owner. After the conference there will be nothing to confirm since the Owner does not engage itself to do or not to do a thing by agreeing to confer with the Contractor. It is expressly agreed that no conference between the Contractor and the Owner shall cure any failure of the Contractor to give any notice nor shall it cure any breach of any time limit or revive any right in the Contract.

(2) *Conditions precedent to.*—A proposal from the Contractor for a conference in respect to (a) a dispute, (b) a controversy, or (c) an interpretation or construction of any provision of the Contract Documents shall contain (a) a statement of the issue or issues, (b) a citation of the provisions of the Contract Documents which govern the issue or issues, (c) a precise summary of the logical principle or principles on which the issue or issues are based, and (d) a summary of the legal grounds which the Contractor takes with respect to the issue or issues.

(3) *Basis for and Terms of.*—All conferences between the Owner and the Contractor shall be pursuant to, under the terms of, and in accordance with this Article of the General Conditions.

Article 38. - Use of Premises.—The Contractor shall confine its equipment, apparatus, the staging

and storage of materials, the operations of its forces, and the Work to limits indicated by law, ordinances, permits, or the Contract Documents and shall not unreasonably encumber the premises with materials. The Contractor shall not load or permit any part of the Work to be loaded with weight that will endanger its safety. The Contractor shall enforce the Engineer's instructions regarding signs, advertisements, fires, and smoking.

Article 39. - Specification Arrangement.—The Specifications are separated into numbered and titled divisions for convenience of reference. Neither the Owner nor the Engineer assumes any responsibility for defining the limits of any subcontracts on account of the arrangement of the Specifications. Notwithstanding the appearance of such language in the various divisions of the Specifications as, “The Mechanical Contractor”, “The Electrical Contractor”, “The Roofing Contractor”, etc., the Contractor is responsible to the Owner for the entire Contract and the execution of all of the Work referred to in the Contract Documents.

Article 40. - Valuable Material, Geological Specimens.—If during the execution of the Work the Contractor, any Subcontractor, or any servant, employee, or agent of either should uncover any valuable material or materials such as, but not limited to, treasure, geological specimen or specimens, archival material or materials, or ore, the Contractor acknowledges that title to the foregoing is vested in the Owner. The Contractor shall notify the Owner upon discovery of any of the foregoing, shall guard it, and shall deliver it promptly to the Owner. The Contractor agrees that the Geologic and Water Resources Division of the Georgia Department of Natural Resources may inspect the Work at reasonable times consistent with the convenience of the Contractor.

Article 41. - Definitions.—(a) *Applicable Law.*—This Contract shall be governed by the law of Georgia.

(b) *Article Not Plenary.*—This Article is not entire, plenary, or exhaustive of all terms used in the General Conditions which require definition. There are definitions of other terms under Articles to which the terms are related.

(c) *Balanced Bid.*—Balanced Bid shall mean a Bid in which each of the unit prices and total amount bid for each of the listed items reasonably reflects the value of that item with regard to the entire Project considering the prevailing cost of labor, material and equipment in the relevant market. A Bid is unbalanced when, in the opinion of the Owner, any unit prices or total amounts Bid on any of the listed items do not reasonably reflect such actual values.

(d) *Change Order Form.*—The Change Order Form is the instrument by which adjustments in the Contract Price and Contract Time are effected pursuant to changes made in accordance with Case (a), Case (b) or Case (c) of Article 29 of the General Conditions or in accordance with Subparagraph (i) of Article 29 of the General Conditions. The Change Order Form shall be accompanied by a breakdown in the form prescribed in a specimen, which the Owner will supply to the Contractor. The Engineer shall certify to the amount of the adjustment. The Change Order Form shall be signed by the Contractor and the Owner. The breakdown is only for the purpose of enabling the Engineer and the Owner to make a judgment on the dollar amount of the adjustment in the Contract Price. No condition, term, qualification, limitation, exception, exemption,

modification, or proviso shall appear in the breakdown. The breakdown shall be in the exact form and language of the above-mentioned specimen. In the event any condition, term, qualification, limitation, exception, exemption, modification, or proviso shall appear in a breakdown, it shall be invalid.

(e) *Contract; Contract Documents.*—The terms Contract and Contract Documents include the Invitation to Bid, Instructions to Bidders, Contractor’s Bid (including all documentation accompanying the Bid and any post-Bid documentation required by the Owner prior to the Notice of Award), the Contract Agreement, Bonds, all Special Conditions, General Conditions, Supplementary Conditions, Specifications (Divisions 01 through 46, inclusive), Drawings, and Addenda, together with written amendments, Change Orders, field orders and the Engineer’s written interpretations and clarifications issued in accordance with the General Conditions on or after the date of the Contract Agreement. Shop drawing submittals reviewed in accordance with the General Conditions, geotechnical investigations and soils reports, and drawings of physical conditions in or relating to existing surface or subsurface structures at or contiguous to the site are not Contract Documents.

(f) *Contract Time.*—Contract Time shall mean the number of consecutive calendar days as provided in the Contract Agreement for substantial completion of the Project, to be computed from and including the date of the Notice to Proceed. All time limits stated in the Contract Documents or shown on the construction progress schedule are of the essence of the Contract.

(g) *Contractor.*—The Contractor shall mean the party identified in the Contract Agreement and its authorized and legal representatives.

(h) *Cross-reference and Citations of Articles and Paragraphs of the General Conditions.*—Cross-references and citations of Articles and paragraphs of the General Conditions are for the convenience of the Contractor, Engineer and the Owner, and are not intended to be plenary or exhaustive nor are they to be considered in interpreting the Contract Documents or any part of the Contract Documents.

(i) *Engineer.*—The Engineer shall mean River 2 Tap, Inc.

(j) *Furnished by Owner.*—Furnished by Owner shall mean that the Owner shall pre-purchase specific products and have them delivered to a place mutually agreed upon by the supplier, the Owner and the Contractor, at no cost to the Contractor. In connection with an item furnished by the Owner, “Install” shall mean to take delivery of the item, off-load and transport to the job site, store as necessary and install according to the Drawings and Specifications.

(k) *Install, Deliver, Furnish, Supply, Provide.*—Such words mean the work in question shall be put in place by the Contractor ready for occupancy and use, unless expressly provided to the contrary.

(l) *Liquidated Damages.*—Liquidated Damages shall mean the sum stated in the Contract Agreement which the Contractor agrees to pay for each consecutive calendar day beyond the

Contract Time required to achieve substantial completion of the Project. Liquidated Damages will end upon written notification from the Owner that the Project is ready for initiation of the Operating Test Period for the total Project.

(m) *Meaning of words and phrases.*—Unless the context or the Contract Documents taken as a whole indicate to the contrary, words used in the Contract Documents that have usual and common meanings shall be given their usual and common meanings and words having technical or trade meanings shall be given their customary meaning in the subject business, trade or profession.

(n) *Notices.*—Unless otherwise provided in the Contract Documents, written notice shall be deemed to have been duly served if delivered in person to the individual or to a member of the firm or to an officer of the corporation for whom it is intended, or if delivered or sent by certified mail to the last business address known to the party that gives notice.

(o) *Notice to Proceed.*—The Notice to Proceed is a written notice from the Owner pursuant to which the Contractor shall commence physical work on the Project site. A Notice to Proceed is a condition precedent to the execution of any Work on the site by the Contractor.

(p) *Order of Condemnation.*—An Order of Condemnation shall be in writing, shall be dated, shall be signed by the Engineer, shall be addressed to the Contractor with a copy to the Owner, and shall contain three elements as follows:

FIRST ELEMENT: Description of Work

- (1) which has been omitted or
- (2) which is unexecuted as of the date of the Order of Condemnation, the time for its incorporation into the Work under the construction progress schedule having expired, or
- (3) which has not been executed in accordance with the methods and materials designated in the Contract Documents.

SECOND ELEMENT: Citation of the provision or provisions of the Contract Documents which has or have been violated.

THIRD ELEMENT: Fixing of a reasonable time within which the Contractor shall have made good or remedied the deficiency which said time shall not be deemed to be an extension of Contract Time or deemed to be authorization for amendment to the construction progress schedule.

An Order of Condemnation may be issued for failure of the Contractor to supply enough workers or enough materials or proper materials, the Order of Condemnation in such event being based on Article 28 of the General Conditions and upon the definition of Work as set forth under Article 41(u).

(q) *Owner.*—The Owner shall mean THE MACON WATER AUTHORITY or its authorized

and legal representatives.

(r) *Products*.—Products shall mean materials or equipment permanently incorporated into the Work.

(s) *Specifications*.—The term “Specifications” shall include all written matter in the bound volume (Divisions 01 through 46, inclusive) or on the drawings and any addenda or modifications thereto.

(t) *Subcontractor*.—The term Subcontractor as employed herein includes only those having a direct contract with the Contractor. It includes one who furnishes labor and materials which are incorporated into the Work but does not include one who merely furnished materials incorporated into the Work by the labor of others.

(u) *Work; Project*.—The terms Work and Project shall mean the entire completed construction required to be furnished under the Contract Documents.

END OF SECTION

SUPPLEMENTARY CONDITIONS

GENERAL (if any condition or specification exists)

The provisions in this Section of the Specifications shall govern in the event of any conflict between this Section, the General Conditions, and/or Specifications.

Policy “A” –Shop Drawing Submittals

Please contact Mr. Joel Herndon, the Macon Water Authority’s (the “Owner’s) Chief Inspector, at 478.464.5639 before commencing the construction activity. The Contractor shall submit five (5) copies of the shop drawings before installation. The Contractor will not be permitted to install materials and appurtenances until all the shop drawings are approved. The Contractor shall submit two copies of as-built drawings after the completion of construction but before the Project is accepted for operation and maintenance. The as-built drawings shall include the following for water/sewer portion of the Project: location of water main, valves, fire hydrants, fittings, water services to each lot, location of sewer mains, manholes (including rim and invert elevations), distance and angle between manholes, distance and length of each lateral from manholes, location of water main, gate valves, fire hydrants and fittings, width of easements and any other pertinent information.

Note: See Section 01720 for additional requirements.

Policy “B” – Televising: All CCTV work shall be per NAASCO standards and per Section 02956.

1. PROJECT MILESTONES & SCHEDULING- It is the desire of the Macon Water Authority to complete this project within the maximum time allowed in the Contract Agreement.

2. BY-PASS PUMPING – NOT USED

2. ACCESS

2.1. PRIVATE PROPERTY

3.1.1 When work is being carried out on public and/or private property, right-of-ways and/or easements, the contractor is responsible for obtaining all permits, permission and approvals required from either entity to do work on their property, right-of-ways and/or easements.

3.1.2 Agreements must be obtained between the Contractor and all public and private property owners, including but not limited to, **City of Macon Parks & Recreation, City of Macon and/or Bibb County, New Town Macon, Georgia Department of Transportation, Norfolk Southern,** and any other municipalities for access to sewer easement and storage of equipment if required. All disturbed areas shall

be restored to equal or better condition either by the Contractor or through an agreement between the Contractor and the property owner. Any access gates or fences disturbed shall be included in the agreements. No additional payment will be made by the Macon Water Authority for this work.

4. PAY ESTIMATE FORM

4.1 Macon Water Authority Pay Estimate Form must be filled in and submitted with each Pay Application.

4.2 The Contractor shall generate an EXCEL spreadsheet listing all items in the Proposal and columns for quantities this period, total this period, total quantities to date, and total amount to date for a detail backup for the attached pay estimate summary sheet.

MWA PAY ESTIMATE FORM – ON NEXT PAGE

5. DELIVERABLES

5.1 **The Contractor shall be responsible to complete in full an EXCEL spreadsheet listing all items and final rehabilitation work completed per the BID as provided by MWA personnel. The total quantities are to be reflected in detail and checked for accuracy and quality assurance.** Please submit final spreadsheet electronically to Heather Veal, CMOM Director, at hveal@maconwater.org or contact for further details at (478) 464-5669.

END OF SECTION



PAY ESTIMATE Summary Sheet

Macon Water Authority

790 Second Street P.O. Box 108
Macon GA 31202
Phone: (478) 464-5600
Fax: (478) 738-3864

Project Name: _____

Project Number: _____

Pay Estimate Number: _____ Partial: _____

Final: _____

Pay Period: _____

Original Contract Amount: \$ _____

Total Change Orders to Date: _____

Current Contract Amount: \$ _____

Original contract Work Performed to Date: _____

Change Order Work Performed to Date: _____

Materials Stored on Job Site: _____

Subtotal: _____

Less (5 %) Previous Retainage: _____

Subtotal: _____

Less Previous Payments: _____

Current Invoice Amount: _____

Less (5 %) Current Retainage: _____

Balance Due This Payment: _____

According to the best of my knowledge and belief, all items and amounts shown on the face of this Pay Estimate are correct; that all Work has been performed or materials supplied, or both, in full accordance with the requirements of the Contract Documents, or duly authorized deviations or additions thereto; that the foregoing is a true and correct statement of the Contract Price account up to and including the last day of the period covered by this Pay Estimate; that none of the "Balance Due This Payment" has been received, and that the undersigned and its Subcontractors have complied with all the labor provisions of the Contract Documents.

The Contractor further certifies that on those items of Work not disputed that all payables, materials, bills, and other indebtedness connected with the Work have been paid (less retention equal to that being retained by the Owner) for Work covered by previous payments. Quantities on request for partial payment are estimated only. Final quantities are by a final survey and "as built" drawings by Contractor.

(Contractor's Name-PRINT)

By: _____
(Signature of Authorized Representative)

Date: _____

Title: _____

By: _____
MWA-Inspector

By: _____
Project Engineer

Date: _____

Date: _____

SUMMARY OF WORK

PART 1 GENERAL

1.1 DESCRIPTION

- A. The Work to be performed under this Contract shall consist of furnishing all labor, materials, tools, equipment and incidentals and performing all operations to rehabilitate approximately 550 linear feet of 12- to 18-inch diameter reinforced concrete stormwater piping via cured-in-place methods as shown on the Drawings.
- B. All Work described above shall be performed as specified in writing to the Contractor. All work shall be done by those skilled in the type of work involved. When new work adjoins, connects or abuts existing work, the latter shall be altered as necessary and the work connected in a substantial and approved workmanlike manner. All work shall match as nearly as practical the existing, adjoining, and/or adjacent similar work. All existing work which is to remain, that is moved or disturbed or damaged by the contractor's operations shall be restored properly to original condition or replaced at no cost to the Owner.

1.2 PROJECT LOCATION

The equipment and materials proposed to be installed are shown on the project plans. The bidders are encouraged to visit the work sites and acquaint themselves with all the requirements of these specifications and all local conditions that may affect the work.

1.3 QUANTITIES

The quantities are as indicated on the Drawings. Owner reserves the right to alter the quantities of work to be performed or to extend or shorten the improvements at any time when and as found necessary, and the Contractor shall perform the work as altered, increased or decreased. Payment for such increased or decreased quantity will be made in accordance with the Instructions to Bidders. No allowance will be made for any change in anticipated profits, nor shall such changes be considered as waiving or invalidating any conditions or provisions of the Contract.

1.4 SCOPE OF WORK

The work to be performed will include, but is not limited to the following items, which shall be provided by the contractor:

- A. Furnishing all labor, materials, tools, equipment and incidentals and performing all operations in connection with CIPP installation and all associated activities such as tap cutting and reinstatement, and all others described in Section 06000 – Sewer Lining CIPP.

- B. Any additional areas that is required to be removed or modified that exceeds the area or length indicated in the bid document must be approved by the engineer of record prior to the demolition. No payment will be made for any work not identified in the bid document without having been approved by the engineer of record prior to the work being completed.

1.5 PARTIAL OWNER OCCUPANCY

The existing facilities to which these improvements are being made will continue operation during the period of construction.

PART 2.0 CONSTRUCTION SPECIFICATIONS

2.1 CONSTRUCTION

- A. Guarantee: In the event that an examination by the Owner reveals evidence of defective materials or workmanship within a period of one year after final completion and acceptance of the work, the Owner may order such defective material replaced and the contractor shall remove and replace the material at his own expense, in a manner acceptable to the Owner.

2.2 PAYMENT

- A. Payment: All work included in the contract will be paid for on a lump sum price basis (see Bid).

END OF SECTION

OCCUPANCY

PART 1 GENERAL

1.01 PARTIAL OCCUPANCY BY OWNER

Whenever, in the opinion of the Engineer, any section or portion of the Work or any structure is in suitable condition, it may be put into use upon the written order of the Engineer and such usage will not be held in any way as an acceptance of said Work or structure, or any part thereof, or as a waiver of any of the provisions of these Specifications and the Contract. Pending final completion and acceptance of the Work, all necessary repairs and replacements, due to defective materials or workmanship or operations of the Contractor, for any section of the Work so put into use shall be performed by the Contractor at Contractor's own expense.

END OF SECTION

MEASUREMENT AND PAYMENT

PART 1 GENERAL

1.01 SCOPE

- A. The Bid lists each item of the Project for which payment will be made. No payment will be made for any items other than those listed in the Bid.
- B. Required items of work and incidentals necessary for the satisfactory completion of the work which are not specifically listed in the Bid, and which are not specified in this Section to be measured or to be included in one of the items listed in the Bid, shall be considered as incidental to the work. All costs thereof, including Contractor's overhead costs and profit, shall be considered as included in the lump sum or unit prices bid for the various Bid items. The Contractor shall prepare the Bid accordingly.
- C. Work includes the clearing and mowing of various existing easements, complete as specified herein, when executed as a separate bid item for the restoration or maintenance of access along the easement. Furnishing all labor, equipment, tools and materials, which are not furnished by the Owner and performing all operations required to complete the work satisfactorily, in place, as specified.

1.02 DESCRIPTIONS

- A. Measurement of an item of work will be by the unit indicated in the Bid.
- B. Final payment quantities shall be determined from documented measurements.
- C. Payment will include all necessary and incidental related work not specified to be included in any other item of work listed in the Bid.
- D. Unless otherwise stated in individual sections of the Specifications or in the Bid, no separate payment will be made for any item of work, materials, parts, equipment, supplies or related items required to perform and complete the work. The costs for all such items required shall be included in the price bid for item of which it is a part.
- E. Payment will be made by extending unit prices multiplied by quantities provided and then summing the extended prices to reflect actual work. Such price and payment shall constitute full compensation to the Contractor for furnishing all labor, equipment, tools and materials not furnished by the Owner and for performing all operations required to provide to the Owner the entire Project, complete in place, as specified and as indicated on the Drawings.
- F. "Products" shall mean materials or equipment permanently incorporated into the work.

1.03 CASH ALLOWANCES – NOT USED

1.04 MOBILIZATION

- A. No separate payment shall be made for mobilization. All mobilization costs shall be included in the unit price bid for the item to which it pertains.

1.05 EASEMENT CLEARING – NOT USED

1.06 EASEMENT MOWING – NOT USED

1.07 TREE REMOVAL – NOT USED

1.08 STUMP REMOVAL – NOT USED

END OF SECTION

CODES AND STANDARDS

PART 1 GENERAL

1.01 DESCRIPTION

- A. Whenever reference is made to conforming to the standards of any technical society, organization, body, code or standard, it shall be construed to mean the latest standard, code, specification or tentative specification adopted and published at the time of advertisement for Bids. This shall include the furnishing of materials, testing of materials, fabrication and installation practices. In those cases where the Contractor's quality standards establish more stringent quality requirements, the more stringent requirement shall prevail. Such standards are made a part hereof to the extent which is indicated or intended.
- B. The inclusion of an organization under one category does not preclude that organizations' standards from applying to another category.
- C. In addition, all work shall comply with the applicable requirements of local codes, utilities and other authorities having jurisdiction.
- D. All material and equipment, for which a UL Standard, an AGA or NSF approval or an ASME requirement is established, shall be so approved and labeled or stamped. The label or stamp shall be conspicuous and not covered, painted, or otherwise obscured from visual inspection.
- E. The standards which apply to this Project are not necessarily restricted to those organizations which are listed in Article 1.02.

1.02 STANDARD ORGANIZATIONS

A. Piping and Valves

ACPA	American Concrete Pipe Association
ANSI	American National Standards Institute
API	American Petroleum Institute
ASME	American Society of Mechanical Engineers
AWWA	American Water Works Association
CISPI	Cast Iron Soil Pipe Institute
DIPRA	Ductile Iron Pipe Research Association
FCI	Fluid Controls Institute
MSS	Manufacturers Standardization Society
NCPI	National Clay Pipe Institute
NSF	National Sanitation Foundation
PPI	Plastic Pipe Institute

- | | | |
|-----------|---|--|
| | UBPPA | Uni-Bell PVC Pipe Association |
| B. | Materials | |
| | AASHTO | American Association of State Highway and Transportation Officials |
| | ANSI | American National Standards Institute |
| | ASTM | American Society for Testing and Materials |
| C. | Painting and Surface Preparation | |
| | NACE | National Association of Corrosion Engineers |
| | SSPC | Steel Structures Painting Council |
| D. | Electrical and Instrumentation | |
| | AEIC | Association of Edison Illuminating Companies |
| | AIEE | American Institute of Electrical Engineers |
| | EIA | Electronic Industries Association |
| | ICEA | Insulated Cable Engineers Association |
| | IEEE | Institute of Electrical and Electronic Engineers |
| | IES | Illuminating Engineering Society |
| | IPC | Institute of Printed Circuits |
| | IPCEA | Insulated Power Cable Engineers Association |
| | ISA | Instrument Society of America |
| | NEC | National Electric Code |
| | NEMA | National Electrical Manufacturers Association |
| | NFPA | National Fire Protection Association |
| | TIA | Telecommunications Industries Association |
| | UL | Underwriter's Laboratories |
| | VRCI | Variable Resistive Components Institute |
| E. | Aluminum | |
| | AA | Aluminum Association |
| | AAMA | American Architectural Manufacturers Association |
| F. | Steel and Concrete | |
| | ACI | American Concrete Institute |
| | AISC | American Institute of Steel Construction, Inc. |
| | AISI | American Iron and Steel Institute |
| | CRSI | Concrete Reinforcing Steel Institute |
| | NRMA | National Ready-Mix Association |
| | PCA | Portland Cement Association |
| | PCI | Prestressed Concrete Institute |
| G. | Welding | |

ASME	American Society of Mechanical Engineers
AWS	American Welding Society
H.	Government and Technical Organizations
AIA	American Institute of Architects
APHA	American Public Health Association
APWA	American Public Works Association
ASA	American Standards Association
ASAE	American Society of Agricultural Engineers
ASCE	American Society of Civil Engineers
ASQC	American Society of Quality Control
ASSE	American Society of Sanitary Engineers
CFR	Code of Federal Regulations
CSI	Construction Specifications Institute
EDA	Economic Development Administration
EPA	Environmental Protection Agency
FCC	Federal Communications Commission
FmHA	Farmers Home Administration
FS	Federal Specifications
IAI	International Association of Identification
ISEA	Industrial Safety Equipment Association
ISO	International Organization for Standardization
ITE	Institute of Traffic Engineers
NBFU	National Board of Fire Underwriters
(NFPA)	National Fluid Power Association
NBS	National Bureau of Standards
NISO	National Information Standards Organization
OSHA	Occupational Safety and Health Administration
SI	Salt Institute
SPI	The Society of the Plastics Industry, Inc.
USDC	United States Department of Commerce
WEF	Water Environment Federation

I. General Building Construction

AHA	American Hardboard Association
AHAM	Association of Home Appliance Manufacturers
AITC	American Institute of Timber Construction
APA	American Parquet Association, Inc.
APA	American Plywood Association
BHMA	Builders Hardware Manufacturers Association
BIFMA	Business and Institutional Furniture Manufacturers Association
DHI	Door and Hardware Institute
FM	Factory Mutual Fire Insurance Company
HPMA	Hardwood Plywood Manufacturers Association
HTI	Hand Tools Institute
IME	Institute of Makers of Explosives

ISANTA	International Staple, Nail and Tool Association
ISDSI	Insulated Steel Door Systems Institute
IWS	Insect Screening Weavers Association
MBMA	Metal Building Manufacturers Association
NAAMM	National Association of Architectural Metal Manufacturers
NAGDM	National Association of Garage Door Manufacturers
NCCLS	National Committee for Clinical Laboratory Standards
NFPA	National Fire Protection Association
NFSA	National Fertilizer Solutions Association
NKCA	National Kitchen Cabinet Association
NWMA	National Woodwork Manufacturers Association
NWWDA	National Wood Window and Door Association
RMA	Rubber Manufacturers Association
SBC	SBCC Standard Building Code
SDI	Steel Door Institute
SIA	Scaffold Industry Association
SMA	Screen Manufacturers Association
SPRI	Single-Ply Roofing Institute
TCA	Tile Council of America
UBC	Uniform Building Code

J. Roadways

AREA	American Railway Engineering Association
DOT	Department of Transportation
SSRBC	Standard Specifications for Construction of Transportation Systems, Georgia Department of Transportation

K. Plumbing

AGA	American Gas Association
NSF	National Sanitation Foundation
PDI	Plumbing Drainage Institute
SPC	SBCC Standard Plumbing Code

L. Refrigeration, Heating, and Air Conditioning

AMCA	Air Movement and Control Association
ARI	American Refrigeration Institute
ASHRAE	American Society of Heating, Refrigeration, and Air Conditioning Engineers
ASME	American Society of Mechanical Engineers
CGA	Compressed Gas Association
CTI	Cooling Tower Institute
HEI	Heat Exchange Institute
IIAR	International Institute of Ammonia Refrigeration
NB	National Board of Boilers and Pressure Vessel Inspectors

PFMA	Power Fan Manufacturers Association
SAE	Society of Automotive Engineers
SMACNA	Sheet Metal and Air Conditioning Contractors National Association
SMC	SBCC Standard Mechanical Code
TEMA	Tubular Exchangers Manufacturers Association

M. Equipment

AFBMA	Anti-Friction Bearing Manufacturers Association, Inc.
AGMA	American Gear Manufacturers Association
ALI	Automotive Lift Institute
CEMA	Conveyor Equipment Manufacturers Association
CMAA	Crane Manufacturers Association of America
DEMA	Diesel Engine Manufacturers Association
MMA	Monorail Manufacturers Association
OPEI	Outdoor Power Equipment Institute, Inc.
PTI	Power Tool Institute, Inc.
RIA	Robotic Industries Association
SAMA	Scientific Apparatus Makers Association

1.03 SYMBOLS

Symbols and material legends shall be as scheduled on the Drawings.

END OF SECTION

PROJECT MEETING

PART 1 GENERAL

1.01 SCOPE

- A. Work under this Section includes all scheduling and administering of pre-construction and progress meetings as herein specified and necessary for the proper and complete performance of this Work.
- B. Scheduling and Administration by Engineer:
 - 1. Prepare agenda.
 - 2. Make physical arrangements for the meetings.
 - 3. Preside at meetings.
 - 4. Record minutes and include significant proceedings and decisions.
 - 5. Distribute copies of the minutes to participants.

1.02 PRECONSTRUCTION CONFERENCE

- A. The Engineer shall schedule the preconstruction conference prior to the issuance of the Notice to Proceed.
- B. Representatives of the following parties are to be in attendance at the meeting:
 - 1. Owner.
 - 2. Engineer.
 - 3. Contractor and superintendent.
 - 4. Major subcontractors.
 - 5. Representatives of governmental or regulatory agencies when appropriate.
- C. The agenda for the preconstruction conference shall consist of the following as a minimum:
 - 1. Distribute and discuss a list of major subcontractors and a tentative construction schedule.

2. Critical work sequencing.
3. Designation of responsible personnel and emergency telephone numbers.
4. Processing of field decisions and change orders.
5. Adequacy of distribution of Contract Documents.
6. Schedule and submittal of shop drawings, product data and samples.
7. Pay request format, submittal cutoff date, paydate and retainage.
8. Procedures for maintaining record documents.
9. Use of premises, including office and storage areas and Owner's requirements.
10. Major equipment deliveries and priorities.
11. Safety and first aid procedures.
12. Security procedures.
13. Housekeeping procedures.
14. Workhours.

1.03 PROJECT COORDINATION MEETINGS

Project Coordination Meetings may be requested at any time at the discretion of the Owner, Engineer or Contractor. The party requesting a meeting shall provide the other two parties with as much notice as possible, as well as a written agenda for such meeting.

END OF SECTION

CONSTRUCTION SCHEDULES

PART 1 GENERAL

1.01 SCOPE

- A. The work under this Section includes preparing, furnishing, distributing, and periodic updating of the construction schedules as specified herein.
- B. The purpose of the schedule is to demonstrate that the Contractor can complete the overall Project within the Contract Time and meet all required interim milestones.

1.02 SUBMITTALS

- A. Overall Project Schedule (OPS)
 - 1. Submit the schedule within 10 days after date of the Notice to Proceed.
 - 2. The Engineer will review the schedule and return it within 10 days after receipt.
 - 3. If required, resubmit within 10 days after receipt of a returned copy.
- B. Near Term Schedule (NTS)
 - 1. Submit the first Near Term Schedule within 10 days of the Notice to Proceed.
 - 2. The Engineer will review the schedule and return it within 10 days after receipt.
- C. Submit an update of the OPS and NTS with each progress payment request.
- D. Submit the number of copies required by the Contractor, plus four copies to be retained by the Engineer.

1.03 APPROVAL

Approval of the Contractor's detailed construction program and revisions thereto shall in no way relieve the Contractor of any of Contractor's duties and obligations under the Contract. Approval is limited to the format of the schedule and does not in any way indicate approval of, or concurrence with, the Contractor's means, methods and ability to carry out the Work.

1.04 OVERALL PROJECT SCHEDULE (OPS)

- A. The Contractor shall submit to the Engineer for approval a detailed Overall Project Schedule of the Contractor's proposed operations for the duration of the Project. The OPS shall be in the form of a Gantt/bar chart.

B. Gantt/Bar Chart Schedule

1. Each activity with a duration of five or more days shall be identified by a separate bar. Activities with a duration of more than 20 days shall be sub-divided into separate activities.
2. The schedule shall include activities for shop drawing preparation and review, fabrication, delivery, and installation of major or critical path materials and equipment items.
3. The schedule shall show the proposed start and completion date for each activity. A separate listing of activity start and stop dates and working day requirements shall be provided unless the information is shown in text form on the Gantt/bar chart.
4. The schedule shall identify the Notice to Proceed date, the Contract Completion date, major milestone dates, and a critical path.
5. The schedule shall be printed on a maximum 11 x 17-inch size paper. If the OPS needs to be shown on multiple sheets, a simplified, one page, summary bar chart showing the entire Project shall be provided.
6. The schedule shall have a horizontal time scale based on calendar days and shall identify the Monday of each week.
7. The schedule shall show the precedence relationship for each activity.

1.05 NEAR TERM SCHEDULE (NTS)

- A. The Contractor shall develop and refine a detailed Near Term Schedule showing the day to day activities with committed completion dates which must be performed during the upcoming 30 day period. The detailed schedule shall represent the Contractor's best approach to the Work which must be accomplished to maintain progress consistent with the Overall Project Schedule.
- B. The Near Term Schedule shall be in the form of Gantt/bar chart and shall include a written narrative description of all activities to be performed and describe corrective action to be taken for items that are behind schedule.

1.06 UPDATING

- A. Show all changes occurring since previous submission of the updated schedule.
- B. Indicate progress of each activity and show actual completion dates.
- C. The Contractor shall be prepared to provide a narrative report at the Project

Coordination Meetings. The report shall include the following:

1. A description of the overall Project status and comparison to the OPS.
2. Identify activities which are behind schedule and describe corrective action to be taken.
3. A description of changes or revisions to the Project and their effect on the OPS.
4. A description of the Near Term Schedule of the activities to be completed during the next 30 days. The report shall include a description of all activities requiring participation by the Engineer and/or Owner.

END OF SECTION

VIDEO AND PHOTOGRAPHS

PART 1 GENERAL

1.01 SCOPE

- A. The Contractor shall furnish all equipment and labor materials required to provide the Owner with a video recording of the Project in DVD or USB format.
- B. DVD's or USB's shall become the property of the Owner and none of the videos herein shall be published without express permission of the Owner.

1.02 PRE AND POST CONSTRUCTION PHOTOGRAPHS

- A. Prior to the beginning of any work, the Contractor shall take project video of the work area to record existing conditions.
- B. Following completion of the work, another recording shall be made showing the same areas and features as in the pre-construction videos.
- C. All conditions which might later be subject to disagreement shall be shown in sufficient detail to provide a basis for decisions. Existing conditions include but are not limited to: driveways, mailboxes, shrubbery, fences, ditch slopes, curbing, etc..
- D. The pre-construction video shall be submitted to the Engineer within 25 calendar days after the date of receipt by the Contractor of Notice to Proceed. Post-construction video shall be provided prior to final acceptance of the project.

END OF SECTION

SECTION 01340

SHOP DRAWINGS, PRODUCT DATA AND SAMPLES

PART 1 GENERAL

1.01 SCOPE

- A. The work under this Section includes submittal to the Engineer of shop drawings, product data and samples required by the various sections of these Specifications.
- B. Submittal Contents: The submittal contents required are specified in each section.
- C. Definitions: Submittals are categorized as follows:
 - 1. Shop Drawings
 - a. Shop drawings shall include technical data, drawings, diagrams, procedure and methodology, performance curves, schedules, templates, patterns, test reports, calculations, instructions, measurements and similar information as applicable to the specific item for which the shop drawing is prepared.
 - b. Provide newly-prepared information, on reproducible sheets, with graphic information at accurate scale (except as otherwise indicated) or appropriate number of prints hereof, with name or preparer (firm name) indicated. The Contract Drawings shall not be traced or reproduced by any method for use as or in lieu of detail shop drawings. Show dimensions and note which are based on field measurement. Identify materials and products in the work shown. Indicate compliance with standards and special coordination requirements. Do not allow shop drawing copies without appropriate final "Action" markings by the Engineer to be used in connection with the Work.
 - c. Drawings shall be presented in a clear and thorough manner. Details shall be identified by reference to sheet and detail, specification section, schedule or room numbers shown on the Contract Drawings.
 - d. Minimum assembly drawings sheet size shall be 24 x 36-inches.
 - e. Minimum detail sheet size shall be 8-1/2 x 11-inches.
 - f. Minimum Scale:
 - (1) Assembly Drawings Sheet, Scale: 1-inch = 30 feet.
 - (2) Detail Sheet, Scale: 1/4-inch = 1 foot.
 - 2. Product Data
 - a. Product data includes standard printed information on materials, products and systems, not specially prepared for this Project, other than the designation of selections from among available choices printed therein.

- b. Collect required data into one submittal for each unit of work or system, and mark each copy to show which choices and options are applicable to the Project. Include manufacturer's standard printed recommendations for application and use, compliance with standards, application of labels and seals, notation of field measurements which have been checked and special coordination requirements.
 3. Samples
 - a. Samples include both fabricated and un-fabricated physical examples of materials, products and units of work, both as complete units and as smaller portions of units of work, either for limited visual inspection or, where indicated, for more detailed testing and analysis.
 - b. Provide units identical with final condition of proposed materials or products for the work. Include "range" samples, not less than three units, where unavoidable variations must be expected, and describe or identify variations between units of each set. Provide full set of optional samples where the Engineer's selection is required. Prepare samples to match the Engineer's sample where indicated. Include information with each sample to show generic description, source or product name and manufacturer, limitations and compliance with standards. Samples are submitted for review and confirmation of color, pattern, texture and "kind" by the Engineer. Engineer will note "test" samples, except as otherwise indicated, for other requirements, which are the exclusive responsibility of the Contractor.
 4. Miscellaneous submittals related directly to the Work (non-administrative) include warranties, maintenance agreements, workmanship bonds, project photographs, survey data and reports, physical work records, statements of applicability, quality testing and certifying reports, copies of industry standards, record drawings, field measurement data, operating and maintenance materials, overrun stock, security/protection/safety keys and similar information, devices and materials applicable to the Work but not processed as shop drawings, product data or samples.

1.02 SPECIFIC CATEGORY REQUIREMENTS

- A. General: Except as otherwise indicated in the individual work sections, comply with general requirements specified herein for each indicated category of submittal. Submittals shall contain:
 1. The date of submittal and the dates of any previous submittals.
 2. The Project title.

3. Numerical submittal numbers, starting with 1.0, 2.0, etc. Revisions to be numbered 1.1, 1.2, etc.
4. The Names of:
 - a. Contractor
 - b. Supplier
 - c. Manufacturer
5. Identification of the product, with the Specification section number, permanent equipment tag numbers and applicable Drawing No.
6. Field dimensions, clearly identified as such.
7. Relation to adjacent or critical features of the Work or materials.
8. Applicable standards, such as ASTM or Federal Specification numbers.
9. Notification to the Engineer in writing, at time of submissions, of any deviations on the submittals from requirements of the Contract Documents.
10. Identification of revisions on resubmittals.
11. An 8 x 3-inch blank space for Contractor and Engineer stamps.
12. Contractor's stamp, initialed or signed, certifying to review of submittal, verification of products, field measurements and field construction criteria and coordination of the information within the submittal with requirements of the Work and of Contract Documents.
13. Submittal sheets or drawings showing more than the particular item under consideration shall have all but the pertinent description of the item for which review is requested crossed out.

1.03 ROUTING OF SUBMITTALS

- A. Submittals and routine correspondence shall be routed as follows:
 1. Supplier to Contractor (through representative if applicable)
 2. Contractor to Engineer.
 3. Engineer to Owner
 4. Owner to Contractor (to be picked up by Contractor)

4. Contractor to Supplier

PART 2 PRODUCTS**2.01 SHOP DRAWINGS**

- A. Unless otherwise specifically directed by the Engineer, make all shop drawings accurately to a scale sufficiently large to show all pertinent features of the item and its method of connection to the Work.
- B. Submit all shop assembly drawings, larger than 11 x 17-inches, in the form of one reproducible transparency with two opaque prints or bluelines.
- C. Submit all shop drawings, 11 x 17-inches and smaller, in the form of six opaque prints or bluelines.
- D. One reproducible for all submittals larger than 11 x 17-inches and no more than three prints of other submittals will be returned to the Contractor.

2.02 MANUFACTURER'S LITERATURE

- A. Where content of submitted literature from manufacturers includes data not pertinent to this submittal, clearly indicate which portion of the contents is being submitted for the Engineer's review.
- B. Submit the number of copies which are required to be returned (not to exceed three) plus three copies which will be retained by the Engineer.

2.03 SAMPLES

- A. Samples shall illustrate materials, equipment or workmanship and established standards by which completed work is judged.
- B. Unless otherwise specifically directed by the Engineer, all samples shall be of the precise article proposed to be furnished.
- C. Submit all samples in the quantity which is required to be returned plus one sample which will be retained by the Engineer.

2.04 COLORS

- A. Unless the precise color and pattern is specifically described in the Contract Documents, wherever a choice of color or pattern is available in a specified product, submit accurate color charts and pattern charts to the Engineer for review and selection.

- B. Unless all available colors and patterns have identical costs and identical wearing capabilities, and are identically suited to the installation, completely describe the relative costs and capabilities of each.

PART 3 EXECUTION

3.01 CONTRACTOR'S COORDINATION OF SUBMITTALS

- A. Prior to submittal for the Engineer's review, the Contractor shall use all means necessary to fully coordinate all material, including the following procedures:
 - 1. Determine and verify all field dimensions and conditions, catalog numbers and similar data.
 - 2. Coordinate as required with all trades and all public agencies involved.
 - 3. Submit a written statement of review and compliance with the requirements of all applicable technical Specifications as well as the requirements of this Section.
 - 4. Clearly indicate in a letter or memorandum on the manufacturer's or fabricator's letterhead, all deviations from the Contract Documents.
- B. Each and every copy of the shop drawings and data shall bear the Contractor's stamp showing that they have been so checked. Shop drawings submitted to the Engineer without the Contractor's stamp will be returned to the Contractor for conformance with this requirement.
- C. The Owner may backcharge the Contractor for costs associated with having to review a particular shop drawing, product data or sample more than two times to receive a "No Exceptions Taken" mark.
- D. Grouping of Submittals
 - 1. Unless otherwise specifically permitted by the Engineer, make all submittals in groups containing all associated items.
 - 2. No review will be given to partial submittals of shop drawings for items which interconnect and/or are interdependent. It is the Contractor's responsibility to assemble the shop drawings for all such interconnecting and/or interdependent items, check them and then make one submittal to the Engineer along with Contractor's comments as to compliance, non-compliance or features requiring special attention.
- E. Schedule of Submittals – Not Used.

3.02 TIMING OF SUBMITTALS

- A. Make all submittals far enough in advance of scheduled dates for installation to provide all required time for reviews, for securing necessary approvals, for possible revision and resubmittal, and for placing orders and securing delivery.
- B. In scheduling, allow sufficient time for the Engineer's review following the receipt of the submittal.

3.03 REVIEWED SHOP DRAWINGS

- A. Engineer Review
 - 1. Allow a minimum of 10 days for the Engineer's initial processing of each submittal requiring review and response, except allow longer periods where processing must be delayed for coordination with subsequent submittals. The Engineer will advise the Contractor promptly when it is determined that a submittal being processed must be delayed for coordination. Allow a minimum of two weeks for reprocessing each submittal. Advise the Engineer on each submittal as to whether processing time is critical to progress of the Work, and therefore the Work would be expedited if processing time could be foreshortened.
 - 2. Acceptable submittals will be marked "No Exceptions Taken". A minimum of three copies will be retained by the Engineer for Engineer's and the Owner's use and the remaining copies will be returned to the Contractor.
 - 3. Submittals requiring minor corrections before the product is acceptable will be marked "Make Corrections Noted". The Contractor may order, fabricate and ship the items included in the submittals, provided the indicated corrections are made. Drawings must be resubmitted for review and marked "No Exceptions Taken" prior to installation or use of products.
 - 4. Submittals marked "Amend and Resubmit" must be revised to reflect required changes and the initial review procedure repeated.
 - 5. The "Rejected - See Remarks" notation is used to indicate products which are not acceptable. Upon return of a submittal so marked, the Contractor shall repeat the initial review procedure utilizing acceptable products.
 - 6. Only two copies of items marked "Amend and Resubmit" and "Rejected - See Remarks" will be reviewed and marked. One copy will be retained by the Engineer and the other copy with all remaining unmarked copies will be returned to the Contractor for resubmittal.

- B. No work or products shall be installed without a drawing or submittal bearing the “No Exceptions Taken” notation. The Contractor shall maintain at the job site a complete set of shop drawings bearing the Engineer's stamp.
- C. Substitutions: In the event the Contractor obtains the Engineer's approval for the use of products other than those which are listed first in the Contract Documents, the Contractor shall, at the Contractor's own expense and using methods approved by the Engineer, make any changes to structures, piping and electrical work that may be necessary to accommodate these products.
- D. Use of the “No Exceptions Taken” notation on shop drawings or other submittals is general and shall not relieve the Contractor of the responsibility of furnishing products of the proper dimension, size, quality, quantity, materials and all performance characteristics, to efficiently perform the requirements and intent of the Contract Documents. The Engineer's review shall not relieve the Contractor of responsibility for errors of any kind on the shop drawings. Review is intended only to assure conformance with the design concept of the Project and compliance with the information given in the Contract Documents. The Contractor is responsible for dimensions to be confirmed and correlated at the job site. The Contractor is also responsible for information that pertains solely to the fabrication processes or to the technique of construction and for the coordination of the work of all trades.

3.04 RESUBMISSION REQUIREMENTS

- A. Shop Drawings
 - 1. Revise initial drawings as required and resubmit as specified for initial submittal, with the resubmittal number shown.
 - 2. Indicate on drawings all changes which have been made other than those requested by the Engineer.
- B. Project Data and Samples: Resubmit new data and samples as specified for initial submittal, with the resubmittal number shown.

END OF SECTION

TEMPORARY FACILITIES

PART 1 GENERAL

1.01 SCOPE

- A. Temporary facilities required for this work include, but are not necessarily limited to:
 - 1. Temporary utilities such as water and electricity.
 - 2. First aid facilities.
 - 3. Sanitary facilities.
 - 4. Potable water.
 - 5. Temporary enclosures and construction facilities.

1.02 GENERAL

- A. First aid facilities, sanitary facilities and potable water shall be available on the Project site on the first day that any activities are conducted on site. The other facilities shall be provided as the schedule of the Project warrants.
- B. Maintenance: Use all means necessary to maintain temporary facilities in proper and safe condition throughout progress of the Work. In the event of loss or damage, immediately make all repairs and replacements necessary, at no additional cost to the Owner.
- C. Removal: Remove all such temporary facilities and controls as rapidly as progress of the Work will permit.

1.03 TEMPORARY UTILITIES

- A. General
 - 1. Provide and pay all costs for all electricity and other utilities, except water, required for the performance of the Work.
 - 2. Pay all costs for temporary utilities, except water, until Project completion.
 - 3. Costs for temporary utilities shall include all power, water and the like necessary for testing equipment as required by the Contract Documents.

B. Temporary Water: Provide all necessary temporary piping, and upon completion of the Work, remove all such temporary piping. Provide and remove water meters.

C. Temporary Electricity

1. Provide all necessary wiring for the Contractor's use.
2. Furnish, locate and install area distribution boxes such that the individual trades may use, their own construction type extension cords to obtain adequate power, and artificial lighting at all points where required by inspectors and for safety.

1.04 FIRST AID FACILITIES

The Contractor shall provide a suitable first aid station, equipped with all facilities and medical supplies necessary to administer emergency first aid treatment. The Contractor shall have standing arrangements for the removal and hospital treatment of any injured person. All first aid facilities and emergency ambulance service shall be made available by the Contractor to the Owner and the Engineer's personnel.

1.05 SANITARY FACILITIES

Prior to starting the Work, the Contractor shall furnish, for use of Contractor's personnel on the job, all necessary toilet facilities which shall be secluded from public observation. These facilities shall be either chemical toilets or shall be connected to the Owner's sanitary sewer system. All facilities, regardless of type, shall be kept in a clean and sanitary condition and shall comply with the requirements and regulations of the area in which the Work is performed. Adequacy of these facilities will be subject to the Engineer's review and maintenance of same must be satisfactory to the Engineer at all times.

1.06 POTABLE WATER

The Contractor shall be responsible for furnishing a supply of potable drinking water for employees, subcontractors, inspectors, engineers and the Owner who are associated with the Work.

1.07 ENCLOSURES AND CONSTRUCTION FACILITIES

Furnish, install and maintain for the duration of construction, all required scaffolds, tarpaulins, canopies, steps, bridges, platforms and other temporary construction necessary for proper completion of the Work in compliance with all pertinent safety and other regulations.

1.08 PARKING FACILITIES

Parking facilities for the Contractor's and Contractor's subcontractors' personnel shall be the Contractor's responsibility. The storage and work facilities provided by the Owner will not be used for parking by the Contractor's or subcontractor's personnel.

END OF SECTION

JOB SITE SECURITY

PART 1 GENERAL

1.01 BARRICADES, LIGHTS AND SIGNALS

- A. The Contractor shall furnish and erect such barricades, fences, lights and danger signals and shall provide such other precautionary measures for the protection of persons or property and of the Work as necessary. Barricades shall be painted in a color that will be visible at night. From sunset to sunrise, the Contractor shall furnish and maintain at least one light at each barricade and sufficient numbers of barricades shall be erected to keep vehicles from being driven on or into any Work under construction.

- B. The Contractor will be held responsible for all damage to the Work due to failure of barricades, signs and lights and whenever evidence is found of such damage, the Contractor shall immediately remove the damaged portion and replace it at Contractor's cost and expense. The Contractor's responsibility for the maintenance of barricades, signs and lights shall not cease until the Project has been accepted by the Owner.

END OF SECTION

SAFETY IN WORK AREAS

PART 1 GENERAL

1.01 SCOPE

- A. The Contractor shall be responsible for conducting all Work in a safe manner and shall take reasonable precautions to ensure the safety and protection of workers, property and the general public. The Contractor's responsibility for protection is described in Articles 21 and 22 of the General Conditions.
- B. All construction shall be conducted in accordance with the latest applicable requirements for Part 1926 of the Occupational Safety and Health Act, Safety and Health Regulations for Construction, Section 107 of the Contract Work Hours and Safety Standards Act, as well as any other local, state or federal safety codes and regulations.
- C. The Contractor shall designate a trained and qualified employee who is to be responsible for ensuring that the Work is performed safely and in conformance with all applicable regulations.
- D. The Contractor shall determine the safety hazards involved in prosecuting the Work and the precautions necessary to conduct the Work safely. If the Contractor is unsure as to any special hazards which may be unique to the various processes, it shall be Contractor's responsibility to determine such information prior to beginning the Work.
- E. The Contractor shall bear all risks associated with performing the Work and shall fully indemnify and hold harmless the Owner and Engineer.

1.02 SPECIAL REQUIREMENTS – Not Used.

END OF SECTION

TRANSPORTATION AND HANDLING

PART 1 GENERAL

1.01 SCOPE

- A. The Contractor shall provide transportation of all equipment, materials and products furnished under these Contract Documents to the Work site. In addition, the Contractor shall provide preparation for shipment, loading, unloading, handling and preparation for installation and all other work and incidental items necessary or convenient to the Contractor for the satisfactory prosecution and completion of the Work.
- B. All equipment, materials and products damaged during transportation or handling shall be repaired or replaced by the Contractor at no additional cost to the Owner prior to being incorporated into the Work.

1.02 TRANSPORTATION

- A. All equipment shall be suitably boxed, crated or otherwise protected during transportation.
- B. Where equipment will be installed using existing cranes or hoisting equipment, the Contractor shall ensure that the weights of the assembled sections do not exceed the capacity of the cranes or hoisting equipment.
- C. Small items and appurtenances such as gauges, valves, switches, instruments and probes which could be damaged during shipment shall be removed from the equipment prior to shipment, packaged and shipped separately. All openings shall be plugged or sealed to prevent the entrance of water or dirt.

1.03 HANDLING

- A. All equipment, materials and products shall be carefully handled to prevent damage or excessive deflections during unloading or transportation.
- B. Lifting and handling drawings and instructions furnished by the manufacturer or supplier shall be strictly followed. Eyebolts or lifting lugs furnished on the equipment shall be used in handling the equipment. Shafts and operating mechanisms shall not be used as lifting points. Spreader bars or lifting beams shall be used when the distance between lifting points exceeds that permitted by standard industry practice.
- C. Under no circumstances shall equipment or products such as pipe, structural steel, castings, reinforcement, lumber, piles, poles, etc., be thrown or rolled off of trucks onto the ground.

- D. Slings and chains shall be padded as required to prevent damage to protective coatings and finishes.

END OF SECTION

STORAGE AND PROTECTION

PART 1 GENERAL

1.01 SCOPE

The work under this Section includes, but is not necessarily limited to, the furnishing of all labor, tools and materials necessary to properly store and protect all materials, equipment, products and the like, as necessary for the proper and complete performance of the Work.

1.02 STORAGE AND PROTECTION

A. Storage

1. Maintain ample way for foot traffic at all times, except as otherwise approved by the Engineer.
2. All property damaged by reason of storing of material shall be properly replaced at no additional cost to the Owner.
3. Packaged materials shall be delivered in original unopened containers and so stored until ready for use.
4. All materials shall meet the requirements of these Specifications at the time that they are used in the Work.
5. Store products in accordance with manufacturer's instructions.

B. Protection

1. Use all means necessary to protect the materials, equipment and products of every section before, during and after installation and to protect the installed work and materials of all other trades.
2. All materials shall be delivered, stored and handled to prevent the inclusion of foreign materials and damage by water, breakage, vandalism or other causes.
3. Substantially constructed weathertight storage sheds, with raised floors, shall be provided and maintained as may be required to adequately protect those materials and products stored on the site which may require protection from damage by the elements.

C. Replacements: In the event of damage, immediately make all repairs and replacements necessary for the approval of the Engineer and at no additional cost to the Owner.

- D. Equipment and products stored outdoors shall be supported above the ground on suitable wooden blocks or braces arranged to prevent excessive deflection or bending between supports. Items such as pipe, structural steel and sheet construction products shall be stored with one end elevated to facilitate drainage.
- E. Unless otherwise permitted in writing by the Engineer, building products and materials such as cement, grout, plaster, gypsumboard, particleboard, resilient flooring, acoustical tile, paneling, finish lumber, insulation, wiring, etc., shall be stored indoors in a dry location. Building products such as rough lumber, plywood, concrete block and structural tile may be stored outdoors under a properly secured waterproof covering.
- F. Tarps and other coverings shall be supported above the stored equipment or materials on wooden strips to provide ventilation under the cover and minimize condensation. Tarps and covers shall be arranged to prevent ponding of water.

1.03 EXTENDED STORAGE

In the event that certain items of major equipment such as air compressors, pumps and mechanical aerators have to be stored for an extended period of time, the Contractor shall provide satisfactory long-term storage facilities which are acceptable to the Engineer. The Contractor shall provide all special packaging, protective coverings, protective coatings, power, nitrogen purge, desiccants, lubricants and exercising necessary or recommended by the manufacturer to properly maintain and protect the equipment during the period of extended storage.

1.04 OWNER FURNISHED EQUIPMENT

The Contractor shall provide storage and protection for all Owner furnished equipment and materials, including extended storage as specified above.

END OF SECTION

CLEANING

PART 1 GENERAL

1.01 SCOPE

This Section covers the general cleaning which the Contractor shall be required to perform both during construction and before final acceptance of the Project unless otherwise shown on the Drawings or specified elsewhere in these Specifications.

1.02 QUALITY ASSURANCE

- A. Daily, and more often if necessary, conduct inspections verifying that requirements of cleanliness are being met.
- B. In addition to the standards described in this Section, comply with all pertinent requirements of governmental agencies having jurisdiction.

1.03 HAZARDOUS MATERIAL AND WASTE

- A. The Contractor shall handle hazardous waste and materials in accordance with applicable local, state, and federal regulations. Waste shall also be disposed of in approved landfills as applicable.
- B. The Contractor shall prevent accumulation of wastes which create hazardous conditions.
- C. Burning or burying rubbish and waste materials on the site shall not be allowed.
- D. Disposal of hazardous wastes or materials into sanitary or storm sewers shall not be allowed.

1.04 DISPOSAL OF SURPLUS MATERIALS

Unless otherwise shown on the Drawings, specified or directed, the Contractor shall legally dispose off the site all surplus materials and equipment from demolition and shall provide suitable off-site disposal site, or utilize a site designated by the Owner.

PART 2 PRODUCTS

2.01 CLEANING MATERIALS AND EQUIPMENT

Provide all required personnel, equipment and materials needed to maintain the specified standard of cleanliness.

2.02 COMPATIBILITY

Use only the cleaning materials, methods and equipment which are compatible with the surface being cleaned, as recommended by the manufacturer of the material or as approved by the Engineer.

PART 3 EXECUTION

3.01 PROGRESS CLEANING

A. General

1. Do not allow the accumulation of scrap, debris, waste material and other items not required for construction of this Work.
2. At least each week, and more often if necessary, completely remove all scrap, debris and waste material from the job site.
3. Provide adequate storage for all items awaiting removal from the job site, observing all requirements for fire protection and protection of the environment.

B. Site

1. Daily, and more often if necessary, inspect the site and pick up all scrap, debris and waste material. Remove all such items to the place designated for their storage.
2. Restack materials stored on site weekly.
3. At all times maintain the site in a neat and orderly condition which meets the approval of the Engineer.

3.02 FINAL CLEANING

- A. Definitions: Unless otherwise specifically specified, "clean" for the purpose of this Article shall be interpreted as the level of cleanliness generally provided by commercial building maintenance subcontractors using commercial quality building maintenance equipment and materials.
- B. General: Prior to completion of the Work, remove from the job site all tools, surplus materials, equipment, scrap, debris and waste. Conduct final progress cleaning as described in 3.01 above.
- C. Site: Unless otherwise specifically directed by the Engineer, hose down all paved areas on the site and all public sidewalks directly adjacent to the site; rake clean other

surfaces of the grounds. Completely remove all resultant debris.

- D. Post-Construction Cleanup: All evidence of temporary construction facilities, haul roads, work areas, structures, foundations of temporary structures, stockpiles of excess or waste materials, or any other evidence of construction, as directed by the Engineer.
- E. Restoration of Landscape Damage: Any landscape feature damaged by the Contractor shall be restored as nearly as possible to its original condition at the Contractor's expense. The Engineer will decide what method of restoration shall be used.
- F. Timing: Schedule final cleaning as approved by the Engineer to enable the Owner to accept the Project.

3.03 CLEANING DURING OWNER'S OCCUPANCY

Should the Owner occupy the Work or any portion thereof prior to its completion by the Contractor and acceptance by the Owner, responsibilities for interim and final cleaning of the occupied spaces shall be as determined by the Engineer in accordance with the Supplementary Conditions of the Contract Documents.

END OF SECTION

RECORD DOCUMENTS

PART 1 GENERAL

1.01 SCOPE

- A. The work under this Section includes, but is not necessarily limited to, the compiling, maintaining, recording and submitting of project record documents as herein specified.
- B. Record documents include, but are not limited to:
 - 1. Drawings;
 - 2. Specifications;
 - 3. Change orders and other modifications to the Contract;
 - 4. Engineer field orders or written instructions, including Requests for Information (RFI) and Clarification Memorandums;
 - 5. Reviewed shop drawings, product data and samples;
 - 6. Test records.
- C. The Contractor shall maintain on the Project site throughout the Contract Time an up to date set of Record Drawings.

1.02 MAINTENANCE OF DOCUMENTS AND SAMPLES

- A. Storage
 - 1. Store documents and samples in the Contractor's field office, apart from documents used for construction.
 - 2. Provide files and racks for storage of documents.
 - 3. Provide locked cabinet or secure storage space for storage of samples.
- B. File documents and samples in accordance with format of these Specifications.
- C. Maintenance
 - 1. Maintain documents in a clean, dry, legible condition and in good order.
 - 2. Do not use record documents for construction purposes.

3. Maintain at the site for the Owner one copy of all record documents.
- D. Make documents and samples available at all times for inspection by Engineer.
- E. Failure to maintain the Record Documents in a satisfactory manner may be cause for withholding of a certificate for payment.

1.03 QUALITY ASSURANCE

- A. Unless noted otherwise, Record Drawings shall provide dimensions, distances and coordinates to the nearest 0.1 foot.
- B. Unless noted otherwise, Record Drawings shall provide elevations to the nearest 0.01 foot for all pertinent items constructed by the Contractor.
- C. The Contractor shall employ a currently registered professional engineer to prepare the Record Drawings from a post-construction, field run survey. The Record Drawings shall provide elevations to the nearest 0.01 foot for all manhole inverts, manhole frames and other pertinent items constructed by the Contractor. The Record Drawings shall provide dimensions, distances, and coordinates to the nearest 0.01 foot and horizontal angles to the nearest 10 seconds.

1.04 RECORDING

- A. Label each document "PROJECT RECORD" in neat, large printed letters.
- B. Recording
 1. Record information concurrently with construction progress.
 2. Do not conceal any work until required information is recorded.

1.05 RECORD DRAWINGS

- A. Record Drawings shall be reproducible, shall have a title block indicating that the drawings are Record Drawings, the name of the company preparing the Record Drawings, and the date the Record Drawings were prepared. The Contractor will be provided paper sepias of the Drawings, or it may elect to provide reproducible drawings via another method. Reproducible shall be defined as being translucent so as to allow a blueline print to be produced.
- B. Legibly mark drawings to record actual construction, including:
 1. All Construction
 - a. Changes of dimension and detail.

- b. Changes made by Requests for Information (RFI), field order, clarification memorandums or by change order.
 - c. Details not on original Drawings.
2. Site Improvements, Including Underground Utilities
- a. Horizontal and vertical locations of all exposed and underground utilities and appurtenances, both new facilities constructed and those utilities encountered, referenced to permanent surface improvements.
 - b. Location of and dimensions of roadways and parking areas, providing dimensions to back of curb when present.
 - c. The locations shall be referenced to at least two easily identifiable, permanent landmarks (e.g., power poles, valve markers, etc.) or benchmarks.
 - d. The Record Drawings shall include the horizontal angle and distance between manhole covers.
3. Structures
- a. Depths of various elements of foundation in relation to finish first floor datum or top of wall.
 - b. Location of internal and buried utilities and appurtenances concealed in the construction, referenced to visible and accessible features of the structure.

1.06 SPECIFICATIONS

- A. Legibly mark each section to record:
- 1. Manufacturer, trade name, catalog number, and supplier of each product and item of equipment actually installed.
 - 2. Changes made by Requests for Information (RFI), field order, clarification memorandums, or by change order.

1.07 SUBMITTAL

- A. At contract closeout, deliver Record Documents to the Engineer for the Owner.
- B. Accompany submittal with transmittal letter, in duplicate, containing:
- 1. Date
 - 2. Project title and number
 - 3. Contractor's name and address
 - 4. Title and number of each record document

5. Signature of Contractor or Contractor's authorized representative
6. Name and address of firm preparing record document
7. Stamp by a professional engineer.

END OF SECTION

WARRANTIES AND BONDS

PART 1 GENERAL

1.01 PROJECT MAINTENANCE AND WARRANTY

- A. Maintain and keep in good repair the Work covered by these Drawings and Specifications until acceptance by the Owner.
- B. The Contractor shall warrant for a period of one year from the date of Owner's written acceptance of certain segments of the Work and/or Owner's written final acceptance of the Project, as defined in the Contract Documents, that the completed Work is free from all defects due to faulty products or workmanship and the Contractor shall promptly make such corrections as may be necessary by reason of such defects. The Owner will give notice of observed defects with reasonable promptness. In the event that the Contractor should fail to make such repairs, adjustments or other work that may be made necessary by such defects, the Owner may do so and charge the Contractor the cost thereby incurred. The Performance Bond shall remain in full force and effect throughout the warranty period.
- C. The Contractor shall not be obligated to make replacements which become necessary because of ordinary wear and tear, or as a result of improper operation or maintenance, or as a result of improper work or damage by another Contractor or the Owner, or to perform any work which is normally performed by a maintenance crew during operation.
- D. In the event of multiple failures of major consequences prior to the expiration of the one year warranty described above, the affected unit shall be disassembled, inspected and modified or replaced as necessary to prevent further occurrences. All related components which may have been damaged or rendered non-serviceable as a consequence of the failure shall be replaced. A new 12 month warranty against defective or deficient design, workmanship, and materials shall commence on the day that the item is reassembled and placed back into operation. As used herein, multiple failure shall be interpreted to mean two or more successive failures of the same kind in the same item or failures of the same kind in two or more items. Major failures may include, but are not limited to, cracked or broken housings, piping, or vessels, excessive deflections, bent or broken shafts, broken or chipped gear teeth, premature bearing failure, excessive wear or excessive leakage around seals. Failures which are directly and clearly traceable to operator abuse, such as operations in conflict with published operating procedures or improper maintenance, such as substitution of unauthorized replacement parts, use of incorrect lubricants or chemicals, flagrant over or under lubrication and using maintenance procedures not conforming with published maintenance instructions, shall be exempted from the scope of the one year warranty. Should multiple failures occur in a given item, all products of the same size and type shall be disassembled, inspected, modified or replaced as necessary and rewarranted for one year.

- E. The Contractor shall, at Contractor's own expense, furnish all labor, materials, tools and equipment required and shall make such repairs and removals and shall perform such work or reconstruction as may be made necessary by any structural or functional defect or failure resulting from neglect, faulty workmanship or faulty materials, in any part of the Work performed by the Contractor. Such repair shall also include refilling of trenches, excavations or embankments which show settlement or erosion after backfilling or placement.
- F. Except as noted on the Drawings or as specified, all structures such as embankments and fences shall be returned to their original condition prior to the completion of the Contract. Any and all damage to any facility not designated for removal, resulting from the Contractor's operations, shall be promptly repaired by the Contractor at no cost to the Owner.
- G. The Contractor shall be responsible for all road and entrance reconstruction and repairs and maintenance of same for a period of one year from the date of final acceptance. In the event the repairs and maintenance are not made immediately and it becomes necessary for the owner of the road to make such repairs, the Contractor shall reimburse the owner of the road for the cost of such repairs.
- H. In the event the Contractor fails to proceed to remedy the defects upon notification within 15 days of the date of such notice, the Owner reserves the right to cause the required materials to be procured and the work to be done, as described in the Drawings and Specifications, and to hold the Contractor and the sureties on Contractor's bond liable for the cost and expense thereof.
- I. Notice to Contractor for repairs and reconstruction will be made in the form of a registered letter addressed to the Contractor at Contractor's home office.
- J. Neither the foregoing paragraphs nor any provision in the Contract Documents, nor any special guarantee time limit implies any limitation of the Contractor's liability within the law of the place of construction.

END OF SECTION

SECTION 02956

INSPECTION OF SEWERS FOR CLEANING, REPAIRS, LINING, AND NEW PIPE INSTALLATIONS

PART 1 GENERAL

1.1 SUMMARY:

- A. Provide all labor, materials, and equipment necessary to perform inspections on sewers to verify the conditions of the pipe and acceptance criteria of Work performed:
 - 1. Prior to, during, or after cleaning pipe.
 - 2. Prior to and after repairing pipe.
 - 3. Prior to and after lining a pipeline.
 - 4. After installation of a new pipe.

1.2 RELATED DOCUMENTS:

- A. Drawing, Technical Specification Sections, General and Supplementary Conditions of the Contract and other Division 00 and Division 01 Specification Sections, apply to this Section.
- B. Specifications throughout all Divisions of the Project Manual are directly pertinent to this Section, and this Section is directly pertinent to them.

1.3 REFERENCED SECTIONS:

- A. Sections specified elsewhere may include but are not limited to:
 - 1. Section 01340: Submittals.

1.4 REFERENCED CODES AND STANDARDS:

- A. National Association of Sewer Service Companies (NASSCO).
 - 1. Pipeline Assessment and Certification Program (PACP) Reference Manual.

1.5 SUBMITTALS:

- A. Provide submittals in accordance with Section 01340.
- B. Submit the following:
 - 1. Qualifications for the contractor performing inspections.
 - 2. Qualifications for the equipment operator.
 - 3. Inspection logs.
 - 4. Inspection reports.
 - 5. Electronic NASSCO PACP database of the inspections.
 - 6. CCTV Video and/or Sonar recordings.

7. Certification and acceptance by lining installer.

1.6 QUALIFICATIONS:

- A. Contractor Qualifications:
 - 1. Perform inspections using a company that is engaged in performing inspections using the type of equipment that will be used to perform the inspections and has inspected no less than 100,000 LF of sewers.
- B. Operator Qualification Requirements:
 - 1. Certified as a NASSCO PACP certified operator with a minimum of three (3) years' experience performing inspections as a NASSCO PACP certified operator.
 - 2. A minimum of three (3) years of experience inspecting, processing, and interpreting data.
 - 3. Submit copies of PACP certification and experience history for each operator prior to beginning work.

1.7 REPORTS:

- A. Inspection Logs:
 - 1. Submit inspection logs containing the following information for all inspections:
 - a. Inspection log for all inspections including, but not limited to:
 - 1) Job and/or work assignment number.
 - 2) Date and time of inspection.
 - 3) Location and identification of pipeline section televised.
 - 4) Upstream and downstream manholes.
 - 5) Direction of inspection.
 - 6) Size and type of pipe.
 - 7) Length of pipeline section televised.
 - 8) Locations of all service connections.
 - 9) Traffic Control, if used.
 - 10) Name of Subcontractors performing work during the inspection, if any.
 - 11) Location of all observed structural deficiencies, Operation and Maintenance deficiencies, construction features, and miscellaneous features in accordance with the National Association of Sewer Service Companies (NASSCO) Pipeline Assessment Certification Program (PACP).
 - 2. Pre-Cleaning:
 - a. Include the following data in the inspection logs when documenting pre- cleaning inspections:
 - 1) The amount of cleaning required.

- 2) Location of service laterals.
 - 3) Sags, breaks, offsets, open joints, and other structural conditions that may warrant immediate attention to repairs.
 3. Post Cleaning:
 - a. Include the following data in the inspection logs when documenting post cleaning inspections:
 - 1) Locations where additional cleaning is required.
 - 2) Location of service laterals.
 - 3) Sags, breaks, offsets, open joints, and other structural conditions that may warrant immediate attention to repairs.
 4. Pre-Lining:
 - a. Include the following data in the inspection logs when documenting post pre-lining inspections:
 - 1) Locations where additional cleaning is required prior to lining.
 - 2) Sags, breaks, offsets, open joints, protruding service connections, and other structural conditions that will prevent proper installation of liner.
 - 3) Verification that necessary repairs are performed prior to lining the pipe.
 5. Post Lining:
 - a. Include the following data in the inspection logs when documenting post lining inspections:
 - 1) Existence and location of imperfections that do not meet the quality requirements of the specification under which the liner was installed.
 6. New Pipe:
 - a. Include the following data in the inspection logs when documenting the inspections performed on new pipe installations:
 - 1) Condition of the pipe at joints, fittings, and points of concern.
 - 2) Data required to verify visual inspection and grade tolerance for new pipe installation as defined by the Contract Documents.
- B. Inspection Reports:
 1. Submit a summary report describing the conditions of the pipe during the inspections including:
 - a. A NASSCO PACP certified worksheet.
 2. When the pipe is to be lined, include in the inspection report the

following:

- a. The general condition of the pipe after cleaning and prior to lining.
- b. Certification and acceptance by the lining installer acknowledging the pipe is ready to be lined and that the conditions within the pipe will permit installation of the lining in accordance with the requirements of the specification to which the lining is being installed.
- c. Recommendations, from the lining installer, regarding additional repairs, cleaning, etc. that need to be made prior to installing the lining.

1.8 ELECTRONIC DATA:

- A. Submit digital copies of the certified NASSCO PACP database of each inspection to Macon Water Authority on flash drive or hard drive that is USB 3.0 compatible.
- B. Provide inspection logs and summary reports with the digital copies.

PART 2. PRODUCTS

2.1 CABLE DRUM AND CABLE:

- A. Cable Drum Requirements:
 1. Motorize with variable speed.
 2. Include serial communications for all speed and direction controls.
 3. Capable of being controlled from the computer keyboard and through mouse click commands or a variable speed “joy stick” controller.
 4. Sufficient capacity to support the length of cable necessary to inspect the pipe without performing a reverse inspection but not less than 2000 linear feet, unless specified otherwise on the Contract.
- B. Cable Requirements:
 1. Dual jacketed with polyurethane and waterproof for constant underwater operations.
 2. Sufficient length to inspect the longest length of pipe in a single direction but not less than 2000 linear feet unless noted otherwise on the Contract.

2.2 CCTV SYSTEM:

- A. Television Inspection Equipment Requirements:
 1. Pipe inspection Camera with the following properties:
 - a. Camera operating temperature range of 32°F to 122°F.
 - b. Imager sensor of ¼” color CCD with minimum 0.4 megapixel or better resolution.
 - c. Producing a video recording using a pan-and-tilt, radial viewing, pipe inspection camera that pans \pm 285 degrees and rotates 360

- degrees with a variable pan speed not to exceed 25 degrees per second.
- d. Camera height adjustment so that the camera lens is always centered at one-half (1-1/2) the inside diameter, or higher, in the pipe being televised.
 - e. Full, true color, sharp image video bandwidths with no sacrifice or visible streaking of low frequency response.
 - f. 525 scanning lines, 60 fields, 30 frames, interlaces 2:1 - NTSC Color Standard, with geometrical image distortion not exceeding two percent (2%) (picture transmission systems requiring use of R.F. suppressors and subject to local transmitter interference not acceptable).
 - g. Equipped with an f/1.4 wide angle lens with optical viewing angle to 70 degrees, auto iris type to control the illumination range for an acceptable picture between ten (10) and 100,000 Lux, with manual override remotely controlled from the viewing station.
 - h. Equipped with high output strobe lighting system capable to illuminate six (5) to 60 inch sewer pipes without externally-mounted lighting.
 - i. A 40:1 zoom length capable of ten times (10X) optical and four times (4X) digital, with auto and manual remote focus capability.
 - j. Video capture equipment that is capable of continuously capturing digital video from first generation recordings with no frame loss, regardless of the progression of the inspection.
2. CD/DVD recorder with the following properties:
 - a. Slow motion playback without noise bars.
 - b. Capability to document the inspection with 90 minute duration maximum, with "data view" indicating project address identification, date, and voice description of the inspection during video recording.
 3. On board television viewing monitor with the following properties:
 - a. High resolution industrial grade color unit providing 3.1 megapixels of resolution or greater.
 - b. Minimum 12 inch diagonally screen.
 - c. Voltage compensation circuits to reduce picture distortion to less than one percent (1%) under voltage conditions varying from 105V to 120V.
 - d. Housed in a steel cabinet which acts as shield to minimize effects of local magnetic fields such as transformers, coils, wraps of cable, etc. (monitors having inadequate or no protection from local magnetic fields, thereby contributing to loss of color picture purity, not acceptable).
 - e. Speaker to allow for audio playback from CD/DVD recording.

B. Document Recordings:

1. Provide in digital format.
2. Store image capture in JPEG formats.
3. Video capture file requirements:
 - a. Be stored in industry standard Windows Media or MPEG-4 format on a USB 3.0 compatible external hard drive and viewable on a personal computer that utilizes Microsoft Media Player.
 - b. Have a minimum resolution of 640 pixels (x) by 480 pixels (y) and an encoded frame rate of 29.97 frames per second.

C. Lighting Equipment Requirements:

1. A halogen lighting system comprised of controlled-beam, reflector-sealed lamps with an automatic light compensator.
2. Capable of supplying dimmable 40-LED array illumination.

2.3 SONAR SYSTEM: NOT USED

2.4 TRANSPORT/PLATFORM:

A. Transport/Platform Requirements:

1. Portable, manual winches or motorized mechanical equipment of indirect drive type.
2. Have sufficient cable or rods to permit inspection of all sewer main sections specified.
3. Capable of moving camera through the pipeline in either direction at a uniform, slow rate.
4. Capable of zero (0) degree turning radius.
5. Fit through a manhole with a minimum inside diameter of 24 inch without modifications to the access structure.
6. If transport is tracked, have multiple wheel set or sufficient torque to maximize traction in large diameter pipe or in adverse pipe conditions including high flow, deep mud, sand and large amount of debris commonly found in storm and sanitary sewers.
7. Be stable in high-velocity flows of up to eight (8) ft/ sec.
8. Support simultaneous use of multiple sensors when appropriate.

2.5 METERING DEVICE:

A. Metering Device Requirements:

1. Display the equipment location at ground level on the monitor screen.
2. Enable the distance recorder to be set at zero (0) from the inspection vehicle.
3. Have an accuracy of plus or minus one (1) percent.
4. Display the distance moved through the pipe on the monitor screen and

be logged along with the saved images for accurate determination of where defects exist in the pipe relative to the deployment location.

2.6 MONITORING VEHICLE:

- A. Monitoring Vehicle Requirements:
 - 1. Separate viewing and working areas.
 - 2. A means to control internal and external sources of light to ensure that the monitor screen display is clearly visible.
 - 3. Seating for two (2) people in addition to the operator, with clear view of the inspection monitor.
 - 4. The ability to print inspection images with text annotations highlighting specific points in the image and the current control settings.

2.7 REMOTE VISIBILITY:

- A. Provide capability to stream CCTV and Sonar video wirelessly for remote viewing by personnel at a remote location.

PART 3. EXECUTION

3.1 CCTV PRIME POSITION:

- A. Position the CCTV/Sonar camera to minimize picture distortion.
- B. In circular sewers, position the CCTV/Sonar camera lens in the center of the pipe.
- C. In non-circular sewers, position the CCTV/Sonar lens at mid-height, unless otherwise agreed, and centered horizontally.
- D. In all instances, position the camera lens parallel with the axis of the sewer. A positioning tolerance of plus or minus ten percent ($\pm 10\%$) of the vertical sewer dimension will be allowed.

3.2 INSPECTIONS – GENERAL:

- A. Perform inspections using CCTV and/or Sonar as required by the Contract documents or as necessitated by the flows in the pipe.
- B. Perform all inspections in accordance with NASSCO PACP guidelines.
- C. Provide Macon Water Authority with access to the television monitor and all other operations at all times.
- D. Set the zero (0) point for the metering device at the center of the manhole or access box.
- E. Move the camera through the pipe at a moderate rate, stopping when necessary to permit proper documentation of the condition of the pipeline.
- F. Maximum camera speed of not greater than 30 feet per minute
- G. Stop inspection equipment at each service lateral, defect, and point of interest for not less than ten (10) seconds while recording the condition of the lateral and defect.
- H. Rotate and move the camera as necessary to fully inspect and document each

service lateral, defect, and point of interest from multiple angles to clearly show the extent and nature of the item.

- I. Record audio designations to the video for each service lateral, defect, and point of interest.
- J. If the camera becomes stuck in the pipeline, perform all actions necessary to remove the camera at no additional cost to Macon Water Authority.
- K. Record and document all inspections and provide paper and electronic copies of inspection reports as well as digital copies of the inspection recordings to Macon Water Authority.

3.3 REPAIR AND LINING INSPECTIONS:

- A. Perform lining inspections using CCTV unless specified otherwise.
- B. Pre-Lining Inspection:
 - 1. Perform pre-lining inspection immediately prior to installing a repair or lining system.
 - 2. Inspect the interior of each segment of pipe to verify the pipe is properly prepared for the repair or installation of the liner and that the pipe complies with the requirements of the repair or lining specification.
 - 3. Certify to Macon Water Authority that the pipe is suitable for repair and lining and that no conditions exist that will damage the repair or liner during installation activities.
- C. Post Lining Inspection:
 - 1. Perform post lining inspections after the repair or liner is installed and before opening the service connections.
 - 2. Inspect the installation condition of the newly installed repair or liner to verify the installation complies with the requirements of the repair or lining specification.
 - 3. If no service laterals are connected to the pipe segment, then this inspection can be used as the Final Lining Installation Inspection.
- D. Final Lining Installation Inspection:
 - 1. Perform final lining installation inspection after all service laterals are reinstated.
 - 2. Inspect the installation of the liner at the laterals and show that reinstatement of each lateral complies with the requirements of the lining specification.

3.4 CLEANING INSPECTIONS:

- A. Pre-Cleaning Inspection:
 - 1. Perform pre-cleaning inspection immediately prior to cleaning the sewer.
 - 2. Inspect the pipe to determine the level (low, medium, or high) of cleaning that will be required to clean the pipe to allow follow-on work to be performed.
 - 3. If the inspection cannot be fully performed from a single direction, attempt to complete the inspection from the other direction.

4. Pre-cleaning inspection will be paid at the unit rate stated in the SOP.
- B. Post Cleaning Inspection:
1. Perform post cleaning inspection immediately after the sewer is cleaned.
 2. Inspect the pipe to determine if cleaning complies with the requirements of the cleaning specification.
 3. Post cleaning inspection is considered incidental to the cleaning and will not be paid.

3.5 NEW PIPE INSTALLATION INSPECTIONS:

- A. Inspect New Pipe When:
1. Pipe has been installed and backfill has been placed and compacted around and over the pipe to finished elevation.
 2. Macon Water Authority believes the pipe was installed improperly and the integrity of the pipe is compromised.
 3. The pipe was subjected to construction activities that may have compromised the integrity of the pipe.
- B. Inspect the pipe to determine if the pipe installation complies with the specification's requirements for the installed pipe.

END OF SECTION

SEWER LINING CIPP

PART 1. GENERAL

1.1 SUMMARY

1.2 RELATED DOCUMENTS

1.3 REFERENCED SECTIONS

1.4 REFERENCED CODES AND STANDARDS:

1.5 DEFINITIONS:

1.6 WARRANTY:

1.7 SUBMITTALS:

- a. Short-term (Initial) Flexural Modulus, Long-term (50-year) Flexural Modulus, and Flexural Strength Testing Data in accordance with the appropriate ASTM Standard.
- b. Safety Data Sheets.

1.8 QUALITY ASSURANCE:

Manufacturer shall have:

CIPP Installer shall have:

CIPP Installer Field Superintendent shall have:

If the Field Superintendent changes at any time during the performance of the work, submit documentation of compliance for the proposed Field Superintendent prior to the replacement Field Superintendent arriving on site.

1.9 DELIVERY, STORAGE AND HANDLING:

1.10 WORK PLAN:

1.11 STYRENE MANAGEMENT PLAN:

1.12 SCHEDULING:

PART 2. PRODUCTS

2.1 GENERAL:

2.2 FABRIC TUBE:

2.3 RESIN SYSTEM:

2.4 HYDROPHILIC END SEALS:

2.5 PRELINERS:

2.6 CIPP DESIGN CRITERIA:

PART 3. EXECUTION

3.1 GENERAL:

3.2 CUSTOMER OUTREACH:

3.3 PRE-INSTALLATION:

3.4 INSTALLATION:

The curing temperatures.

The duration of holding the pressurized fluid at curing temperatures.

Place temperature gauges at the upstream and downstream ends of the Reach being lined to monitor the pressurized fluid's (air or water) temperature.

Document the following curing readings in curing logs every 30 minutes:

- a. Install a Temperature Monitoring System in all pipes 36 inches and larger being lined with CIPP.
- b. The system shall monitor the curing process over the entire length of the CIPP.
- c. The monitoring system and related software shall be capable of monitoring curing temperature continuously during installation along the full length of the CIPP liner.

Prior to installing the CIPP in the host pipe, confirm the temperature monitoring system's proper function.

Monitor the sensors using a device that can record the temperatures throughout the entire curing period utilizing a tamper-proof database.

If the monitoring system fails, record temperature gauges near each manhole with manual temperature readings every 30 minutes.

Document curing temperatures from the temperature monitoring system in curing logs.

A built-in process that monitors the curing as the light train travels through the CIPP.

An automated computer control system that adjusts light temperature, intensity, wavelength and speed of light train.

A fully restored service connection shall be free from burrs or projections and have a smooth and crack-free edge.

The hole shall be 90% minimum and 100% maximum of the original service connection inside diameter.

The invert of the service connection shall match the invert of the reinstalled service opening.

- a. A one (1) piece homogenous main and lateral CIPP connection liner formed as a structural cylinder that renews 18 inches and 360 degrees of the main line and extends up the lateral piece as a continuous lining six (6) inches.

Build up the invert to remove any flow restrictions and to form a continuous invert through the manhole.

Flat and remove CIPP material above the top of the existing channel.

Cut and shape the bench of the manhole as necessary to support the CIPP.

3.5 ENVIRONMENTAL CONTROLS:

3.6 POST-INSTALLATION VIDEO INSPECTION:

3.7 SITE RESTORATION:

3.8 FIELD QUALITY CONTROL AND TESTING:

- a. 1500 to 3000 LF – one (1) set of three (3) samples from 2 different locations.
 - b. Greater than 3000 LF – one (1) set of three (3) samples from each 3000 LF or portion thereof.
 - c. The number of samples sets taken are independent of the number of different Reaches lined.
 - d. Locations will be determined by Macon Water Authority.
- A. Provide all labor, tools, materials, equipment, and supervision necessary to install Cured- in-Place Pipe (CIPP) including, but not limited to installing CIPP system, trimming protruding

- Laterals, reconnecting Laterals, preliners, grouting, performing quality control, taking samples and testing product, and reinstating existing connections.
- B. Drawings, Technical Specification Sections, General and Supplementary Conditions of the Contract, and other Division 00 and Division 01 Specification Sections, apply to this Section.
- C. Specifications throughout all Divisions of the Contract Documents are directly pertinent to the Section, and this Section is directly pertinent to them.
- D. Sections specified elsewhere may include but are not limited to:
1. Section 01300: Submittals.
 2. Section 01320: Video and Photographs.
 3. Section 01351: Public Notification - (Sewer).
- E. ASTM International (ASTM):
1. ASTM C581: “Standard Practice for Determining Chemical Resistance of Thermosetting Resins Used in Glass Fiber Reinforced Structures, Intended for Liquid Service”.
 2. ASTM D543: “Standard Practices for Evaluating the Resistance of Plastics to Chemical Reagents”.
 3. ASTM D790: “Standard Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials”.
 4. ASTM D3567: “Standard Practice for Determining Dimensions of “Fiberglass” (Glass-Fiber-Reinforced Thermosetting Resin) Pipe and Fittings”.
 5. ASTM D5813: “Standard Specification for Cured-In-Place Thermosetting Resin Sewer Piping Systems”.
 6. ASTM F1216: “Standard Practice for Rehabilitation of Existing Pipelines and Conduits by the Inversion and Curing of a Resin-Impregnated Tube”.
 7. ASTM F1743: “Standard Practice for Rehabilitation of Existing Pipelines and Conduits by Pulled-in-Place Installation of Cured-in-Place Thermosetting Resin Pipe (CIPP)”.
 8. ASTM F2019: “Standard Practice for Rehabilitation of Existing Pipelines and Conduits by the Pulled in Place Installation of Glass Reinforced Plastic (GRP) Cured-in-Place Thermosetting Resin Pipe (CIPP)”.
- F. CIPP: Cured-in-Place Pipe (CIPP) is a resin-impregnated flexible tube that is either inverted or pulled into a pipeline/conduit and expanded to fit tightly against said pipeline by using water or air pressure. The resin system is cured to create a continuous and tight-fitting pipeline by either:
1. Elevating the temperature of the fluid (water/air), used to inflate the pipe, to a sufficient level for the initiators in the resin to create a thermosetting reaction, or
 2. Using ultraviolet (UV) light to create a thermosetting resin.
- G. CIPP Installer: The firm who installs the CIPP system. The CIPP Installer could be the Contractor.
- H. Lateral: Service pipe from property line to sewer main, excluding the Lateral Connection.
- I. Lateral Connection: The junction connecting the Lateral to the sewer main.
- J. Lateral Connection Seal: Watertight seal between Lateral and the sewer main.

- K. Manufacturer: Manufacturer of the CIPP System, which includes the fabric tube, the resin system, and other components as needed for CIPP installation.
- L. Reach: A length of pipe between two points containing a specified feature; usually manholes.
- M. The Contractor shall provide a Warranty for all Work for a period of one (1) year from the date of Substantial Completion.
- N. During the Warranty period, Macon Water Authority may inspect the installed CIPP at Macon Water Authority's expense. The Contractor will be notified a minimum of fourteen (14) days prior to the inspection and is invited to attend.
- O. At any point prior to the end of the Warranty, if the CIPP has defects as defined in the Table in Paragraph 3.9, the defects shall be remedied by the Contractor in accordance with Section 00700 – General Conditions.
- P. Requirements for ‘Submittals’ shall be in accordance with Section 01340.
- Q. Submit qualification documentation for:
 - 1. Manufacturer.
 - 2. CIPP Installer.
 - 3. Field Superintendent for the CIPP Installer.
- R. Submit the following Manufacturer's information:
 - 1. Certification that the materials to be used meet the requirements of ASTM F1216 and/or ASTM D5813.
 - 2. Recommendations for shipping, storage and handling of all components of the CIPP System.
 - 3. Recommended pressures, temperatures, and durations for insertion, heat up, curing, and cool down phases.
 - 4. Product data and instructions for resin and catalyst system, including:
 - 5. Product data and instructions for felt and/or fiberglass tube and sealing materials.
- S. Submit the following:
 - 1. Work Plan.
 - 2. Design calculations.
 - 3. Quality Control Plan
 - 4. Styrene Management Plan.
- T. Submit the following documentation the same day as the CIPP installation:
 - 1. Wet-out report when wet-out is performed on site.
 - 2. Curing logs.
- U. Submit the pre-construction and post-construction CCTV inspection documentation within 14 days of the CIPP Installation.
- V. Qualifications and Experience:
 - 1. Provide evidence and documentation demonstrating the minimum qualifications for the Manufacturer, CIPP Installer, and CIPP Installer Field Superintendent as follows:
 - 1) At least five years active experience in the commercial application of CIPP.

- 2) A CIPP System with a minimum of 500,000 linear feet and 1,500 CIPP Reaches successfully installed.
 - 1) At least three years active experience in the commercial installation of the CIPP product bid.
 - 2) At least 50,000 linear feet and 200 Reaches of successful installations.
 - 3) A minimum of five (5) projects of comparable length, diameter (circular and other shapes) and/or complexity. Provide a list of projects with:
 - a) Project names.
 - b) Years' work was performed
 - c) Owner contact names and current phone numbers.
 - d) Diameter(s) and length(s) of lined pipes.
 - e) Construction start and completion dates.
 - 4) A license or certificate from the Manufacturer stating the CIPP Installer is approved and/or qualified to install the Manufacturer's CIPP system.
 - 1) Been the Superintendent on a minimum of 25,000 linear feet of installation.
 - 2) At least three (3) years' experience with CIPP. Provide a list of similar projects managed by the Superintendent. The list shall include:
 - a) Project names.
 - b) Years' work was performed.
 - c) Owner contacts and current phone numbers.
 - 3) Strong communication skills, both written and oral, to ensure that the work proceeds in a proper and efficient manner.
- W. Quality Control Plan:
1. A checklist for documenting critical steps in the CIPP process.
 2. Defined responsibilities of the personnel assuring all quality requirements are met.
- X. Protect, store, and handle materials during transportation and delivery, while stored on- site, and during installation following manufacturer's recommendations.
- Y. Maintain CIPP at proper temperature in refrigerated facilities and/or sunlight protected facilities to prevent premature curing prior to installation.
- Z. Immediately remove from site any CIPP showing evidence of premature curing.
- AA. Repair or replace any CIPP material that becomes damaged before or during insertion. Repair or replacement will be at the Contractor's sole expense.
- BB. The Work Plan for each Reach shall include:
1. CIPP installation site plan and layout. Redline markups on design plans are sufficient.
 2. Critical steps in the CIPP process.
 3. Access and termination points. Redline markups on design plans are sufficient.
 4. Field verified pipe diameter and Reach lengths. Redline tables on design plans is acceptable.

5. Equipment to be used.
 6. Method of CIPP insertion (e.g., air inversion, water inversion, pulled-in-place, etc.), cure method (e.g., water, hot air/steam, UV, etc.).
- CC. Submit Work Plan for each pipe Reach a minimum of 14 days in advance of wet out.
1. Multiple Work Plans for different Reaches may be submitted.
 2. Do not begin work on any Reach until the Work Plan has been approved.
- DD. Prepare and submit Styrene Management Plan which shall include the following:
1. Styrene SDS.
 2. Manufacturer's recommendations to mitigate odors from area around job site and Contractor's plan to comply with those recommendations.
 3. Plan to prevent water with styrene from entering storm drains, outfalls, open waterways, and other similar waterways.
 4. Plan to discharge water with styrene to sanitary sewer. Note that discharge to a combined sewer is only allowed when combined sewer overflows are not likely.
 5. Description of PPE for workers on job site.
 6. Sample of signs to be posted around job site to inform public of health issues and mitigation strategies associated with styrene.
 7. Location of signs described in preceding bullet (redline markup on Contract Drawings are sufficient).
- EE. Submit proposed work schedules a minimum of seven (7) days prior to all planned work.
- FF. Provide 48 hours advance verbal notice prior to pre- and post-installation CCTV inspection.
- GG. Identify in the work schedules and verbal notices any shifts that may take longer than eight hours or require work to be performed outside the approved working hours.
- A. All components of the CIPP shall be new and free of defects and shall be:
1. Continuous and of sufficient length to extend between consecutive Reaches.
 2. Homogeneous across the entire wall thickness containing no intermediate or encapsulated elastomeric layer.
 3. Void of material in the tube that may cause delamination in the cured product.
 4. Fully wetted with no dry or unsaturated layers evident.
 5. Capable of conforming to offset joints, bells, and disfigured pipe sections.
 6. Able to stretch to fit irregular pipe sections and negotiate bends.
 7. Have an interior pipe surface wall color after installation that is a light reflective color.
- B. The tube shall consist of one or more layers of a flexible needled felt or an equivalent nonwoven or woven material, or a combination of nonwoven and woven materials, capable of carrying resin and withstanding the installation pressures and curing temperatures, and in accordance with ASTM F1216, F1743, D5813, and F2019, as applicable.
- C. The tube shall be:
1. Compatible with the resin system to be used on this project.
 2. Fabricated to a size that, when installed, will tightly fit the internal circumference and

- the length of the original conduit. Make allowances for the longitudinal and circumferential stretching that occurs during placement of the tube.
3. Uniform in thickness and when subjected to the installation pressures will meet the designed finish wall thickness within negative five percent (-5%) to plus ten percent (+10%).
 4. Marked for distance at regular intervals along its entire length, not to exceed five feet. Such markings shall also include the manufacturer's name or identifying symbol.
- D. Inversion Fabric Tube: the outside layer of fabric tube shall be plastic coated with a material that is compatible with the resin system and curing technique. This layer shall have an allowance for circumferential stretching during inversion.
- E. Pulled-In-Place Fabric Tube: The outside layer of fabric tube shall have an impermeable plastic coating to contain the resin during and after fabric tube impregnation. The tube shall have an allowance for circumferential and longitudinal stretching during installation.
- F. Any plastic film applied to the tube on what will become the interior wall of the finished CIPP shall be compatible with the resin system used, translucent enough that the resin is clearly visible, and shall be firmly bonded to the felt material.
- G. The resin system shall be a corrosion resistant polyester, vinyl ester, or epoxy and catalyst system that when properly cured meets the minimum requirements given herein.
- H. Thixotropic agents that do not interfere with visual inspection may be added for viscosity control.
- I. Resins may contain pigments, dyes, or colors that do not interfere with visual inspection of the resin-impregnated CIPP or its required properties.
- J. Resin Enhancer: Resin enhancer may be used. Maximum amount of enhancer allowed is 35 pounds enhancer per 100 pounds resin.
- K. Bond Enhancer: If using resin enhancer (e.g., aluminum trihydride) or fiberglass reinforced felt, use a suitable bond-enhancing compound (i.e., Silane or equal) to increase the bond between the resin and other material.
- L. The chemical corrosion resistance of the actual resin system proposed and used by the Contractor shall be tested by the resin manufacturer, in accordance with ASTM F1216, ASTM D543, ASTM D5813, or ASTM C581 as applicable.
- M. For UV-light cured systems a photo initiator shall be added to the resin prior to impregnation.
1. The photo-initiator shall be appropriate to the UV-curing system intended for use.
 2. Ultraviolet curing is not allowed for CIPP lining that is more than eight (8) mm design thickness.
- N. Sealing material shall be as recommended by the CIPP manufacturer and is compatible with the CIPP resin system.
- O. Acceptable materials shall not crack, dry up, or shrink.
- P. Hydraulic cements and quick-set cement products are not acceptable.
- Q. Preliners used to obtain proper cure of CIPP shall be:
1. Reinforced plastic sheet formed into a tube sized to fit the host pipe being lined, and
 2. Continuous with the proposed CIPP in length of the Reach.
- R. Perform design in accordance with ASTM F1216, Appendix X1 or ASTM D3567 and submit to Macon Water Authority.

- S. Prior to design and ordering the CIPP, verify the internal dimensions of the existing sewer main to insure the CIPP will be the appropriate dimension.
- T. Identify all physical properties and parameters of the CIPP in the design submittal.
- U. The design parameters for CIPP thickness calculation shall be the following unless noted otherwise on Contract Drawings:
 - 1. A minimum service life of 50 years under continuous service.
 - 2. All pipes shall be considered fully deteriorated.
 - 3. A minimum overall safety factor of 2.0.
 - 4. A fully saturated surrounding soil, with groundwater levels at ground surface, unless shown otherwise on the Contract Drawings.
 - 5. AASHTO HS-20 Live Load.
 - 6. A soil modulus of elasticity of 700 psi, unless shown otherwise on the Contract Drawings.
 - 7. Dry soil Density of 120 lbs/ft³.
 - 8. The depth of cover for a specific Reach shall be the deepest of the following: adjacent upstream manhole, adjacent downstream manhole, or deepest point between manholes; all as shown on the Contract Drawings.
 - 9. A minimum ovality of 2.0% and maximum long-term deflection of 5%.
 - 10. Enhancement Factor (K) of 7.0.
 - 11. A Poisson's ration of 0.3.
 - 12. A minimum short-term flexural modulus of elasticity (ASTM D790) at 73°F:
 - 13. Polyester System: 250,000 psi
 - 14. Enhanced Polyester System: 400,000 psi
 - 15. Vinyl Ester System: 300,000 psi
 - 16. The materials used shall provide a minimum long-term (50 yr) flexural modulus of elasticity of 125,000 psi (ASTM D790).
 - 17. A minimum flexural strength for gravity lines of 4,500 psi (ASTM D790).
 - 18. Assume no bonding to original pipe wall.
- A. Field verify lengths and inside diameters of pipe to be lined prior to designing and ordering CIPP.
- B. Macon Water Authority will perform water shutoffs to individual properties during installation of the CIPP.
- C. Make every effort to maintain service usage throughout the duration of the project.
- D. In the event that a Lateral will be temporarily out of service, the maximum amount of time of no service shall be 16 hours for any property served by the sewer.
- E. Clean all debris, grease, roots, and other foreign matter from inside of sewers to be rehabilitated in accordance with Section 02956.
 - 1. The sewer shall have no debris prior to CIPP installation.
 - 2. Clear the sewer of obstructions, solids, protruding service lines, collapsed pipe, or any other obstruction that might prevent proper insertion of the CIPP assembly.

3. Cut all protruding services with a remote robotic cutter to allow proper installation of the CIPP.
 4. Notify Macon Water Authority of any obstruction or protruding service that cannot be removed and will prevent successful installation of the CIPP.
 5. Obtain written approval from Macon Water Authority to perform a point repair excavation to uncover and remove or repair the obstruction prior to the commencing point repair work.
- F. Manhole Access and Modifications:
1. Remove manhole frame and cover, chimney and/or cone as needed to achieve minimum access opening as required for the liner inversion process.
- G. Bypassing Sewage:
1. The stormwater system will likely not require bypass pumping. Contractor is advised to coordinate work schedule around anticipated rain events.
- H. Temporary Control of Infiltration:
1. Chemical grout may be used to temporarily control infiltration.
- I. Before starting lining operations:
1. Thoroughly inspect each Reach of sewer being rehabilitated using CCTV immediately before lining the pipe in accordance with Section 02956.
 2. Determine the exact location of all sewer service connections by CCTV inspection.
 3. Pre-lining CCTV inspection is considered incidental to the CIPP lining work unless shown otherwise on the Contract Drawings.
- J. Preliner:
1. Use preliner when infiltration is sufficient to cause resin migration.
 2. Damage to the preliner tube shall be repaired in accordance with the manufacturer's recommendations.
- K. Install CIPP in accordance with the practices given in ASTM F1216 for direct inversion installations, ASTM F1743 for pulled-in-place installations, and ASTM F2019 for UV cured fiberglass installations.
- L. Hydrophilic End Seals:
1. Prior to the installation of the CIPP, insert continuous or properly trimmed hydrophilic end seals to the interior circumference of the existing sewer at the inlet and outlet of each manhole.
 2. Ensure trimmed end seal edges are butted up against each wall per the Manufacturer's recommendation.
 3. End seals shall have no gap between the trimmed edges.
- M. Tube Impregnation:
1. The quantity of resin used for the tube's impregnation shall be sufficient to fill the volume of air voids in the tube with additional allowances being made for polymerization shrinkage and the anticipated loss of any resin through cracks and irregularities in the original pipe wall.
 2. Impregnate the tube using a vacuum or pressure impregnation process in conjunction with a roller system to achieve a uniform distribution of the resin throughout the tube.
- N. Curing:

1. Follow the Manufacturer's recommendations to cure the resin including, but not limited to:
 2. Temperature Monitoring for CIPP in pipes less than 36 inches in diameter using steam or water cure:
 - 1) Temperature at the upstream and downstream manhole as indicated by external thermocouples.
 - 2) Pressure inside the CIPP liner.
 3. Temperature Monitoring System for CIPP in pipes 36 inches in diameter and larger using steam or water cure:
 4. Curing Monitoring System for CIPP using UV Cure shall include the following:
 5. Submit curing logs the same day as the installation of the CIPP
- O. Lateral Reinstatement:
1. Reinstatement all Lateral connections unless the Lateral is visibly capped or unless instructed otherwise by Macon Water Authority.
 2. Open each connection using a remote cutting tool that can cut a hole matching the service connection diameter.
 3. Prevent coupons from passing through the sewer system by collecting them at the next manhole downstream of the pipe rehabilitation operation.
- P. Lateral Connection:
1. Where lateral connections exist, reinstate after main reach lining:
- Q. CIPP Joint at Manholes:
1. Seal ends of CIPP at manhole to achieve watertight pipe seals.
 2. For CIPP passing through manholes,
- R. Styrene and Temperature Control:
1. Take precautions to minimize the release of styrene and mitigate styrene odors generated during the setup and CIPP lining process, and prevent such odors from entering structures, businesses, or other types of establishments, through service connections or other plumbing fixtures.
 2. For CIPP installations in separate storm sewers, at no time will water, condensate, or any other material be allowed to discharge into downstream outfalls or water bodies. Any water, condensate, or other materials shall be contained and pumped to the sanitary sewer system.
 3. For CIPP installations in separate storm sewers, upon completion of cool down process, flush fully-cured and cooled-down CIPP. Flushing shall consist of jetting entire surface of CIPP twice with clean water.
 4. Styrene air emissions shall comply with Federal and District requirements.
- S. After lining work is complete and service connections are reinstated and reactivated, perform a post-installation inspection of the CIPP in accordance with Section 02956.
- T. Post lining CCTV inspection is considered incidental to the CIPP lining work unless shown otherwise on the Contract Drawings.
- U. Restore the project area affected by the Work to a condition at least equal to that existing prior to the work.

- V. Site restoration is considered incidental to the CIPP lining work unless shown otherwise on the Contract Drawings.
- W. Macon Water Authority will verify the physical properties of the installed CIPP using an independent third-party laboratory, at Macon Water Authority's expense, selected by Macon Water Authority.
- X. Prepare and provide field samples to Macon Water Authority for testing as follows:
 - 1. Provide the number of samples for the linear feet (LF) of CIPP installed as follows:
 - e. Less than 1500 LF – one (1) set of three (3) samples from a single location.
 - 2. The samples shall be restrained samples for diameters of CIPP less than 18 inches; and flat plate samples for diameters of CIPP 18 inches and larger.
 - 3. Flat plate samples shall be taken directly from the wet-out tube, clamped between flat plates, and cured in the downtube.
 - 4. Samples for UV cured CIPP shall be restrained bag samples.
 - 5. Label all samples with the date of installation, manhole number, and street address where the sample was taken.
- Y. All tests will be in accordance with applicable ASTM test methods to confirm compliance with the requirements specified in this Section as follows:
 - 1. Thickness.
 - 2. Short term flexural (bending) strength.
 - 3. Short-term flexural modulus of elasticity.
 - 4. Tests will be completed for only one (1) of the three (3) samples collected for a given Reach.
 - 5. The other two (2) samples will be stored by Macon Water Authority for additional testing if any samples fail to meet requirements of this Specification or the applicable ASTM.
- Z. The Contractor may, at its discretion and cost, conduct additional testing using additional samples.
- AA. Acceptance of the CIPP shall be based on compliance with this Section as demonstrated by curing logs, post-installation inspection CCTV, and laboratory test results.
 - 1. The layers of the finished CIPP shall be uniformly bonded such that:
 - 2. The CIPP fits tightly to the internal circumference of the existing pipe, and a membrane integrally bonded to the internal circumference of the felt, thus forming a smooth, chemically inert internal flow surface.
 - 3. Inspection results showing defects that exceed accepted tolerance levels as defined in the table below shall be remedied by the Contractor.
 - 4. The repair method chosen by the Contractor may be the Acceptable Remedy listed in the Table below.
 - 5. The Contractor may also submit an alternative remedy for approval by Macon Water Authority and, if Macon Water Authority approves the alternative remedy, the Contractor shall install the approved remedy.

3.9 ACCEPTANCE:

- a. It shall not be possible to separate any two layers with a probe or point of a knife blade so that the layers separate cleanly, or
- b. That the knife blade moves freely between the layers.
- c. All layers, after cure, form one homogeneous structural pipe wall with no part of tube left unsaturated by resin.

Defects	Accepted Tolerance levels	Acceptable Remedy
Visible leaking through CIPP wall / Pinholes	None	<ul style="list-style-type: none"> • Install internal CIPP spot repair.
Wrinkles / Fins / Folds below the springline	Five (5%) of host Pipe Diameter or less	<ul style="list-style-type: none"> • Remove where recommended by the Manufacturer.
Bubbles / Blistering / Dimples / Lumps / Hot Dogs (Longitudinal Lump) / Foreign Inclusions / Dry Spots	Five (5%) of host Pipe Diameter or less assuming such does not impede flow	<ul style="list-style-type: none"> • Remove defective portion of CIPP and install internal CIPP spot repair following recommendations from the Manufacturer.
Lateral Overcut	< ½ inch	<ul style="list-style-type: none"> • A one (1) piece homogenous main and lateral CIPP connection liner, or • Lateral connection reconstruction seals or structural grout in accordance with NASSCO “Performance Specification Guideline for Lateral Rehabilitation – Lateral Seals”
Cracks	None	<ul style="list-style-type: none"> • Install internal CIPP spot repair.
Delamination	None	<ul style="list-style-type: none"> • Remove defective portion of CIPP and install internal CIPP spot repair.
Bursts / Collapse / Unravel / Lifts	None	<ul style="list-style-type: none"> • Remove defective portion of CIPP and install internal CIPP spot repair.
Seals at Termination Points not Water Tight	None	<ul style="list-style-type: none"> • Repair and/or replace.

END OF SECTION