



OVERFLOW REPORT

BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

Executive Director
& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

DATE OF OVERFLOW: Wednesday, March 26, 2025, 2:40 pm – 5:05 pm

REPORT SUBMITTED: Friday, March 28, 2025

LOCATION OF OVERFLOW: – [Flint Rock Park Lift Station](#) - Lift Station ID: 50

CAUSE OF OVERFLOW: We determined that the minor overflow was caused by a leaking force main.

ESTIMATED VOLUME DISCHARGED: 100 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Tobesofkee

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Wednesday, March 26, 2025

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The force main has been repaired.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Marlayzha Griffin