

MINOR SPILL REPORT TO EPD

BOARD MEMBERS
Gary Bechtel
Chairman
Frank Patterson
Vice-Chairman
Elaine H. Lucas
Desmond Brown
Dwight Jones
Bill Howell
Valerie Wynn

Ron Shipman
Executive Director
& President

790 Second Street

P.0.Box 108 Macon, GA 31202 (478) 464-5600 Fax: (478) 750-2007 MaconWater.org EPD Watershed Protection Branch 2 Martin Luther King, Jr. Drive Suite 1152 Atlanta, GA 30334

DATE OF MINOR SPILL: Tuesday, April 8, 2025, 8:07 pm – Wednesday, April 9, 2025,

9:20 am

REPORT SUBMITTED: Friday, April 11, 2025

LOCATION OF MINOR SPILL: 308 Carrick Way - MH ID: 62170

(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After removing the blockage, we determined that the minor spill was caused by grease in the sewer main. No commercial sources of grease have been identified upstream from the spill location.

ESTIMATED VOLUME DISCHARGED: 6,344 gallons

(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Wolf Creek

SERVICE BASIN AFFECTED: Wolf Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Wednesday, April 9, 2025

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled for cleaning and CCTV inspection. The details of this spill have been forwarded to our Grease Management team for further investigation. Additionally, this line has been added to the Hotspot Inspection list for ongoing monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Marlayzha Griffin