



## MAJOR OVERFLOW REPORT

### BOARD MEMBERS

Gary Bechtel

*Chairman*

Frank Patterson

*Vice-Chairman*

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

**Executive Director  
& President**

---

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

[MaconWater.org](http://MaconWater.org)

**DATE OF OVERFLOW:** Thursday, June 26, 2025, 1:30 am – 9:00 am

**REPORT SUBMITTED:** Tuesday, July 1, 2025

**LOCATION OF OVERFLOW:** [1011 Walker Swamp Road](#) – MH IDs: 64096, 64094, 64091, 61093, and 61100

*(Please note that the address used is a reference for the location of the manholes.)*

**CAUSE OF OVERFLOW:** The cause of this major overflow was due to a power outage at our Lower Poplar Water Reclamation Facility.

**ESTIMATED VOLUME DISCHARGED:** 1,150,000 gallons

*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**SERVICE BASIN AFFECTED:** Bay Street

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area. The affected area has also been treated with an enzyme-based organic waste treatment called Bio-bug.

**OVERFLOW STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** Thursday, June 26, 2025

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** The power failure issue was resolved, and service was restored to the plant.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon-Bibb County Health Department

**REPORT SUBMITTED BY:** Bryan Jones