



**BOARD MEMBERS**

Gary Bechtel

*Chairman*

Frank Patterson

*Vice-Chairman*

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

**Executive Director**

**& President**

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

[MaconWater.org](http://MaconWater.org)

**MINOR SPILL REPORT TO EPD**

**EPD Watershed Protection Branch**  
**2 Martin Luther King, Jr. Drive**  
**Suite 1152**  
**Atlanta, GA 30334**

**DATE OF MINOR SPILL:** Tuesday, July 8, 2025, 6:24 pm – 8:00 pm

**REPORT SUBMITTED:** Friday, July 11, 2025

**LOCATION OF MINOR SPILL:** [3443 McKenzie Drive](#) - MH ID: 61796  
(Please note that the address used is a reference for the location of the manhole.)

**CAUSE OF MINOR SPILL:** The cause of this minor spill was hydraulic overload due to heavy rains in the MWA service area and a rising creek level.

**ESTIMATED VOLUME DISCHARGED:** 4,950 gallons  
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

**RECEIVING WATERS:** Ditch feeding Dillon Branch

**SERVICE BASIN AFFECTED:** Lower Rocky Creek

**WRF SERVICE AREA NPDES PERMIT:** GA0024546

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:**  
Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

**SPILL STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** Wednesday, July 9, 2025

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** The Macon Water Authority will continue investigating sources of inflow and infiltration into its system. We will also schedule to have this line cleaned and televised.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

**REPORT SUBMITTED BY:** Bryan Jones