

Addendum No.1

Lower Rocky Creek WRF 42" & 24" Gravity Sewer Rehabilitation

Macon, Georgia,

Date: September 04, 2025

This addendum forms a part of the Contract Documents and modifies the original Specifications and Contract Documents as noted below. Acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may result in disqualification of the bidder.

The following additions/changes modify the Request for Proposal for the referenced project, dated August 21, 2025.

Questions

Q1. Would shotcrete or Thermoform be an acceptable alternative liner instead of the CIPP for this project?

A1. No, shotcrete or Thermoform are not approved alternatives to CIPP lining for this project.

Q2. Would CIPP Liner (Flexible Liner Tube) Manufacturers other than those listed in Specification Section 33 01 30.70, 2.01.C.2.16 need any form of pre-approval to be able to bid on this project?

A2. Yes, other manufacturers may be considered if the felt and resin meet the specification requirements. Product data must be submitted for review and approval by MWA.

Q3. Would the owner consider Quadex Structure Guard an approved epoxy liner for manhole rehabilitation per Specification Section 33 01 30.80?

A3. No, the preferred epoxy product is Tnemec Epoxy Series. Quadex Structure Guard will not be approved as an alternative.

Q4. Would the owner consider Quadex GeoKrete an approved alternative for manhole rehabilitation per Specification Section 33 01 30.80?

A4. No, the preferred product is SewperCoat. Quadex GeoKrete will not be approved as an alternative.

Q5. Please advise if the engineers estimate is available for the project.

A5. The available project budget is listed on the Georgia Procurement Register. A detailed engineering cost estimate will not be provided.

No fee adjustment shall be made for a failure to understand, or for a misinterpretation of the contract documents.

REQUIRED CONFIRMATION OF RECEIPT:

Acknowledge receipt of this addendum by return e-mail and as required on the Bid form
*"Section 00300-3" of the contract documents.