



BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

Executive Director

& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

MAJOR SPILL REPORT TO EPD

EPD Watershed Protection Branch

2 Martin Luther King, Jr. Drive

Suite 1152

Atlanta, GA 30334

DATE OF MAJOR SPILL: Monday, September 22, 2025, 12:15 pm – Tuesday, September 23, 2025, 5:30 am

REPORT SUBMITTED: Wednesday, September 24, 2025

LOCATION OF MAJOR SPILL: [1566 North Atwood Drive](#) – Gravity Main ID: 12826
(Please note that the address used is a reference for the location of the gravity main.)

CAUSE OF MAJOR SPILL: The cause of this major spill was due to a broken sewer main.

ESTIMATED VOLUME DISCHARGED: 14,490 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Rocky Creek

SERVICE BASIN AFFECTED: Lower Rocky Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The debris has been removed. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Monday, September 22, 2025

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The sewer main has been repaired.

MONITORING INITIATED: Tuesday, September 23, 2025

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGH (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Marlayzha Griffin