



OVERFLOW REPORT

BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

**Executive Director
& President**

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

DATE OF OVERFLOW: Thursday, October 23, 2025, 11:20 am – 1:30 pm

REPORT SUBMITTED: Tuesday, October 28, 2025

LOCATION OF OVERFLOW: [106 Fairways Court](#) – MH ID: 62800
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After a thorough investigation, we determined that the overflow was a result of damage to our sewer main caused by an independent contractor.

ESTIMATED VOLUME DISCHARGED: 1,040 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Upper Rocky Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
Debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Friday, October 24, 2025

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The sewer main is scheduled for repair.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Marlayzha Griffin

