



## OVERFLOW REPORT

### BOARD MEMBERS

Gary Bechtel

*Chairman*

Frank Patterson

*Vice-Chairman*

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

**Executive Director  
& President**

---

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

[MaconWater.org](http://MaconWater.org)

**DATE OF OVERFLOW:** Friday, November 14, 2025, 10:55 am – 1:00 pm

**REPORT SUBMITTED:** Tuesday, November 18, 2025

**LOCATION OF OVERFLOW:** [648 Paul Street](#) – MH ID: 52904  
(Please note that the address used is a reference for the location of the manhole.)

**CAUSE OF OVERFLOW:** After clearing the blockage, we determined that the minor overflow was caused by rags and debris in the sewer main.

**ESTIMATED VOLUME DISCHARGED:** 2,500 gallons  
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

**SERVICE BASIN AFFECTED:** Lower Rocky Creek

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:**  
The blockage has been cleared, and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

**OVERFLOW STATUS:** The blockage has been removed; sewage is no longer escaping.

**SIGNS POSTED:** Friday, November 14, 2025

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** This line is scheduled for cleaning and CCTV inspection. It will also be added to the Hotspot Inspection list for ongoing monitoring.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon-Bibb County Health Department

**REPORT SUBMITTED BY:** Marlayzha Griffin