Macon Water Authority

BOARD MEMBERS
Gary Bechtel
Chairman
Frank Patterson
Vice-Chairman
Elaine H. Lucas
Desmond Brown
Dwight Jones
Bill Howell
Valerie Wynn

Ron Shipman
Executive Director
& President

790 Second Street

P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MINOR SPILL: Sunday, December 21, 2025, 11:40 am – 2:30 pm

REPORT SUBMITTED: Tuesday, December 23, 2025

LOCATION OF MINOR SPILL: 1795 Anthony Road - MH ID: 55419
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After removing the blockage, we determined that the minor spill was caused by rags in the sewer main.

ESTIMATED VOLUME DISCHARGED: 3,400 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

RECEIVING WATERS: Ditch feeding Rocky Creek

SERVICE BASIN AFFECTED: Lower Rocky Creek

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Sunday, December 21, 2025

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled for cleaning and CCTV inspection. It will also be added to our Hot Spot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Marlayzha Griffin