Macon Water Authority

BOARD MEMBERS
Gary Bechtel
Chairman
Frank Patterson
Vice-Chairman
Elaine H. Lucas
Desmond Brown
Dwight Jones
Bill Howell
Valerie Wynn

Ron Shipman
Executive Director
& President

790 Second Street

P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MINOR SPILL: Tuesday, December 9, 2025, 7:00 pm – 10:20 pm

REPORT SUBMITTED: Friday, December 12, 2025

LOCATION OF MINOR SPILL: 624 Forest Hill Road - MH ID: 66990
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After removing the blockage, we determined that the minor spill was caused by grease and debris in the sewer main. No commercial sources of grease have been identified upstream from the spill location.

ESTIMATED VOLUME DISCHARGED: 8,000 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

RECEIVING WATERS: Tributary to Sabbath Creek

SERVICE BASIN AFFECTED: Sabbath Creek

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, December 9, 2025

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled for cleaning and CCTV inspection. The details of this spill have been forwarded to our Grease Management team for further investigation, and we will continue to monitor this area.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Marlayzha Griffin