Macon Water Authority

BOARD MEMBERS
Gary Bechtel
Chairman
Frank Patterson
Vice-Chairman
Elaine H. Lucas
Desmond Brown
Dwight Jones
Bill Howell
Valerie Wynn

Ron Shipman
Executive Director
& President

790 Second Street

P.0.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Thursday, January 8, 2026, 2:32 pm – 5:00 pm

REPORT SUBMITTED: Monday, January 12, 2026

LOCATION OF OVERFLOW: 1011 Walker Swamp Road – MH ID: 81992
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After clearing the blockage, we determined that the minor overflow was caused by roots in the sewer main.

ESTIMATED VOLUME DISCHARGED: 1,924 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Lower Rocky Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: The blockage has been cleared, and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Friday, January 9, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This line is scheduled to be repaired. It will also be added to the Hotspot Inspection list for ongoing monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Marlayzha Griffin