



## OVERFLOW REPORT

### BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

Executive Director

& President

---

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

[MaconWater.org](http://MaconWater.org)

**DATE OF OVERFLOW:** Monday, January 26, 2026, 9:15 am – 10:50 am

**REPORT SUBMITTED:** Thursday, January 29, 2026

**LOCATION OF OVERFLOW:** [Intersection of Brookdale Avenue & Melrose Street](#) – MH ID: 60927

*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF OVERFLOW:** After clearing the blockage, we determined that the minor overflow was caused by grease in the sewer main.

**ESTIMATED VOLUME DISCHARGED:** 1,900 gallons

*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**SERVICE BASIN AFFECTED:** Lower Rocky Creek

### **CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:**

The blockage has been cleared, and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

**OVERFLOW STATUS:** The blockage has been removed; sewage is no longer escaping.

**SIGNS POSTED:** Monday, January 26, 2026

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** This line is scheduled for cleaning and CCTV inspection. It will also be added to the Hotspot Inspection list for ongoing monitoring.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon-Bibb County Health Department

**REPORT SUBMITTED BY:** Marlayzha Griffin



**BOARD MEMBERS**

**Gary Bechtel**

*Chairman*

**Frank Patterson**

*Vice-Chairman*

**Elaine H. Lucas**

**Desmond Brown**

**Dwight Jones**

**Bill Howell**

**Valerie Wynn**

**Ron Shipman**

**Executive Director**

**& President**

---

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

**[MaconWater.org](http://MaconWater.org)**

