



## OVERFLOW REPORT

### BOARD MEMBERS

Gary Bechtel

*Chairman*

Frank Patterson

*Vice-Chairman*

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

*Executive Director*

*& President*

---

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

[MaconWater.org](http://MaconWater.org)

**DATE OF OVERFLOW:** Saturday, January 31, 2026, 10:17 am – 12:04 pm

**REPORT SUBMITTED:** Wednesday, February 4, 2026

**LOCATION OF OVERFLOW:** [1243 Baker Drive](#) – MH ID: 52456  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF OVERFLOW:** After clearing the blockage, we determined that the minor overflow was caused by grease and rags in the sewer main. Commercial sources of grease have been identified upstream from this location.

**ESTIMATED VOLUME DISCHARGED:** 856 gallons  
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**SERVICE BASIN AFFECTED:** Lower Rocky Creek

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:**  
The blockage has been cleared, and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

**OVERFLOW STATUS:** The blockage has been removed; sewage is no longer escaping.

**SIGNS POSTED:** Saturday, January 31, 2026

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** This line is scheduled for cleaning and CCTV inspection. It will also be added to the Hotspot Inspection list for ongoing monitoring. Additionally, the details of this overflow have been forwarded to our Grease Management team for further investigation. We will continue to monitor this location

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon-Bibb County Health Department

**REPORT SUBMITTED BY:** Marlayzha Griffin