



OVERFLOW REPORT

DATE OF OVERFLOW: Wednesday, March 11, 2026, 1:26 pm – 2:44 pm

REPORT SUBMITTED: Friday, March 13, 2026

LOCATION OF OVERFLOW: [239 Rogers Ave](#) – MH ID: Unmapped manhole
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After clearing the blockage, we determined that the minor overflow was caused by roots and rags in the sewer main.

ESTIMATED VOLUME DISCHARGED: 1,560 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Riverside

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Wednesday, March 11, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This line is scheduled for cleaning and CCTV inspection. It will also be added to the Hotspot Inspection list for ongoing monitoring. The unmapped manhole will be updated in our mapping system.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Marlayzha Griffin

BOARD MEMBERS

Gary Bechtel
Chairman

Frank Patterson
Vice-Chairman

Elaine H. Lucas

Dwight Jones

Bill Howell

Valerie Wynn

Michel Wanna
Interim Executive
Director &
President

790 Second Street

P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
[MaconWater.org](#)