



OVERFLOW REPORT

BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Dwight Jones

Bill Howell

Valerie Wynn

Michel Wanna

Interim Executive

Director &

President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

DATE OF OVERFLOW: Thursday, March 26, 2026, 7:30 am – 8:30 am

REPORT SUBMITTED: Monday, March 30, 2026

LOCATION OF OVERFLOW: [905 Main Street](#) – MH ID:59196
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After clearing the blockage, we determined that the minor overflow was caused by grease in the sewer main. No commercial sources of grease have been identified upstream from the spill location.

ESTIMATED VOLUME DISCHARGED: 480 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Main Street

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The blockage has been cleared, and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Thursday, March 26, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This line is scheduled for cleaning and CCTV inspection. It will also be added to the Hotspot Inspection list for ongoing monitoring. This information has been forwarded to our Grease Management Team for further investigation.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Marlayzha Griffin