

**ADDENDUM NO. 2**

**STRUCTURAL REPAIRS FOR AMERSON WTP**

**MACON WATER AUTHORITY  
MACON, GEORGIA**

**ADDITIONAL INFORMATION DOCUMENTS**

The following document:

- Questions and Responses

is being provided with this addendum for informational purposes only. The document listed above is not, and will not, be considered as part of the Contract Documents.

**PLANS**

No modifications to the plans are included in this addendum.

**SPECIFICATIONS**

No modifications to the specifications are included in this addendum.

***Bidder Must Acknowledge Receipt of this Addendum on Bid Form***

March 18, 2026  
Barge Design Solutions, Inc.  
1201 Front Ave, Suite F  
Columbus, Georgia 31901  
706-321-4583

## QUESTIONS AND RESPONSES

### STRUCTURAL REPAIRS FOR AMERSON WTP

#### MACON WATER AUTHORITY MACON, GEORGIA

#### **QUESTIONS:**

Question: The specifications reference pressure grouting as the method for slab and foundation stabilization. We request clarification on whether polyurethane injection may be used in lieu of pressure grouting. Polyurethane injection offers comparable void-filling and soil stabilization performance with the added benefit of controlled, low-pressure application, which may be preferable given the proximity to existing structural elements. Please confirm whether this substitution is acceptable, or advise of any conditions or limitations that would apply.

Response: Barge takes no exception to polyurethane injection as an alternate to pressure grouting for this application. Contractor to submit product data for review.

Question: For pipe sealing applications identified in the project scope, we request clarification on whether single-component waterproofing grout or foam products are acceptable alternatives to any multi-component systems specified. Please confirm whether these products are permissible and, if so, whether there are specific performance criteria or product submittals required for approval.

Response: Single component product data may be submitted for review but must comply with NSF 61. Contractor to submit product data for review prior to installation

Barge Design Solutions, Inc.  
1201 Front Ave, Suite F  
Columbus, Georgia 31901  
706-321-4590