



BOARD MEMBERS

Gary Bechtel
Chairman

Frank Patterson
Vice-Chairman

Elaine H. Lucas
Dwight Jones

Bill Howell
Valerie Wynn

Michel Wanna
Interim Executive
Director &
President

790 Second Street

P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MINOR SPILL: Monday, May 4, 2026, 11:29 am – 1:30 pm

REPORT SUBMITTED: Friday, May 8, 2026

LOCATION OF MINOR SPILL: [279 Belvedere Drive](#) - MH ID: 70774
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After removing the blockage, we determined that the minor spill was caused by rags in the sewer main.

ESTIMATED VOLUME DISCHARGED: 2,420 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Bowman Creek

SERVICE BASIN AFFECTED: Corbin Avenue

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Monday, May 4, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled for cleaning and CCTV inspection. It will also be added to our Hot Spot inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Marlayzha Griffin