



## MINOR SPILL REPORT TO EPD

### BOARD MEMBERS

Gary Bechtel  
*Chairman*

Frank Patterson  
*Vice-Chairman*

Elaine H. Lucas  
Dwight Jones

Bill Howell  
Valerie Wynn

Michel Wanna  
Interim Executive  
Director &  
President

790 Second Street

P.O.Box 108  
Macon, GA 31202  
(478) 464-5600  
Fax: (478) 750-2007  
[MaconWater.org](http://MaconWater.org)

EPD Watershed Protection Branch  
2 Martin Luther King, Jr. Drive  
Suite 1152  
Atlanta, GA 30334

**DATE OF MINOR SPILL:** Thursday, June 11, 2026, 3:45 pm – 5:30 pm

**REPORT SUBMITTED:** Tuesday, June 16, 2026

**LOCATION OF MINOR SPILL:** [4089 Broadway](#) - MH ID:51864  
(Please note that the address used is a reference for the location of the manhole.)

**CAUSE OF MINOR SPILL:** After removing the blockage, we determined that the minor spill was caused by rags in the sewer main.

**ESTIMATED VOLUME DISCHARGED:** 2,100 gallons  
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

**RECEIVING WATERS:** Ditch feeding Ocmulgee River

**SERVICE BASIN AFFECTED:** Lower Rocky Creek

**WRF SERVICE AREA NPDES PERMIT:** GA0024546

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

**SPILL STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** Thursday, June 11, 2026

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** This line is scheduled for cleaning and CCTV inspection. It will also be added to our Hot Spot Inspection list for monitoring.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

**REPORT SUBMITTED BY:** Marlayzha Griffin