



## MINOR SPILL REPORT TO EPD

### BOARD MEMBERS

Gary Bechtel  
*Chairman*

Frank Patterson  
*Vice-Chairman*

Elaine H. Lucas  
Dwight Jones

Bill Howell  
Valerie Wynn

Michel Wanna  
Interim Executive  
Director &  
President

---

790 Second Street

P.O.Box 108  
Macon, GA 31202  
(478) 464-5600  
Fax: (478) 750-2007  
[MaconWater.org](http://MaconWater.org)

**EPD Watershed Protection Branch**  
**2 Martin Luther King, Jr. Drive**  
**Suite 1152**  
**Atlanta, GA 30334**

**DATE OF MINOR SPILL:** Monday, June 8, 2026, 11:43 am – 2:40 pm

**REPORT SUBMITTED:** Friday, June 12, 2026

**LOCATION OF MINOR SPILL:** [6300 Moseley Dixon Road](#) - MH ID: 86368  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF MINOR SPILL:** After removing the blockage, we determined that the minor spill was caused by a sewer plug lodged in the sewer main.

**ESTIMATED VOLUME DISCHARGED:** 3,540 gallons  
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**RECEIVING WATERS:** Ditch feeding Lake Tobesofkee

**SERVICE BASIN AFFECTED:** Tobesofkee

**WRF SERVICE AREA NPDES PERMIT:** GA0024546

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

**SPILL STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** Monday, June 8, 2026

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** The sewer plug has been removed from the sewer main. This line will be added to our Hotspot inspection list for monitoring.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

**REPORT SUBMITTED BY:** Marlayzha Griffin