



BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Marshall Talley

Dwight Jones

Bill Howell

Valerie Wynn

Michel Wanna

Interim Executive

Director &

President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Tuesday, July 28, 2026, 12:29 pm – 2:05 pm

REPORT SUBMITTED: Friday, July 31, 2026

LOCATION OF OVERFLOW: [3823 Overlook Avenue](#) – Main ID: 45336
(Please note that the address used is a reference for the location of the sewer main.)

CAUSE OF OVERFLOW: After clearing the blockage, we determined that the minor overflow was caused by grease and roots in the sewer main.

ESTIMATED VOLUME DISCHARGED: 768 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that overflowed from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Corbin

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: The blockage has been cleared, and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, July 28, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This line is scheduled for cleaning and CCTV inspection. The details of this overflow have been forwarded to our Grease Management team for further investigation. It will also be added to our Hot Spot Inspection list for monitoring and is scheduled for chemical treatment to address root intrusion.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Marlayzha Griffin