



BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Marshall Talley

Dwight Jones

Bill Howell

Valerie Wynn

Michel Wanna

Interim Executive

Director &

President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Monday, August 3, 2026, 8:00 am – 8:30 am

REPORT SUBMITTED: Thursday, August 5, 2026

LOCATION OF OVERFLOW: [3299 North O'Hara Drive](#) – Force Main ID: 62
(Please note that the address used is a reference for the location of the force main.)

CAUSE OF OVERFLOW: This minor overflow was caused by a broken cleanout on a force main.

ESTIMATED VOLUME DISCHARGED: 2,000 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: O'Hara

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Monday, August 3, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This force main cleanout has been repaired.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Marlayzha Griffin