



MINOR SPILL REPORT TO EPD

BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Marshall Talley

Dwight Jones

Bill Howell

Valerie Wynn

Michel Wanna

Executive Director

& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

EPD Watershed Protection Branch

2 Martin Luther King, Jr. Drive

Suite 1152

Atlanta, GA 30334

DATE OF MINOR SPILL: Wednesday, September 2, 2026, 10:11 am – Friday, September 4, 2026, 1:00 pm

REPORT SUBMITTED: Friday, September 4, 2026

LOCATION OF MINOR SPILL: [216 Troon West](#) – Main ID: 42864

(Please note that the address used is a reference for the location of the sewer main.)

CAUSE OF MINOR SPILL: During an aerial inspection of the sewer main, a minor leak was discovered. A shovel was also found lodged in the invert of the downstream manhole. After the initial repair was completed, another leak occurred. Additional parts needed for the repair had to be ordered, resulting in a 24-hour delay.

ESTIMATED VOLUME DISCHARGED: 8,000 gallons

*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

RECEIVING WATERS: Wolf Creek

SERVICE BASIN AFFECTED: Wolf Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Friday, September 4, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The sewer main has been repaired.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGH (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones