



BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Marshall Talley

Dwight Jones

Bill Howell

Valerie Wynn

Michel Wanna

Executive Director
& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Thursday, September 10, 2026, 8:22 am – 1:25 pm

REPORT SUBMITTED: Monday, September 14, 2026

LOCATION OF OVERFLOW: [229 Great Waters Lane](#) – Force Main: 68
(Please note that the address used is a reference for the location of the force main.)

CAUSE OF OVERFLOW: The force main was damaged during construction by an independent contractor, which caused sewage to escape from the pipe.

ESTIMATED VOLUME DISCHARGED: 200 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Tobesofkee

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The debris has been removed. This affected area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Thursday, September 10, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The force main has been repaired.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Monroe County / Macon Reporter and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Marlayzha Griffin