



OVERFLOW REPORT

BOARD MEMBERS

Gary Bechtel
Chairman

Frank Patterson
Vice-Chairman

Elaine H. Lucas

Marshall Talley

Dwight Jones

Bill Howell

Valerie Wynn

Michel Wanna
Executive Director
& President

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

DATE OF OVERFLOW: Monday, September 14, 2026, 8:50 am – 11:15 am

REPORT SUBMITTED: Friday, September 18, 2026

LOCATION OF OVERFLOW: [3299 O'Hara Drive, North](#) – Force Main ID: 62
(Please note that the address used is a reference for the location of the force main.)

CAUSE OF OVERFLOW: After investigation, the cause of this overflow was determined to be a crack in the force main, which allowed sewage to escape.

ESTIMATED VOLUME DISCHARGED: 350 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: O'Hara

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
Debris has been removed from the area. The affected area has been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Monday, September 14, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The force main has been repaired.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Monroe County / Macon Reporter and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Marlayzha Griffin