



BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Marshall Talley

Dwight Jones

Bill Howell

Valerie Wynn

Michel Wanna

**Executive Director
& President**

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MINOR SPILL: Sunday, October 4, 2026, 2:02 pm – 4:30 pm

REPORT SUBMITTED: Thursday, October 8, 2026

LOCATION OF MINOR SPILL: [229 Great Waters Lane](#) – Force Main ID: 68
(Please note that the address used is a reference for the location of the force main.)

CAUSE OF MINOR SPILL: The force main was damaged during construction by an independent contractor, which caused sewage to escape from the pipe.

ESTIMATED VOLUME DISCHARGED: 2,880 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Storm drain

SERVICE BASIN AFFECTED: Tobesofkee

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Sunday, October 4, 2026

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The force main has been repaired.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Monroe County / Macon Reporter, WMAZ (TV), WMGH (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Marlayzha Griffin